

**MPUC Docket No. E-6472-/M-05-1993
OAH Docket No. 12-2500-17260-2**

BEFORE THE
MINNESOTA OFFICE OF ADMINISTRATIVE HEARINGS
100 Washington Square, Suite 1700
Minneapolis, Minnesota 55401-2138

FOR THE
MINNESOTA PUBLIC UTILITIES COMMISSION
127 7th Place East, Suite 350
St. Paul, Minnesota 55101-2147

In the Matter of the Petition of Excelsior Energy Inc.
and Its Wholly-Owned Subsidiary MEP-I, LLC For Approval of Terms and
Conditions For The Sale of Power From Its Innovative Energy Project Using
Clean Energy Technology Under Minn. Stat. § 216B.1694 and a
Determination That the Clean Energy Technology Is Or Is Likely To Be a
Least-Cost Alternative Under Minn. Stat. § 216B.1693

**PREPARED REBUTTAL TESTIMONY AND EXHIBITS OF
EXCELSIOR ENERGY INC. AND MEP-I LLC**

BAXTER JONES

OCTOBER 10, 2006

1 **EXCELSIOR ENERGY, INC.**

2 **BEFORE THE MINNESOTA PUBLIC UTILITIES COMMISSION**

3 **PREPARED REBUTTAL TESTIMONY OF**

4 **BAXTER JONES**

5 **Q Please state your name and business address.**

6 A My name is Baxter Jones and I am Senior Vice President for ICF International,
7 9300 Lee Highway, Fairfax, Virginia 22031.

8 **Q Have you previously provided testimony in this proceeding?**

9 A Yes. On June 19, 2006, I filed Direct Testimony on behalf of MEP-I LLC and
10 Excelsior Energy Inc. (collectively, “Excelsior”) relating to the ICF Consulting’s Final
11 Report entitled Air Quality and Health Benefits Modeling: Relative Benefits Derived
12 From Operation of the MEP-I/II IGCC Power Station (hereafter, the “Health Benefits
13 Report”). See Exhibit TLO-2 to the Supplemental Testimony of Thomas L. Osteraas.

14 **I. SCOPE AND SUMMARY**

15 **Q What is the purpose of your Rebuttal Testimony in this proceeding?**

16 A The purpose of my rebuttal testimony is to respond to the Direct Testimony and
17 Schedules of Northern States Power Company (“NSP”), d/b/a Xcel Energy witness
18 Roger A. Clarke. Mr. Clarke raises issues concerning the following elements related to
19 my Direct Testimony:

- 20 1. Concerns with respect to the differences noted between the emissions
21 modeled by ICF in the health benefits analysis and emissions Excelsior
22 set forth in the New Source Review Construction Authorization Permit
23 Application submitted on June 28, 2006 to the Minnesota Pollution
24 Control Agency (hereafter, the “PSD Permit Application”).

1 2. The impact of such differences on the overall conclusions found in the
2 Health Benefits Report.

3 I also testify herein to the potential added regulatory pressure that likely will be
4 brought to bear on new sources of PM_{2.5} precursors seeking permits in states like
5 Minnesota, since these PM_{2.5} precursors have been found to cause or contribute to
6 violations of PM_{2.5} National Ambient Air Quality Standards (“NAAQS”).

7 Emissions Characterizing the IGCC and SCPC Power Stations

8 **Q Please address the concern raised by Mr. Clarke regarding the difference between**
9 **the annual emissions presented in ICF’s Health Benefits Report and the annual**
10 **emissions presented in Excelsior’s PSD Permit Application?**

11 A I have reviewed Mr. Clarke’s direct testimony and determined Mr. Clarke’s
12 concern to be unwarranted.

13 **Q Why is that so?**

14 A ICF’s model uses hourly emissions as input data, not annual emissions.
15 Mr. Evans in his rebuttal testimony correctly identifies the differences between the
16 hourly emissions modeled by ICF and the hourly emissions presented in the PSD Permit
17 Application.

18 **Q Given the differences noted by Mr. Evans between the hourly emissions modeled**
19 **by ICF and the hourly emissions noted in the permit application, is there any need**
20 **to alter the conclusions stated in ICF’s Health Benefit Report?**

21 A No. The difference in hourly emissions between the values used in ICF’s
22 modeling and the values in the PSD Permit Application do not justify concerns
23 regarding the conclusions reflected in ICF’s Health Benefit Report.

1 **Q Why is that so?**

2 A The differences between what ICF modeled and what is contained in the PSD
3 Permit Application are small, relative to the emissions ICF modeled for the SCPC plant.
4 That is, even without the 35 lb decrease (relative to the PSD permit application) in the
5 hourly emissions for SO₂ modeled by ICF, the SO₂ emissions from the IGCC Power
6 Station still would be substantially smaller than the SO₂ emissions from the SCPC plant,
7 and the change that this difference causes in fine particulate matter should be at least
8 partially offset by the 18 pound per hour increase (relative to the PSD permit
9 application data) in hourly NO_x emissions modeled by ICF. See Mr. Evans' testimony
10 at pages 10 through 12. I should note that without additional detailed modeling, it is
11 difficult to predict the precise degree to which the offset would occur.

12 **Q Even so, do the conclusions of ICF's health benefits analysis remain intact?**

13 A Yes, the conclusion that there would be significant health impact benefits and
14 damage cost benefits attributable to Excelsior's proposed IGCC plant relative to an
15 Alternative SCPC plant, remains well-supported and reasonable.

16 Regulatory Pressure to Reduce Fine Particulate Matter

17 **Q Please briefly explain the environmental concerns over fine particulate matter and**
18 **the regulations that have been put in place to deal with those concerns.**

19 A As noted in the Health Benefit Report, fine particulate matter (otherwise known
20 as PM_{2.5}) has been shown to more highly correlate with adverse health effects of
21 ambient particulate matter exposures than do other measures of particulate matter
22 exposure. As a result, the U.S. EPA has established National Ambient Air Quality
23 Standards (NAAQS) for PM_{2.5} (most recently updated in 2006) and begun the process
24 of identifying sources that cause or contribute to ambient violations of these standards.

1 In addition, in 2005 the U.S. EPA promulgated the Clean Air Interstate Rule (CAIR) ,
2 which focuses on reducing emissions across broad geographical regions, in an attempt
3 to reduce instances where the PM_{2.5} standards are violated.

4 **Q What has been the response of large electric generating units across the eastern**
5 **U.S. in response to the requirements imposed under the Acid Rain Program and**
6 **CAIR?**

7 A Many facilities are in the process of reducing their emissions of SO₂ and NO_x
8 (both being contributors to acid rain and precursors of fine particulate matter).

9 **Q Based on the work you have conducted for Excelsior and other work that is not**
10 **proprietary, do you believe that decreased emissions of SO₂ and NO_x will translate**
11 **to health benefits?**

12 A Yes. SO₂ and NO_x are known to be important precursors of fine particulate
13 matter, and reduced emissions of these compounds would result in lower ambient levels
14 of fine particulates, which would be expected to translate into reduced health impacts
15 (i.e., increased health benefits). This is a basic scientific underpinning of the SO₂ and
16 NO_x emission reductions required by EPA's CAIR program.

17 **Q Therefore, now that scientific evidence has shown a growing correlation between**
18 **fine particulate matter and health impacts, and knowing that large, coal-fired**
19 **electric generating units emit relatively large quantities of fine particulate**
20 **precursors (e.g., SO₂ and NO_x), is it reasonable to presume that added pressure**
21 **will be placed on proposed new electric generating units located within CAIR**
22 **States to lower their SO₂ and NO_x emissions relative to what they would otherwise**
23 **be required to do in the absence of the PM_{2.5} regulations?**

1 A Yes. CAIR states, including Minnesota, have restrictive emission budgets for
2 fine particulate precursors under CAIR, and it is reasonable to presume that new coal-
3 fired electric generating units will be under increased pressure to reduce emissions of
4 such precursors.

5 **Q Would it then be reasonable to suggest that a technology already having an**
6 **emission profile exhibiting significantly lower emissions of PM_{2.5} precursors (that**
7 **is, capable of superior performance relative to other technologies' emissions of SO₂**
8 **and NO_x) could be considered to have already internalized the cost of complying**
9 **with PM_{2.5} regulations?**

10 A In general, yes. Of course, I would have to know the specific location of the
11 source and its SO₂ and NO_x emission rates before providing a definitive answer. In
12 terms of the Minnesota circumstance of which I modeled, there would probably be
13 added pressure to reduce the level of emissions from the Central Minnesota SCPC plant
14 solely because of its PM_{2.5} impacts on downwind receptors.

15 **Q Does this conclude your testimony?**

16 A Yes.