

Direct Testimony and Schedules  
Richard Gonzalez

State of Minnesota  
Before the Office of Administrative Hearings  
For the Minnesota Public Utilities Commission

*In the Matter of a Petition by Excelsior Energy Inc. for Approval of a Power  
Purchase Agreement Under Minn. Stat. § 216B.1694, Determination of Least  
Cost Technology, and Establishment of a Clean Energy Technology Minimum  
Under Minn. Stat. § 216B.1693*

OAH Docket No. 12-2500-17260-2  
PUC Docket No. E6472/M-05-1993

**Transmission Costs and Timing**

September 5, 2006

## Table of Contents

I.	Introduction and Qualifications	1
II.	Purpose of Testimony	2
III.	Cost of Network Upgrades	3
IV.	Timing of Network Upgrades	8
V.	Conclusion	10

1 I. INTRODUCTION AND QUALIFICATIONS

2  
3 Q. PLEASE STATE YOUR NAME.

4 A. My name is Richard Gonzalez.

5  
6 Q. BY WHOM ARE YOU EMPLOYED AND WHAT IS YOUR POSITION?

7 A. I am employed by Excel Engineering, Inc. as Principal Engineer,  
8 Transmission Planning.

9  
10 Q. FOR WHOM ARE YOU TESTIFYING?

11 A. I am providing testimony on behalf of Northern States Power Company  
12 doing business as Xcel Energy ("Xcel Energy").

13  
14 Q. PLEASE SUMMARIZE YOUR QUALIFICATIONS AND EXPERIENCE.

15 A. I graduated from the University of Minnesota in 1982 with a Bachelor of  
16 Electrical Engineering degree. From 1983 to 1984 I was a Planning Engineer  
17 in the Division of System Engineering of the U. S. Department of Energy's  
18 Western Area Power Administration, Golden, Colorado. From 1984 to 2003  
19 I was an engineer in the Delivery System Planning and Engineering  
20 Department at Northern States Power Company and subsequently Xcel  
21 Energy and was the principal planning engineer on the studies that resulted in  
22 the Public Utilities Commission March 2003 Order granting a Certificate of  
23 Need for Xcel Energy to construct four new high voltage transmission lines  
24 in western Minnesota. I am presently a Principal Engineer and Partner at  
25 Excel Engineering, Inc., an independent electrical engineering consulting firm.  
26 In these positions I have been responsible for electric transmission system  
27 technical and economic analyses. This includes load forecasting, power

1 system modeling, development, and economic evaluation of options, and  
2 formulation of designs and specifications for new and upgraded transmission  
3 facilities. My resume is provided as Exhibit\_\_(RG-1), Schedule 1.  
4 Exhibit\_\_(RG-1), Schedule 2 provides further details regarding my  
5 experience in electric transmission studies.

## 6 7 II. PURPOSE OF TESTIMONY 8

9 Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?

10 A. I have been retained by Xcel Energy to evaluate the costs and timing of  
11 obtaining transmission access for delivery to Xcel Energy of the output from  
12 the 603-MW Mesaba Unit 1 project proposed by MEP-I LLC ("Mesaba 1  
13 LLC"). To do so, I reviewed Mesaba 1 LLC's entire public filing, paying  
14 particular attention to the parts regarding transmission access. Specifically, I  
15 reviewed Section IV, Subsection I (Transmission Infrastructure  
16 Requirements) of the Petition, as well as the Testimony of Stephen D.  
17 Sherner. I also reviewed the MISO studies responding to Mesaba 1 LLC's  
18 interconnection request. I considered all of this information to provide a  
19 basis for describing likely scenarios and cost estimates for necessary  
20 transmission infrastructure improvements.

21  
22 Q. WHAT ARE YOUR CONCLUSIONS REGARDING THE COST AND TIMING OF  
23 NEEDED TRANSMISSION IMPROVEMENTS TO DELIVER THE OUTPUT OF MESABA  
24 UNIT 1 TO XCEL ENERGY'S SYSTEM?

25 A. Based on my review and analysis, I conclude that:

- 26 • The costs of transmission system additions and upgrades necessary for  
27 "delivery" will be approximately \$180 million, in addition to the

1 approximately \$70-73 million costs reported by Mesaba 1 LLC to  
2 interconnect the plant. Because I performed my study at a high level  
3 and only MISO can finally determine the upgrades that will ultimately  
4 be required, actual costs may exceed these numbers, perhaps by a  
5 significant amount. It is highly unlikely that costs would be less than I  
6 have identified.

- 7 • The transmission system improvements necessary for the delivery of  
8 Mesaba Unit 1's output to Xcel Energy's system will require a  
9 significant amount of time to properly plan, design, and construct. I  
10 estimate that the needed improvements would not be in service before  
11 2014.

12  
13 I describe the basis for these conclusions in the remainder of my testimony.

### 14 15 III. COST OF NETWORK UPGRADES

16  
17 Q. MR. SCHERNER INDICATES THAT MESABA 1 LLC MAY SEEK LOCAL CAPACITY  
18 RESOURCE DESIGNATION FOR MESABA UNIT 1. IS THIS AN APPROPRIATE  
19 APPROACH?

20 A. I agree with Mr. Scherner that such designation is a more practical approach  
21 than attempting to secure Network Resource designation, given the significant  
22 number and scope of the system limitations identified in MISO's deliverability  
23 study. However, Mesaba 1 LLC indicates it does not know what network  
24 upgrades are necessary for Mesaba Unit 1 to secure this designation.

1 Q. TO ACHIEVE THE LOCAL CAPACITY RESOURCE DESIGNATION THAT MESABA 1  
2 LLC DESCRIBES IN ITS PETITION, ARE THE NETWORK UPGRADES FOR THIS  
3 DESIGNATION LIKELY TO BE SIGNIFICANT?

4 A. Yes. Increased firm deliveries of power from Minnesota Power's system,  
5 where the interconnection would occur, to Xcel Energy's system would  
6 require significant transmission system upgrades to increase the firm rating of  
7 the Minnesota Power-Xcel Energy interface.

8  
9 Q. PLEASE DESCRIBE THE UPGRADES THAT YOU BELIEVE WOULD BE NEEDED TO  
10 PROVIDE FIRM TRANSMISSION SERVICE FOR THE MESABA UNIT 1 OUTPUT.

11 A. Delivery of Mesaba Unit 1's output would require development of a new 345-  
12 kV circuit from northern Minnesota to the Twin Cities, and improvements at  
13 the existing Chisago Co 500/345 kV substation. Exhibit\_\_\_(RG-1), Schedule  
14 3 lists the system additions and upgrades required for firm delivery of the  
15 Mesaba Unit 1's output to Xcel Energy's system.

16  
17 Q. HOW DID YOU DETERMINE THAT THESE UPGRADES WOULD BE REQUIRED?

18 A. Based on my experience and knowledge of the regional transmission system, I  
19 developed a study to analyze this part of the system. Powerflow modeling  
20 was performed to simulate a power delivery from the Mesaba West  
21 Range/Blackberry site to the Xcel Energy system. This analysis indicates  
22 significant issues arising on the existing transmission network, particularly the  
23 Forbes-Chisago Co 500 kV line, which is a defined "constrained interface" or  
24 "flowgate" whose loading is monitored and managed by MISO. This  
25 interface is not currently robust enough to accommodate the additional  
26 generation output from Mesaba Unit 1 that would flow over this line. The

1 upgrades described in Exhibit \_\_\_(RG-1), Schedule 3 are a logical way to  
2 alleviate these problems.

3  
4 Q. WHAT WOULD SUCH TRANSMISSION SYSTEM INVESTMENTS COST?

5 A. I estimate the costs of transmission delivery upgrades for Mesaba Unit 1  
6 would be approximately \$180 million, or approximately \$300/kW.

7  
8 Q. HOW DID YOU DERIVE THIS COST ESTIMATE?

9 A. My study found seven transmission line upgrades or additions and 15  
10 substation improvements that need to be implemented to overcome the  
11 identified constraints. The transmission elements primarily involve  
12 constructing 345-kV lines at various locations in Minnesota. The longest  
13 segment would be the 62-mile rebuild of the Riverton-Benton Co line,  
14 upgrading the line from 230 kV to include a second circuit operating at 345  
15 kV. My analysis indicates that another 41 miles of new 345-kV line on new  
16 right of way would be required as part of this undertaking. All of the project  
17 elements and my estimates of the cost for them are itemized in my Schedule 3.

18  
19 Q. IS YOUR ESTIMATE CONSISTENT WITH RECENT EXPERIENCE?

20 A. Yes. The \$180 million estimate is consistent with other relatively recent  
21 projects. This estimate is consistent with the actual costs of the Manitoba -  
22 Minnesota Transmission Upgrade ("MMTU") project and the Harvey-  
23 Glenboro project. In the MMTU project, which was designed to support a  
24 400-MW capacity increase, the overall costs were \$260/kW. For the Harvey-  
25 Glenboro transmission line projects, which increased transfer capability by  
26 200 MW, the cost was \$280/kW.

1 I believe my \$180 million estimate is conservative, given the more recent costs  
2 associated with the 345 kV Arrowhead – Weston transmission line and Xcel  
3 Energy’s experience on the Buffalo Ridge. While the Arrowhead – Weston  
4 line is not yet completed, the available public information indicates that the  
5 cost of this project will be over \$500/kW. Similarly, Xcel Energy’s “825  
6 MW” series of Buffalo Ridge transmission projects is expected to be  
7 constructed for approximately \$400/kW. Given these more recent projects,  
8 my estimate of \$300/kW appears conservative.  
9

10 Q. DOES YOUR COST ESTIMATE INCLUDE ALL THE COSTS ASSOCIATED WITH THE  
11 DELIVERY OF MESABA UNIT 1’S OUTPUT TO XCEL ENERGY’S SYSTEM?

12 A. No. My estimate does not include the costs associated with interconnecting  
13 Mesaba Unit 1 to the transmission grid. Mesaba 1 LLC reports the estimated  
14 costs to be \$70 million for the Blackberry (“West”) site and \$73 million for  
15 the Forbes (“East”) site. To get a full picture of the costs of delivering output  
16 to Xcel Energy, both transmission “delivery” and “interconnection” costs  
17 must be considered.  
18

19 Q. DO YOUR IDENTIFIED TRANSMISSION PATH AND COSTS APPLY TO BOTH OF  
20 MESABA 1 LLC’S POSSIBLE SITES, OR WOULD SEPARATE ESTIMATES NEED TO  
21 BE PREPARED?

22 A. My analysis focused on developing a transmission plan for the West site.  
23 However, the conclusions are applicable also to the East site because the  
24 fundamental transmission needs are similar: regardless of where the new  
25 generation is located on the Minnesota Power system, there will be a need to  
26 provide additional transmission capacity from Minnesota Power’s system to  
27 the Twin Cities (in addition to the site-specific interconnection requirements).



1 Although there may be subtle differences in which substations may be  
2 involved or which lines or transformers may need to be upgraded or added,  
3 the total costs will not differ significantly between the two identified Mesaba  
4 generation sites for any given level of generation addition.

5  
6 Q. DO YOU HAVE ANY QUALIFICATIONS REGARDING YOUR STUDY OR COST  
7 ESTIMATES?

8 A. Yes. First, given the time available, it was not possible to conduct an in-depth  
9 transmission system study as would ordinarily be undertaken for a generation  
10 addition of this size, as this would take several months and would require the  
11 participation of all affected parties. However, drawing on my experience in  
12 transmission planning, I was able to develop an adequate and reasonable  
13 transmission outlet plan for Mesaba Unit 1.

14  
15 Second, only MISO, applying its tariffed study process, can finally determine  
16 the actual network upgrades and provide associated cost estimates for  
17 transmission that would be required to provide firm transmission service for  
18 Mesaba Unit 1. While I have provided these types of transmission cost  
19 estimates in the past for utilities, including Xcel Energy, Great River Energy,  
20 and others to assist their resource selection processes, the official study of  
21 required upgrades and estimated costs can only be provided by MISO.

22  
23 Q. WHAT IS YOUR RESPONSE TO MESABA 1 LLC'S ASSERTION THAT ANY POWER  
24 PLANT WOULD REQUIRE SIGNIFICANT UPGRADES AND COMPARABLE COSTS?

25 A. The required upgrades and costs of providing firm transmission service for a  
26 new generator depend on the generator's location. Without studies and  
27 specific projects to compare, I cannot agree with this conclusion.

1  
2 For example, in conjunction with its 2004 Resource Plan, Xcel Energy  
3 retained me to conduct transmission studies to assess the costs of  
4 deliverability from a number of possible sites for new baseload resources,  
5 including a hypothetical 750-MW coal unit ("Sherco 4") from Becker,  
6 Minnesota to Xcel Energy's load. I revisited that analysis in preparation for  
7 my testimony here. For illustration, I updated the analysis and have provided  
8 my summary spreadsheet as Exhibit\_\_\_(RG-1), Schedule 4. My total estimate  
9 for that work is approximately \$91 million, or \$121/kW.

#### 10 11 IV. TIMING OF NETWORK UPGRADES

12  
13 Q. HAVE YOU CONSIDERED THE TIMING OF THE NECESSARY NETWORK  
14 UPGRADES?

15 A. Yes. I expect that a reasonable time frame to complete all of the identified  
16 upgrades would be at least 2014. Given the number of activities involved  
17 with implementing the identified upgrades, I believe this estimate is  
18 conservative.

19  
20 Q. HOW DID YOU REACH THIS ESTIMATED TIME FRAME?

21 A. I reviewed 12 transmission construction projects to consider the time required  
22 to plan, permit, and construct, as well as the complexity of the project. I  
23 considered this information to estimate a reasonable time frame for the  
24 upgrades likely to be required for Mesaba Unit 1. I provide the relevant  
25 information from these projects in Table 1 below.

1

Table 1

Project	Planning	Permitting	Construction	Yrs	Notes
MMTU (500 kV upgrade)	1989-1993	1990-94	1991-1995	6	No new lines
Split Rock-Sioux Falls 230 kV	1989	1989-1998	1999	10	1 mile 230 kV
Chisago-Apple River 230 kV	1994-1996	1996-?	?	12+	inactive
Stone Lake-Bay Front 161 kV	1994-1996	1996-1998	2000-2001	7	55 mi 161 kV
Arrowhead-Weston 345 kV	1997-1998	1999-2005	2004-2008	11	220 mi 345 kV
Harvey-Glenboro 230 kV	1997-1998	1998-2000	2001-2002	5	160 mi 230 kV
Buffalo Ridge 425→825 MW	1999-2001	2002-2003	2003-2008	9	94 mi 345 kV
Buffalo Ridge (BRIGO)	2004-2005	2006-2007	2009-2010	6	~55 mi 115 kV
SW MN→Twin Cities EHV	2005	2006-2008	2009-2011	6	327 mi 345 kV
St Cloud-Fargo (CapX 2020)	2004-2005	2006-2008	2010-2012	8	250 mi 345 kV
Red Rock-Rogers Lk 115 kV	1997	1997-2001	2002-2005	8	6 mi double ckt
Willmar-Paynesville 115→230 kV	1999	2001	2002-2003	4	26 mi rebuild

2

3

4 Q. WHAT DO YOU CONCLUDE FROM THIS INFORMATION?

5 A. It is evident that projects involving new 230 or 345 kV lines should generally  
6 be expected to take at least six years from beginning of planning to  
7 completion of construction; eight years is a more typical duration.

8

9 Q. GIVEN THIS INFORMATION, WHAT DO YOU BELIEVE IS A REASONABLE TIME  
10 LINE FOR DEVELOPING OUTLET TRANSMISSION FOR MESABA UNIT 1?

11 A. If transmission planning studies were initiated immediately, they could  
12 possibly be completed sometime in 2008. Permitting and routing could occur  
13 in 2009-2010, with design, land acquisition, and construction beginning in  
14 2011 and completing in 2014. This represents an eight-year implementation  
15 schedule

16

17 This scenario assumes relatively favorable conditions regarding permitting,  
18 and assumes no delays in arranging and implementing financing and cost-

1 sharing arrangements among the requestor, MISO, and the affected  
2 transmission owners. This schedule also assumes no unusual difficulty in  
3 securing line and substation construction contractors, materials, and  
4 construction outages. Considering the number and magnitude of planned  
5 major transmission projects in the region and throughout North America, it is  
6 uncertain that such assumptions would be satisfied. Completion could thus  
7 take longer than this estimate, since there is little opportunity for significantly  
8 accelerating any of the required activities.

9  
10 Q. DO YOU HAVE AN OPINION AS TO HOW LONG IT WOULD TAKE TO BUILD THE  
11 TRANSMISSION ASSOCIATED WITH THE SHERCO 4 COMPARABLE THAT YOU  
12 IDENTIFIED IN YOUR TESTIMONY?

13 A. It would take a similar amount of time as my estimates for the relevant  
14 utilities to permit and construct the transmission necessary for delivery from  
15 Mesaba Unit 1.

## 16 17 V. CONCLUSION

18  
19 Q. PLEASE SUMMARIZE YOUR CONCLUSIONS.

20 A. I estimate that the upgrades required to deliver the output of Mesaba Unit 1  
21 to Xcel Energy's system would require the following:

- 22 • A new 345-kV transmission line between the Minnesota Power and  
23 Xcel Energy systems and substation expansions.
- 24 • Approximately \$180 million or more to construct, over and above the  
25 \$70-73 million in interconnection costs.
- 26 • Approximately eight years (until at least 2014) to complete.

1 Q. DOES THIS CONCLUDE YOUR TESTIMONY?

2 A. Yes, it does..

**RICHARD GONZALEZ, PE**  
**Excel Engineering, Inc.**  
**Minneapolis, Minnesota**

---

## **Experience**

- 2003-Present    Principal Engineer  
                    Transmission Planning  
                    Excel Engineering, Inc , Minneapolis, MN
- 1984-2003      Engineer I/Engineer II/Planning Engineer/Superintendent/Principal Engineer  
                    Transmission Planning/Delivery System Planning & Engineering  
                    Northern States Power Company/Xcel Energy, Minneapolis, MN
- 1983-1984      Engineer  
                    Division of System Engineering; System Studies Branch  
                    Western Area Power Administration, Golden, CO
- 1980-1982      Engineering Intern Student  
                    Power Supply Planning  
                    Northern States Power Company, Minneapolis, MN

## **Education**

Bachelor of Electrical Engineering, University of Minnesota Institute of Technology, 1982

Additional technical/business coursework at University of Minnesota and University of Colorado:

- Statistics
- Business Law
- Engineering Economics/Accounting
- Semiconductor power electronic circuits
- Quality control and reliability
- Fluid mechanics
- Heat transfer
- Surveying
- Measurement techniques and data acquisition

## **Licenses**

Licensed Professional Engineer, State of Minnesota (18938)  
Class A Master Electrician, State of Minnesota (AM01282)  
Electrical Contractor, State of Minnesota (CA02012)  
Commercial Radiotelephone Operator (with radar endorsement),  
Federal Communications Commission (PG-16-19197)  
Amateur Radio Operator (Extra Class), Federal Communications Commission

## Supervision of Technical Studies

Manitoba-Minnesota Transmission Upgrade (MMTU) Project Technical Studies (1989-1993, multiple utilities). Included specification of 500 kV series compensation and world's largest Static VAR Compensator (SVC).

EPRI Research Project RP3012-18 (Evaluation of Thyristor-Controlled Series Compensation).

Definition of project scope, review of contractor (Ontario Hydro) study results.

Measurement of Sherburne County Generating units' subsynchronous frequency response (February, 1992): selection, scheduling, supervision, review of contractor (Power Math Associates, San Diego, CA) measurements and technical analysis.

Subsynchronous Resonance Analysis of the MMTU Project: selection, supervision, review of contractor (General Electric Company, Schenectady, NY) technical analysis.

Exciter Instability Study of Angus C Anson generating Plant: coordination of on-line testing; selection, supervision, review of contractor (EUMAC Inc, Phoenix, AZ) technical analysis.

Statistical Analysis of Wisconsin Northern Area Winter peak load sensitivity to temperature: selection, supervision of statistical consultant (Prof. S Weisberg, University of Minnesota).

Central North Dakota-Manitoba Interconnection Study (1997-98): Organized & led technical study group; performed technical and economic analysis of transmission options. Study resulted in construction of new 160-mile 230 kV Manitoba-U.S. interconnection.

Southwest Minnesota/Southeast South Dakota Electric Transmission Study (1999-2001): Organized & led technical study group; performed technical and economic analysis of transmission options. Study culminated in successful permitting of \$160 million transmission improvement plan, including 90-mile interstate 345 kV line.

MISO transmission service studies (multiple).

Generation outlet capacity evaluations (multiple): Performed single- and multi-site transmission outlet evaluations for Independent Power Producers, investor-owned utilities, and G & I Cooperatives for plant sizes of 20 – 1500 MW for sites in Minnesota, Dakotas, Iowa, Wisconsin, Illinois, Kansas.

Wilmarth-Lakefield 345 kV Series Compensation Study (August, 2004): Determined optimal amount and location of series compensation to alleviate constrained interface ("flowgate") concerns. Determined recommended ratings for capacitor bank and protective equipment.

Buffalo Ridge Incremental Generation Outlet ("BRIGO") Electric Transmission Study (June, 2005): Organized & led technical study group; performed technical and economic analysis of "incremental" transmission options involving only 115 kV and lower-voltage improvements.

Southwest Minnesota→Twin Cities EHV Development Electric Transmission Study (November, 2005): Organized & led technical study group; formulated transmission options, performed technical and economic analyses. Recommended Plan includes 327 circuit-miles of new 345 kV transmission and 1300 MVAR of reactive compensation.

MAPP Reactive Adequacy Study (2005). Identify regional load centers within MAPP territory for detailed analysis; direct technical staff's voltage stability analyses (Q-V, P-V, power factor sensitivity); interpret results; provide recommendations.

Red River Valley/Northwest Minnesota Load-Serving Transmission Study (2006): Identify upcoming load-serving deficiencies; formulate & evaluate short- and long-range transmission options to address overloads and voltage stability issues. Recommended Plan includes new 230 and 345 kV lines and reactive compensation.

## **Publications**

- "Manitoba-Minnesota Transmission Upgrade Project", *Transmission & Distribution*, May 1992.
- "Evaluation of FACTS Technologies' Application to the Manitoba-Minnesota Transmission Interface", (IEEE Special Publication: *Current Activities in FACTS Technologies*), 1992.
- "Recommended Practice for Modelling of Static VAR Compensators", (Contributor) IEEE publication.
- "500 kV Series Compensation Project", (Co-Author) EEI Electrical Systems and Equipment Committee, October, 1992.
- "Application of Fast-Switched Shunt Capacitors to Improve Power System Dynamic and Steady-State Performance", (Co-Author), American Power Conference (Chicago, IL 1995).
- "Transmission Outlet Cost Minimization Strategies for Wind-Electric Generating Facilities", American Wind Energy Association (Austin, TX 1997)
- "Probabilistic Planning of Shunt Reactive Installations: Application of Binomial Probability Distribution Function to Prediction of Aggregate Shunt Reactive Compensation Availability and Determination of Spares Requirement", American Power Conference (Chicago, IL 1997)
- "Solid Dielectric 115 kV Direct-Buried Cable Applied Within Substation Enables Conversion to Ring Bus Configuration to Meet Enhanced Reliability Needs", American Power Conference (Chicago, IL 1997)
- "Statistical and Engineering Analysis of Transmission System Topology's Influence on Large Autotransformer Failure Rates", (Lead Author), American Power Conference (Chicago, IL 1997)
- "Developing a Long-Range Bulk Transmission System Plan for Northern States Power" (Co-Author), American Power Conference (Chicago, IL 1997)
- "Why FACTS Devices May Not Achieve Widespread Use", Minnesota Power Systems Conference, October, 1997.
- "Recent NSP Experience with Application of Mechanically-Switched Shunt Capacitors to Improve Power System Dynamic and Steady-State Performance", IEEE "FACTS Applications" IEEE Special Publication, 1996.
- "Stepped Capacitor Applications: Design of Multi-Stage 115 kV Shunt Capacitor Bank", Minnesota Power Systems Conference, October, 1996.
- "Approach to Modeling Utility Network for Harmonic Impedance Analysis", (Co-author), Minnesota Power Systems Conference, October, 1996.
- "Voltage Stability Issues and Analysis Methods as Applied to Reactive Compensation Requirements of Red River Valley Electric Transmission System", Minnesota Power Systems Conference, October, 1995.
- "Application of Fast-Switched Shunt Capacitors to Enhance Power System Dynamic and Steady-State Performance", (Co-Author), North American Power Symposium (Massachusetts Institute of Technology, November, 1996).
- "An Exploration of Utility Concerns Due to Wind Electric Generation" (Co-Author) University of Minnesota, June, 1996.
- "Semiconductor-Based Power Control is Exciting, but Evolutionary Enhancements to Conventional Devices Render them More Practical", The Future of Power Delivery in the 21st Century, (EPRI Conference; La Jolla, CA, November, 1997).



“Recent Storm-Induced Transmission Facility Outages in Minnesota Imposing Operating Challenges on Bulk System Reliability and Performance” (Co-Author) American Power Conference (Chicago, IL 1998)

“Transmission System Shunt Capacitor Banks: Recent Advances in Control Concepts and Switching Equipment Yield Improved Application Flexibility and Performance”, Minnesota Power Systems Conference, October, 1998.

“Southwest Minnesota Wind Generation Transmission Outlet: SVC Installation at Lake Yankton Substation”, Minnesota Power Systems Conference, November, 2004.

### **Industry Groups/Seminar Participation**

Panelist, IEEE Transmission & Distribution Conference, Dallas, TX (2003)

Presenter, IEEE Winter Power Meeting, New York (1992, 1995)

Presenter, MAPP Engineering Conference (1992)

Presenter, Minnesota Power Systems Conference (1991, 95, 96, 97, 98, 2000, 2003, 2004)

Presenter, Tutorial Session, Minnesota Power Systems Conference (2006)

Presenter, Iowa State University Power System Operators’ Short Course (1999, 2003)

Presenter, EEI System Planning Committee (1992)

Presenter, EPRI Flexible AC Transmission Systems (FACTS) Workshop (1990)

Presenter, North Central Electric Association, 1997

Participant, EPRI/NERC Voltage Stability Forum (1992)

Participant, “Probabilistic Methods Applied to Power Systems” Symposium

Participant, EPRI “Power System Planning & Operations Voltage/VAR Projects” Symposium

Participant, EPRI “Non-Linear Dynamics” Seminar (1993)

Coordinator, Power System Voltage Stability Seminar (1994)

Member, Mid-Continent Area Power Pool Design Review Subcommittee (1997-2001)

Member, Electrical Section, National Fire Protection Association (National Electrical Code Sponsor)

Member, Institute of Electrical and Electronics Engineers (IEEE), Power Engineering Society

Past Member, Mid-Continent Area Power Pool, Transmission Studies Task Force

Past Member, EPRI Industry Advisory Panel RP1208 (Extended Transient/Mid-Term Stability Program)

Past Chair, Mid-Continent Area Power Pool Red River Valley Sub-regional Planning Group

### **Other Presentations**

MAPP Design Review Subcommittee (Multiple)

MAPP Sub-Regional Planning Groups (Multiple)

EPRI Industry Advisors’ Meeting (project RP3022: Evaluation of Thyristor-Controlled Series Compensation) (multiple)

IEEE Power Engineering Society (Twin Cities)

Minnesota Legislative Electric Energy Task Force (2004)

NSP Engineers’ Association (multiple)

Manitoba-U.S. Tie Line Coordinating Committee (1994)

American Power Dispatchers Association (1994)

National Wind Coordinating Committee: Midwest Wind Conference (2005)

Missouri Basin Systems Group Planning Committee (1994)

EPRI “FACTS” System Studies Project Review (1993)

Excel Engineering Industrial/Utility Seminar (2006)

**Testimony in Legal & Regulatory Proceedings**

Certificate of Need/Route Certification for transmission lines and substations (States of MN & WI)

Local transmission permitting proceedings (various municipalities)

Certificate of Need for generation facilities (State of MN)

Corporate Merger (FERC)

Presidential Permit (DOE) for U.S.-Canada new and upgraded interconnections

Right-of-way condemnations

Electric shock/burn litigation

**RICHARD GONZALEZ, PE**  
**Excel Engineering, Inc.**  
**Minneapolis, Minnesota**

---

**Summary of Experience in Electric Transmission Studies  
for Generation Outlet or Regional Transfer Capability Enhancement**

*Transfer Capability*

- 1) Manitoba-Minnesota Transmission Upgrade (MMTU) Project (1989-93):  
*Lead engineer* in major transmission study efforts relating to increasing north-south transfer capability between Manitoba and the U.S.
  - *Transmission planning studies*, formulating and evaluating options, technical and economic performance, identifying the performance characteristics and ratings of upgrades required; and
  - *MAPP Design Review Subcommittee (MAPP DRS) studies*, to demonstrate the proposed additions adequate to satisfy the MAPP System Design Standards under proposed power transfer conditions.
  - The MMTU Project achieved 400 MW increase in Manitoba-U.S. (southward) and 500 MW (northward) power transfer capability primarily by extensive installations of reactive power supply facilities.
  - Completed in May, 1995 at a cost of \$100,300,000. Roughly 75% allocated to 400 MW southward transfer capability. Therefore, the cost of the incremental southward transfer capability was approximately \$188/kW in 1995 dollars. Adjusting to today's dollars (at 3.0%/yr), this is approximately \$260/kW.
- 2) Central North Dakota-Manitoba ("Harvey-Glenboro 230 kV") 1997-00
  - The Harvey-Glenboro project increased Manitoba-U.S. (southward) power transfer capability by 200 MW (from 1975) to 2175 MW, and also established a 700 MW northward transfer capability. This was achieved primarily by the addition of a 160-mile 230 kV line from central North Dakota (Harvey) to southwestern Manitoba (Glenboro).
  - Less noticeable, but crucial to achieving satisfactory performance, was the addition of large shunt capacitor banks in North Dakota (Balta Switching Station) and the Twin Cities (Chisago County Substation).
  - The Harvey-Glenboro project was completed in October, 2002 at a cost of approximately \$50 million. The cost of the incremental transfer capability can be reckoned to be \$250/kW. Adjusting to today's dollars (at 3.0%/yr), this is approximately \$280/kW.
- 3) Wisconsin Interface Reliability Enhancement Study (WIRES) 1997-98
  - The WIRES Study formulated and evaluated 47 transmission options for increasing bulk power import capability into eastern Wisconsin, as required to satisfy provisions of Wisconsin Act 204.
  - Transmission options were evaluated with respect to steady-state, dynamic stability, and voltage stability performance. As the lead NSP transmission planning engineer in

this effort, I performed some of the transfer capability evaluations, interpreted results of the technical analyses, and participated in development of the study report.

- Utility managements subsequently elected to implement the 220-mile Arrowhead-Weston 345 kV line.
- Arrowhead-Weston under construction. Public information indicates that the cost of this project will be over \$500/kW.

#### *Generator Interconnection and Outlet*

- 4) Sherco/Monticello Generation Increase Study
- 5) Chemolite Generation (265 MW)
- 6) Buffalo Ridge wind outlet (425 MW)
- 7) Lakefield Generating Station (550 MW). These studies were performed to demonstrate the proposed generation interconnection and outlet facilities are adequate to satisfy the MAPP System Design Standards for these baseload, intermediate, wind, and peaking facilities. This demonstration is necessary to achieve generating capacity accreditation in the MAPP generation reserve sharing pool. I was the lead engineer on all four studies, and secured MAPP Design Review Subcommittee acceptance of the studies. Study (5) showed no need for off-site improvements due to the generation being located within the Minneapolis/St. Paul load center, while all others confirmed need for off-site transmission system upgrades to accommodate firm delivery of the new generation's output.
- 8) Buffalo Ridge 825 MW (Split Rk-Lakefield Jct 345 kV and 3 115 & 161 kV lines), Xcel Energy's "825 MW" series of Buffalo Ridge transmission projects is expected to be constructed for approximately \$400/kW. This project includes 94 miles of new 345 kV line, and 3 lower-voltage lines.
- 9) Buffalo Ridge Incremental Generation Outlet (BRIGO) (825→1200 MW). Ongoing project just commencing regulatory permitting; includes two new 115 kV lines.
- 10) Buffalo Ridge EHV (1200→1800 MW). Like (8) and (9), this study was performed for the purpose of identifying the preferred transmission option for achieving increased levels of southwest Minnesota/southeast South Dakota Buffalo Ridge generation outlet capacity. Activities for all three studies included organization and coordination of inter-utility study group, performance of technical and economic analyses, and report compilation. This project, which includes over 300 circuit miles of new 345 kV, is in initial stages of permitting.
- 11) Xcel Energy (baseload, multi-site) (750 & 1500 MW) (2005).
- 12) Great River Energy (baseload, multi-site) (2005). These two studies were screening-level studies to support baseload generation siting efforts. Transmission outlet improvement plans were developed for each site to accommodate one or more generating units, subject to MAPP and MISO reliability and constrained interface loading criteria. In the Xcel Energy study it was concluded that sites remote from the Twin Cities would typically require one 345 kV line addition from the site to the Twin Cities for each 750 MW generator addition.

Transmission Facilities for Delivery of Mesaba Unit 1 Output to Xcel Energy Twin Cities Load Center  
(Blackberry site)

603 MW Excelsior--> Twin Cities

Transmission Lines	miles	cost/mi	Installed cost (\$1,000's)
Riverton-Benton Co 230 kV: rebuild to double ckt 345/230 kV	62	800	49,600
Benton Co-Monticello 230 kV: rebuild to double ckt 345/230 kV	22	800	17,600
Monticello-(Dickinson)-W Waconia: new 345 kV single ckt	41	525	21,525
Monticello-(Dickinson)-W Waconia: acquire right-of-way	41	100	4,100
W Waconia-Blue Lk: rebuild to double ckt 345/230 kV	24	800	19,200
Chisago Co-Kohlman Lk: reconductor low-capacity section	6.1	180	1,098
Chisago Co-King 345 kV: reconductor low-capacity section	6.7	180	1,206
Total Lines			114,329
Substations			
Riverton Sub: add 345/230 kV transformation (2 x 400 MVA)			8,000
Riverton Sub: add 4 230 & 3 345 kV breakers, establish 3-position 345 kV ring bus			6,000
Riverton Sub: add +150 MVAR Static VAR Compensator @ 230 kV			13,500
Benton Co Sub: add 5 345 kV breakers to develop 5-position ring bus			5,000
Benton Co Sub: install series compensation for Riverton 345 kV line			8,500
Benton Co Sub: add 50 MVAR shunt reactor			1,000
Monticello Sub: add 4 345 kV breakers (2 line terminations)			4,000
Blue Lk Sub: add 3 345 kV breakers (8M29, 30, 31; new row for new Monti line & Pl line)			4,000
Blue Lk Sub: add 50 MVAR shunt reactor			1,000
Chisago Co Sub: upgrade 500 kV series capacitors to 2500 amps			3,000
Chisago Co Sub: add 3 x 80 MVAR 115 kV caps			3,000
Riverton Sub: add 3 x 60 MVAR 230 kV shunt capacitors			3,000
Benton Co Sub: add 1 x 80 MVAR 115 kV shunt capacitors			1,000
Blue Lk Sub: add 1 x 80 MVAR 115 kV shunt capacitors			1,000
A S King Sub: add 2 345 kV breakers (establish 3rd row)			4,000
Total Substations			66,000
Grand Total Lines & Substations			180,329
			\$/kW 299

Notes:

1. Line costs: single ckt 345  
double ckt 345  
removal of existing
- \$1,000/mi  
525  
800  
50
2. Costs do not include recovery of undepreciated value of existing facilities to be removed.
3. Assumes Boswell-Riverton 230 kV line already provided as part of interconnection facilities.

Transmission Facilities for Delivery of Sherco Unit 4 Output to Xcel Energy Twin Cities Load Center

	unit cost	units	total element cost	total project cost	total project cost	total plan cost	\$/KW
<b>Sherco - Chisago Co 345 kV</b>					<b>\$28,625,000</b>	<b>\$90,825,000</b>	<b>\$121</b>
345 kV line							
Sherco - Chisago Co	\$525 000	45	\$23 625 000				
345 kV breakers							
Sherco	\$1 000 000	2	\$2 000 000				
Chisago Co	\$1 000 000	1	\$1 000 000				
				\$26 625 000			
<b>Red Rock-Chisago 345kV dbl ckt</b>					<b>\$42,250,000</b>		
345 kV dbl ckt							
Red Rock-Chisago	\$850 000	45	\$38 250 000				
345 kV breakers							
Red Rock	\$1 000 000	1	\$1 000 000				
Chisago	\$1 000 000	3	\$3 000 000				
				\$42 250 000			
<b>Chisago-Rush City 230kV</b>					<b>\$3,000,000</b>		
230 kV line							
Chisago-Chisago tap	\$350 000	2	\$700 000				
move 345-230 kV tx							
to Chisago from Red Rock	\$300 000	1	\$300 000				
345 kV breakers							
Chisago	\$1 000 000	2	\$2 000 000				
				\$3 000 000			
<b>add an additional 48 Mvars at Eau Claire</b>					<b>\$100,000</b>		
48 Mvar Cap							
Eau Claire	\$100 000	1	\$100 000				
				\$100 000			
<b>Second Monticello 345-230 kV transformer</b>					<b>\$7,000,000</b>		
345-230 kV 336 Mva tx							
Monticello	\$3 000 000	1	\$3 000 000				
345 kV breakers							
Monticello	\$1 000 000	2	\$2 000 000				
230 kV breakers							
Monticello	\$1 000 000	2	\$2 000 000				
				\$7 000 000			
<b>Add two South Faribault 161-115 kV 336 MVA transformers</b>					<b>\$7,000,000</b>		
161-115 kV 336 Mva tx							
South Faribault	\$2 000 000	2	\$4 000 000				
161 kV breakers							
South Faribault	\$800 000	2	\$1 600 000				
115 kV breakers							
South Faribault	\$700 000	2	\$1 400 000				
				\$7 000 000			
<b>Reconductor Cannon Falls Transmission - Pine Island 69 kV to</b>					<b>\$2,850,000</b>		
69 kV 477 ACSR reconductor							
Cannon Falls Tr - Cannon Falls	\$100 000	13	\$130 000				
Cannon Falls - South CF	\$100 000	24	\$240 000				
South Cannon Falls - Hader	\$100 000	94	\$940 000				
Hader - Zumbrota	\$100 000	80	\$800 000				
Zumbrota - Lena TP	\$100 000	10	\$100 000				
Lena TP - Pine Island	\$100 000	64	\$640 000				
		285		\$2 850 000			
<b>Add shunt reactors for new 345 kV lines (2 x 50 MVAR)</b>	\$1 000 000	2	\$2 000 000	\$2 000 000	\$2 000 000	<b>\$90,825,000</b>	<b>\$121</b>