

2 BEFORE THE MINNESOTA PUBLIC UTILITIES COMMISSION

3 DIRECT TESTIMONY OF RONALD R. RICH

4  
5 I. INTRODUCTION

6 Q: Please state your name, occupation, and business address.

7 Ronald R. Rich, President  
8 Atmosphere Recovery, Inc.  
9 15800 32nd Avenue North, Suite 110  
10 Plymouth, MN 55447  
11

12 Q: What is your education and professional background?

13 I have a B.S.E. degree in Aerospace and Mechanical Engineering from Princeton  
14 University, and a M.S.E. degree in Environmental Engineering from Stanford University. I am  
15 President of Atmosphere Recovery, Inc., a company I founded 11 years ago that develops  
16 advanced process gas monitoring and control technologies that enhance industrial and energy  
17 production efficiency for and reduce emissions at Fortune 1000 companies. During my career, I  
18 have designed, developed, managed and assessed hundreds of advanced energy production (both  
19 conventional and alternative), energy conservation, and environmental mitigation and  
20 remediation projects and have attached my C.V. My most recent expertise is in the area of  
21 efficient gas reaction process measurement and control and, control, prevention and mitigation of  
22 air emissions. However, I also have expertise in industrial and utility water and wastewater  
23 treatment and solid and hazardous waste generation reduction and disposal.

24 Q: On whose behalf are you testifying?

25 A: I'm testifying on behalf of mncoalgasplant.com.

26 Q: What are your major issues of concern and recommendations regarding Excelsior's  
27 Mesaba Project?

1 A: Many issues concern me about this project, which I believe is not in the public interest, but in this  
2 docket addressing public interest and cost, my primary concerns are that there are cost associated  
3 with aspects of this project that must be carefully taken into account, specifically:

- 4 • Cost of Carbon Dioxide Emissions and Sequestration
- 5 • Air Emissions from Proposed Flares – Cost of Control and Mitigation
- 6 • Costs of Plant and Off-Site Safety
- 7 • Evaporative Cooling Tower and ZLD Air Emissions – Cost of Control and Mitigation
- 8 • Cooling Water Blowdown ZLD – Cost of Control and Mitigation
- 9 • Costs of Cumulative Impacts in Conjunction with the MSI project
- 10 • Overstated Economic Benefits and Costs not Addressed

11 **I. COST OF CARBON DIOXIDE EMISSIONS AND SEQUESTRATION**

12 **Q: What are your concerns about the carbon dioxide emissions and sequestration costs?**

13 A: In the Power Purchase Agreement Petition and accompanying report, Excelsior claims  
14 that “[t]he Mesaba Project will significantly reduce emissions of carbon dioxide.” Petition, para.  
15 23; Report, Section I, 4; Section II, pps. 3-11; etc.

16 Since CO2 capture requirements within the design lifetime of the facility are  
17 acknowledged in the application, the cost of design, installation and operation of CO2 capture and  
18 sequestration equipment should be required by the PUC. This must include costs incurred from  
19 point of generation and attachment to the Mesaba plant to the point of sequestration and  
20 maintenance of sequestration.

21 Further, where CO2 capture is required, capturing only 1/3 of the CO2 is not a reasonable  
22 mitigation plan, because that rate of capture will almost certainly not meet such capture  
23 requirements; most announced plans for future DOE backed IGCC plants assume a 90% CO2  
24 capture requirement. Therefore, the proposed CO2 capture cost amount is inadequate – planning  
25 and cost assumptions should be targeted at the 90% capture level.

1 Inclusion of the costs of CO2 capture and sequestration is necessary because CO2 capture  
2 and sequestration was used to justify the proposed facility's substantially higher cost of  
3 electricity, reasonable under a strict regulatory regime. Not only costs must be considered, but  
4 these features must be included in the design and construction plans because to forgo inclusion of  
5 the additional equipment and its cost, that is assumed to be required in the near term, imposes  
6 unknown, but even higher costs per KWh on Minnesota ratepayers than those imposed if this  
7 facility is constructed to capture and sequester CO2. The PUC is obligated to consider complete  
8 facility costs prior to approval, both in a typical Power Purchase Agreement and public interest  
9 context, and also under the provisions of the Mesaba legislation.

10 **Q: What is the impact of carbon capture on the plant's efficiency?**

11 A: Capturing and compressing CO2 would require a significant portion of the plant's energy  
12 output, reducing net electrical output and further increasing ratepayer costs. Most DOE estimates  
13 for carbon capture range from 10-40% of the net output of an IGCC plant and do not include the  
14 additional energy required for CO2 transportation and sequestration. If the net power reduction is  
15 known by Excelsior Energy and not disclosed (likely given the decision to design for only a 33%  
16 capture of their CO2 emissions), this section of the application as well as all net power output and  
17 per KWh emissions presented elsewhere in the report are purposefully misleading and need to be  
18 revised. If they are not known by Excelsior Energy the document language should state the  
19 anticipated performance penalties based on best available information. The PUC should require  
20 these disclosures and their related economics. Even under the assumption the discharged  
21 combustion gas is relatively clean of "criteria" and "hazardous" air pollutants, costly steps must  
22 be taken to capture the CO2 in an acceptable form for transportation to the sequestration site:

- 23 1. The combustion gas discharge stacks must be equipped with a damper or valve assembly and  
24 appropriate residual heat removal equipment, ducting and blowers (likely) to safely move the  
25 gas to the facility CO2 capture area. This equipment cost has not been disclosed.



2. The water produced as a result of combustion with air (or oxygen if modified), nitrogen, and excess oxygen remaining must be removed from the cooled combustion gas in a potentially capital intensive and high operating cost process yet to be disclosed.
3. The remaining gas phase CO<sub>2</sub> would need to be converted to a liquid or solid to allow economic transportation to a permanent sequestration site. Any such phase change, whether mechanical (such as compression) or thermal (such as refrigeration) would involve even more significant capital and operating not yet disclosed.
4. Because both proposed sites are located very far, in excess of 450 miles and more likely at least 1000 miles, from a suitable sequestration site, additional capital cost would be required for CO<sub>2</sub> storage and the onsite equipment to transfer the captured CO<sub>2</sub> to a high pressure, 700 psi or greater, pipeline or pressured or refrigerated railroad tank or bulk carrier cars. This cost has not been disclosed.
5. Assuming 90% capture, the volume and the weight of the CO<sub>2</sub> to be transported from the facility would exceed three times that of the coal or natural gas supplied to the facility. Either a long and very expensive additional 450+ mile pipeline would need to be constructed, or a large quantity of specialized CO<sub>2</sub> rail cars purchased. The costs of this additional infrastructure have not been disclosed. The costs of operating the transportation system would also be expensive given the shipping distances involved and the energy expenses required to move the CO<sub>2</sub>.
6. CO<sub>2</sub> asphyxiates animals and humans at concentrations in excess of 20,000 ppm. In addition, the density of CO<sub>2</sub> causes it to displace air upward when spilled. To prepare for both accidents and potential terrorism as a result of the hazard, additional undefined and undisclosed additional capital costs would be incurred.
7. Finally, it is likely that the costs of sequestration, including site preparation, unloading and injection equipment, perpetual monitoring, and storage failure and remediation, even if subsidized by the Federal government, will be the most significant cost of the entire CO<sub>2</sub>

capture and sequestration process. No such costs, not even an attempt at per ton disposal rates, are disclosed.

Taken together, these seven components represent a very significant additional cost of electricity from this facility. If the reduced net output of the plant as a result of CO<sub>2</sub> capture is considered, the per KWh price is even higher, but still undisclosed by Excelsior. Because of the potential for significant cost and shift in the economic feasibility of this project, Excelsior must disclose this information and the Commission must consider this range of costs.

**Q: What experience and studies address whether carbon capture and sequestration is feasible?**

**A:** Carbon capture and sequestration has not been accomplished in a power plant of this configuration, this distance, or in a commercial context – there is no prior experience to draw from. Carbon capture and sequestration a distance from source has been begun in a pilot study, but this scheme is not under consideration for the Mesaba project, so the Applications state. However, the Mesaba legislation requires Excelsior to make best efforts to secure Department of Energy funding for sequestration study, and this has been done. In its Siting application, Excelsior states:

Additionally, the Applicant has contracted with the University of North Dakota Energy and Environmental Research Center (“EERC”) to assess CO<sub>2</sub> management options for Mesaba One and Mesaba Two. This work is part of the Plains CO<sub>2</sub> Reduction Partnership...Phase II efforts EERC is conducting for DOE to validate the most promising sequestration technologies and infrastructure concepts identified during Phase I of the Program. Sink-source pairs, specific to the composition of CO<sub>2</sub> gas streams that can be removed from the syngas produced by Mesaba One and Mesaba Two, will be identified and ranked according to engineering, economic, and public-acceptance considerations.

Siting Application, Section 3.1.5.3.5 Potential Carbon Capture Benefit.

1    **Q:    In light of your knowledge of carbon capture and sequestration, do you have comments**  
2       **about this plan??**

3    **A:    Yes, I have comments on the Excelsior plan to research carbon sequestration:**

- 4       1. A review of this research indicates that the carbon sequestration method of most interest to  
5       Excelsior Energy is based on the amount of excess CO<sub>2</sub> that can be captured by natural CO<sub>2</sub>  
6       absorption in the land or water (with a wetland focus). Even if such sequestration had  
7       significant potential, IGCC CO<sub>2</sub> capture potential is not needed for this approach, since all  
8       atmospheric CO<sub>2</sub> (including that from conventional PC coal plants) would equally benefit.
- 9       2. Since the global CO<sub>2</sub> concentration is rising faster every year, it is clear that natural “sinks”  
10      for CO<sub>2</sub> have been unable to absorb the massive worldwide volumes of CO<sub>2</sub> emitted.  
11      Permanent underground or under ocean storage of CO<sub>2</sub> in liquid or solid form is the only  
12      currently known method that has any prospect of maintaining atmospheric CO<sub>2</sub> levels at  
13      acceptable concentrations.
- 14      3. The volume of CO<sub>2</sub> captured by the plant (even at only 33% much less 90%) would far  
15      exceed the volume of coal shipped to the plant.
- 16      4. The proposed West Range location lies approximately 450 miles east-southeast from the  
17      nearest remotely feasible underground sequestration area (South-Central Saskatchewan). A  
18      large capacity, high pressure pipeline would need to serve that nearest area even if sufficient  
19      capacity existed.
- 20      5. Higher capacity, more viable sequestration locations with sufficient potential capacity exceed  
21      1000 miles from the West Range plant site.
- 22      6. The East Range plant site is closer to Lake Superior which might be used for transshipment  
23      of captured CO<sub>2</sub> in tankers.
- 24      7. Given the energy, cost and danger of liquid or solid CO<sub>2</sub> transportation over the long  
25      distances both proposed sites are inappropriate for anticipated future CO<sub>2</sub> sequestration  
26      requirements.



1 **Q: Do you have any recommendations?**

2 A: Yes, I have recommendations. The PUC should require that both proposed site evaluations  
3 include the estimated energy consumption and economics of CO2 transportation and sequestration  
4 using appropriate permanent sequestration approaches in making its public interest determination. In  
5 addition, to indicate the financial penalty caused by the mandated siting, the PUC should also  
6 consider an economic evaluation of two alternate reference sites, one for a generating plant near a  
7 coal mine-mouth and another one near a permanent CO2 sequestration location, and ideally a third,  
8 that of a generating plant near a coal mine-mouth that is also near a permanent CO2 sequestration  
9 location.

10 **2. Cost of Control and Mitigation of Air Emissions from Proposed Flares**

11 **Q: Have you reviewed the air emissions data provided in Excelsior's proposal?**

12 A: Yes, I have reviewed air emissions data provided in Excelsior's proposal, and I am particularly  
13 concerned about the air emissions from proposed flares and the costs of containment.

14 **Q: What are your concerns about flare air emissions:**

15 A: My concerns focus on air emissions from flares and associated costs. Excelsior states in its Siting  
16 Application application:

17 The elevated flares for Mesaba One and Mesaba Two will be designed for a  
18 minimum 99 percent destruction efficiency for carbon monoxide and hydrogen  
19 sulfide." and that the flares are normally used only to oxidize treated syngas and  
20 natural gas combustion products during gasifier startup operations.

21 Siting Application, 3.4.1.1.3 Flares - Pages 183-184, et seq.:

22 However it also states that:

23 The flares will also be available to safely dispose of emergency releases from the  
24 IGCC Power Station during unplanned upset events or outages. The estimated  
25 maximum short-term and annual emission rates, based on agency guidance and  
26 equipment supplier specifications, are shown in Table 3.4-8.

Id. Here is that table, cited above:

**Table 3.4-8 Flare Short-Term Emission Rates (Phase I and II)**

Operating Mode	Emission Rate (Lb/Hr)				
	NOX	SO2	CO	PM10	VOC
Normal operation <sup>1</sup>	0.3	0.01	2.2	0.03	0.02
Normal startup operation <sup>2</sup>	230	370	5,350	28	21
Maximum flaring operation <sup>3</sup>	478	2,080	11,360	60	45
<b>Emission Rate (Tons/Year)</b>					
Maximum Annual <sup>4</sup>	26.8	24.6	572	3.4	2.6

<sup>1</sup> Natural gas pilot, only.

<sup>2</sup> Startup flaring of syngas for two gasifiers and two flares.

<sup>3</sup> Maximum flaring capacity for two flares, based on flaring syngas production from two gasifiers for each flare and a worst case upset sulfur content of 400 ppmv in syngas.

<sup>4</sup> Maximum annual emission based on combustion of approximately 700 billion Btu of syngas and 136 billion Btu of natural gas during startup, plant upsets, and normal operating conditions.

**Q: What are your concerns regarding air emissions during flare operation?**

**A:** My concerns about air emissions during flare operation are as follows:

1. The E-Gas process and the syngas it forms is similar to many existing processes that use flares for "startup", "plant upsets" (i.e. problems and emergencies) and "normal operating conditions".
2. As indicated in Table 3.1.3 the anticipated syngas formula (30-40% H<sub>2</sub>; 35-50% CO; 13-26% CO<sub>2</sub>; 1-5% CH<sub>4</sub>; 2-3% N<sub>2</sub> and Ar) at one atmosphere pressure is nearly identical to specialized heat treating and steel reducing atmospheres for which my company makes monitoring and control devices and that I have personally monitored and controlled.
3. Flares are often the single largest contributor to air emissions from such processes and the assumptions made on their use make very large differences in anticipated criteria air emissions from such processes.
4. The data presented in Table 3.4-8 indicates that the gasifier flares have the potential to be the most significant source of air emissions from the facility.



- 1 5. If the flare pilot is extinguished during an emergency or caused by an operator error the short  
2 term air emissions from the 185 foot stack may be significantly higher than indicated and  
3 could cause onsite health effects or fires and possibly offsite health risks too.
- 4 6. The air emission assumptions made are questionable and/or misleading, and in addition:
- 5 a. No maximum syngas flow rates through the flares are indicated during "upsets and  
6 emergencies" however the diameter of each syngas flare would apparently be 5.5  
7 feet, capable of large flow rates. Maximum startup and emergency flow rates should  
8 be specified.
- 9 b. Only two gasifiers are assumed to be operating at any one time. However, if there is a  
10 problem with one of the two, flaring will likely occur in from the third during its  
11 startup. Two or three flares could be simultaneously operating in high emission  
12 startup or emergency modes.
- 13 c. Normal operation is assumed to emit only the combustion products of the natural gas  
14 pilot. This assumes zero flow. The proposed E-Gas reactors will operate at 400+ psi  
15 and likely will release a portion of syngas through the flare at all times. During  
16 partial power operation can be assumed (as other in other syngas systems) that an  
17 unused fraction of the gas will be vented through flare
- 18 d. During an emergency or a syngas vessel valve failure, large amounts of syngas could  
19 vent through the flare. According to Excelsior Energy, during emergencies, the  
20 scrubber system would not operate and non-combustible air emissions, including  
21 selenium, arsenic and mercury, would vent directly to the atmosphere without  
22 reduction or control. If the flare is extinguished, no control or limitation of any  
23 emission would take place.
- 24 e. A "minimum 99% destruction efficiency" for CO and H<sub>2</sub>S is stated. Therefore CO in  
25 the syngas would range from maximums of 3,500-5,000 ppm and an undisclosed  
26 amount of H<sub>2</sub>S would be emitted. Flare monitoring data that I have measured would

1 indicate emissions of CO would approximate 10,000 to 35,000 ppm through smaller  
2 diameter flares. There seems no basis for the “99% reduction” assumed; if there is,  
3 such data should be provided, as well as the cost of achieving this “99% reduction.”

4 f. The majority of the facility HAPs are indicated as coming through the flares. No  
5 assumptions other than table footnotes are provided.

6 **Q: Do you have any recommendations regarding air emissions of flares?**

7 **A:** Yes. My recommendation is that Excelsior must include a much more detailed assessment of  
8 syngas flare operations, performance, flow rates, planned and unanticipated syngas upsets, emergency  
9 conditions and assumed frequency, component reliability, and on and offsite effects. Each of these  
10 has a significant impact on air emissions and must be considered in the overall evaluation of  
11 emissions and more to the point in this proceeding, the significant cost impacts of controlling and/or  
12 mitigating emissions during these planned and unavoidable flare occurrences. Excelsior must provide  
13 cost estimates of flare impacts and control and mitigation, and these must be considered by the  
14 Commission in its public interest determination.

15 **3. Costs of Plant Site and Off-Site Safety**

16 **Q: Do you have concerns about the extent of costs for Plant Site and Off-Site Safety?**

17 **A:** Plant operating safety and its potential for human and environmental impact has not been  
18 adequately considered in the application. With one exception, the applicant has included only  
19 standard (“boilerplate”) references to safety permits, construction issues, generic training and related  
20 material safety data sheets along with one reference to the CMP public access closure for “safety  
21 reasons. The exceptional reference is “Flaring of untreated syngas or other streams within the plant  
22 will only (Siting Application, Section 3.1.6.5 Flare). In one location, IGCC technology combines all  
23 the safety risks and potential repair, remediation, and liability costs associated with: 1, coal transport  
24 and storage; 2, natural gas fired combustion turbine-electric power plants; 3, steam turbine-electric  
25 power plants; and 4, forced evaporative cooling systems. Problems with or failures in each of these  
26 components of an IGCC plant pose relatively known safety risks both on the plant site and to the



1 surrounding community and environment. None of these safety risks are addressed by Excelsior  
2 Energy.

3 In addition, IGCC technology inherently adds three significant but relatively unknown additional  
4 safety risks:

- 5 1. High pressure gasifiers employing both natural gas and coal slurry as fuel and pure oxygen;
- 6 2. Use of low and variable energy content syngas as a feedstock to the gas turbines; and
- 7 3. Extreme technological complexity with a high probability of operational accidents.

8 Of these three, the syngas gasifiers would appear to cause the greatest safety risk both on and off site.

9 Normal Operation Gasifier Risk - The proposed IGCC intends to inject pure oxygen and coal  
10 slurry directly into two of three high pressure vessels at more than 400 psig during "normal"  
11 operation at a scale much larger than has been tried before. Gas valve control or sealing failures could  
12 result in a non-explosive but sudden increase in pressure that would either blow out undisclosed but  
13 probable "rupture disks" or cracking the vessel or its piping. This "normal operation" risk would  
14 result in a sudden, high volume air emission of the most contents of the gasifier including the  
15 "normal" contents (30-40% H<sub>2</sub>; 35-50% CO; 13-26% CO<sub>2</sub>; 1-5% CH<sub>4</sub>; 2-3% N<sub>2</sub> and Ar), most of  
16 the hazardous pollutants including mercury, and any additional combustion products from the  
17 pressure increase. The volume released could far exceed 30 times the actual volume of the gasifier,  
18 depending on the pressure relief setpoint, and pose a serious on-site asphyxiation and fire hazard.  
19 Residents downwind of the facility would also be at risk, especially since the release would occur at  
20 ground level.

21 Startup Gasifier Risk -- During startup, natural gas would apparently be used to heat the gasifier  
22 until it reaches appropriate temperatures and pressures. If the temperature in the vessel is below a  
23 critical value, at ambient pressure about 1200 Deg. F, and if the natural gas and oxygen valve set or  
24 ignition system fails in certain ways during the heat up, unburned combustible gas can accumulate in  
25 the gasifiers that can suddenly explode. Such explosions occur often in the auto industry in heat  
26 treating furnaces that use similar, but less explosive, gas mixtures. However, because they do not



1 operate at elevated pressures, less damage occurs. An explosion at elevated pressures in a gasifier  
2 vessel generally cannot be relieved by rupturing of a component. In this case the gasifier can  
3 potentially fracture the vessel into a number of pieces that can travel significant distances from their  
4 original location. Clearly there is significant on-site risk both to workers and other IGCC equipment.  
5 It is conceivable that smaller pieces, like bomb shrapnel, put offsite individuals and property at risk.

6 Emergency Gasifier Risk – It is not specified by Excelsior Energy what constitutes an  
7 “emergency”. However, because Excelsior Energy chooses to address only this risk in the joint  
8 application there must be other situations or combinations of situations more serious than that  
9 described above for which “Flaring of untreated syngas or other streams within the plant will only  
10 occur as an emergency safety measure during unplanned plant upsets or equipment failures.” In any  
11 event, such emergencies may or may not be served by flaring untreated syngas, especially if a flare or  
12 its associated valving is itself part of the failure.

13 This is one example of the kind of risk assessment that should be part of the EIS. Others should  
14 also be included. According to the IGCC industry itself:

- 15 • The most unpredictable startup activities concern shakedown of [the syngas] gasifier and gas  
16 processing systems and initial operation of the gas turbines on syngas. Early ASU startup and  
17 startup of the power block on natural gas ensure they stay off the critical patch (sic - intended  
18 word path?).
- 19 • The integrated plant controls including the gasifier safety shutdown and control systems must be  
20 thoroughly checked prior to first syngas production. Small programming glitches can  
21 significantly delay startup because of the time needed to prepare for each gasifier light-off.

22 Rich Exhibit \_\_\_\_, IGCC - The Challenges of Integration, Robert F. Geosits and Lee A. Schmoe  
23 Bechtel Corporation, Proceedings of GT2005, ASME Turbo Expo 2005: Power for Land, Sea and  
24 Air, June 6-9, 2005 Reno-Tahoe, Nevada, USA.

1 ConocoPhillips, Fluor and Siemens, the same team that is supposed to provide design,  
2 construction and operational expertise to the Mesaba Power facility attended an IGCC "risk"  
3 symposium sponsored by the DOE in 2004. A presentation in this symposium compared the  
4 IGCC technological, regulatory and economic risks to those posed by nuclear power and  
5 concluded that electric power utilities believed nuclear power plants posed less risk than  
6 IGCC. Rich Exhibit \_\_\_, Climate VISION Risk Framework for Advanced Clean Coal Plants  
7 Risks & Challenges, David Berg, Chief Advisor, DOE Policy Office, Presentation to Roundtable on  
8 Deploying Advanced Clean Coal Plants, July 29, 2004, Washington, DC.

9 This document provides a framework to address safety and economic risk issues and  
10 could be used by Excelsior Energy to properly evaluate the missing safety and risk  
11 information. The Commission must use this as its framework to assist in addressing the  
12 public interest and cost issues of safety and risk.

13 **Q: Do you have recommendations for consideration of the cost and public interest**  
14 **implications of safety, environmental and economic risks of IGCC?**

15 A: Recommendation for the EIS: The PUC should consider both known and potential safety and  
16 related environmental risks of the proposed plant in the EIS. Particularly, the EIS should reflect the  
17 potential safety and environmental risks posed by the three proposed syngas gasifiers and all  
18 proposed safety measures to mitigate their potential problems. Site selection criteria should favor that  
19 location with the least potential for accidental harm to the surrounding people and property and the  
20 least over all on and off-site environmental impact. As above, the Commission should add the  
21 framework presented in the DOE's Climate VISION Risk Framework for Advanced Clean Coal  
22 Plants Risks & Challenges when it considers costs and public interest.

23 **4. Costs of Evaporative (Wet) Cooling Tower and ZLD Air Emissions**



Excelsior Energy proposes to discharge water vapor and chemicals to the air through its use of evaporative (wet) cooling towers and evaporation from its ZLD system(s). Based on the inconsistent and incomplete data provided in the following tables:

**Table 3.6-6  
Water Appropriation Requirements**

Phase	West Range IGCC Power Station		East Range IGCC Power Station	
	Average Annual Appropriation (GPM)	Peak Appropriation (GPM)	Average Annual Appropriation (GPM)	Peak Appropriation (GPM)
Mesaba One	4,000 <sup>a</sup> -4,400 <sup>b</sup>	6,500	3,700 <sup>a</sup>	5,000
Mesaba One & Two	8,800 <sup>b</sup> -10,300 <sup>c</sup>	15,200	7,400 <sup>a</sup>	10,000

<sup>a</sup>Based on 8 COC in the gasification island and the power block cooling towers

<sup>b</sup>Based on 5 COC in the gasification island and the power block cooling towers

<sup>c</sup>Based on 3 COC in the gasification island and the power block cooling towers

Page 271

**Table 3.7-4 Quantitative Comparison of Environmental-Related Attributes at West and East Range Sites**

	Mesaba One and Mesaba Two Air Emissions <sup>1</sup> (Tons Per Year; Hg in lbs/yr)				SO <sub>2</sub> <sup>2</sup>	NO <sub>x</sub> <sup>2</sup>	PM <sub>10</sub> <sup>2</sup>	Hg <sup>1</sup>	CO <sub>2</sub> <sup>3</sup>	Class I Visibility (Days >10% Impairment) RWCA <sup>4</sup>	Permitted Wastewater Discharge (GPD)	Permitted Wastewater Discharge (GPD) Proposed Natural Gas Refinery	Permitted Wastewater Discharge (GPD) Proposed Natural Gas Refinery	Average Water Appropriation (GPM)	Cooling Tower Blowdown Discharge (GPM)	ZLD Water Discharge Rate (GPD)
	SO <sub>2</sub>	NO <sub>x</sub>	PM <sub>10</sub>	Hg <sup>1</sup>												
West Range	1350	2872	493	54	2016 (SB) 1831 (B)	15	1	2	3	4400 (B) 10300 (E)	390 (B) 3500 (E)	4400 (B) 10300 (E)	390 (B) 3500 (E)	4400 (B) 10300 (E)	390 (B) 3500 (E)	4400 (B) 10300 (E)
East Range	1350	2872	709	54	2016 (SB) 1831 (B)	49	20	12	5	7,400	9	7,400	9	7,400	9	7,400

1. Figures provided represent stack and fugitive emissions of selected pollutants assuming 100% capacity factor (sulfur dioxide, nitrogen oxides, volatile organic compounds, and particulate matter are included in totals). See Application for Part 700 New Source Review Construction Authorization attached as Appendix B for basis of estimates.

2. Mercury emissions from stack emission points represent peak annual emissions as permitted.

3. SO<sub>2</sub> emissions (lb/hr) are based on the Mesaba One and Mesaba Two sites. East Range Site with ZLD will have lower efficiency and higher emissions per kWh.

4. Visibility based on Calfuff Method 2, 1992 Method Data.

5. I = Phase I; II = Phase II.

6. I = Phase I; II = Phase II; East Range ZLD eliminates discharge of cooling tower blowdown.

7. Fuel dependent; GI = Gasification Island; PB = Power Block (i.e., eliminating cooling tower blowdown).

Page 134

**Table 3.4-17  
Estimated Wastewater Discharge Rates To West Range Site Receiving Waters**

	Cycles of Concentration	Peak Discharge (GPM)	Average Annual Discharge (GPM)
I	5	1,300	550-900
I and II	3	5,140	2,200-3,500

Page 208



Table 3.4-18 Wastewater Discharge Rate From Systems In The Phase I IGCC Power Station

Wastewater Component	Cycles of Conc.	Expected Discharge (GPM)	
		Ann. Avg.	Peak
Power Block Cooling Tower Blowdown	8	335	498
HRSG Demineralizer /RO Reject Water*	8	15	15
HRSG Blowdown*	8	17	17
Gasifier/ASU Cooling Tower Blowdown	8	140	209
Plant Service Water	8	45	45
Mixed Bed Polisher Regen./Backwash	8	15	15
Power Block Cooling Tower Blowdown	5	585	873
HRSG Demineralizer /RO Reject Water*	5	15	15
HRSG Blowdown*	5	17	17
Gasifier/ASU Cooling Tower Blowdown	5	245	366
Plant Service Water	5	45	45
Mixed Bed Polisher Regen./Backwash	5	15	15
Power Block Cooling Tower Blowdown	3	1,180	1,750
HRSG Demineralizer /RO Reject Water*	3	15	15
HRSG Blowdown*	3	17	17
Gasifier/ASU Cooling Tower Blowdown	3	494	732
Plant Service Water	3	45	45
Mixed Bed Polisher Regen./Backwash	3	15	15

\*The HRSG Demineralizer/RO Reject Water stream and HRSG Blowdown stream both discharge directly to the Power Block Cooling Tower and, therefore, would be reflected in the discharge from the Power Block Cooling Tower. For example, the average annual discharge from the IGCC Power Station assuming 8 cycles of concentration would be 535 gpm (335+140+45+15), not 567 (335+15+17+140+45+15).

Page 210

The Mesaba I and II combined facility proposes to evaporate somewhere between 5,000 and 10,000 gallons of water per day. The vast majority of the evaporation is assumed to be through the "gasifier/ASU" and "power block" evaporative cooling towers.

Especially during cold winters, but also occurring year round during more humid periods, the water vapor often forms a significant continuous cloud of water vapor and mist that can continue downwind of the cooling tower for several miles. Within a mile or two of the facility, the evaporated water can also produce a ground fog at the ground level and extending upward for several hundred feet.

In addition to the obstruction of view this water vapor causes, this cloud can condense and form a slippery layer that in the winter can freeze and build up ice on homes, walkways and streets and pose a danger to nearby residences.

Evaporative cooling towers always emit more than water. The upward flow of the air inside these towers mix pick up (entrain) small droplets of water containing any of the chemicals and organisms that are added to or come from the water source being used or form as a result of chemical or biological

reactions in the tower. An example chemical is chlorine. An example organism that forms in warm weather causes “legionnaires’ disease”. As the droplets evaporate, there diameter reduces, they are carried further and they can penetrate far into lungs. This tendency increases health risks of individuals several miles downwind of the discharge point. These particles also can significantly add to the facility’s PM<sub>10</sub> and PM<sub>2.5</sub> air emissions. These emissions do not appear to have been considered by Excelsior Energy. In fact none of the cooling tower emission, health and visual obstruction concerns or the costs of controlling and mitigating them seems to have been considered at all.

Excelsior proposes to consume the following chemicals that may evaporate or become entrained in the as a cooling tower air emission:

Table 3.4-19 Chemical Additives Used Per Year (Phase I and II)

Chemical	Point(s) Of Introduction	Estimated Usage (lbs/Year)	Estimated Residual In Discharge	Basis, % In Discharge
Scale Dispersant	Cooling Towers	75,000	750	1%
Corrosion Inhibitor	Cooling Towers	300,000	3000	1%
Dechlorination - Sodium bisulfite	Cooling Tower Blowdown Sump, Reverse Osmosis System	15,000 7500	150 75	1%
Oxygen Scavenger	Boiler Feed Water	6600	66	1%
Condensate Corrosion Inhibitor-Neutralizing Amine	Boiler Feed Water	2200	22	1%
Chlorination - Sodium Hypochlorite	Cooling Towers	300,000	1500	0.5%
pH control-93% Sulfuric acid	Cooling Towers, Reverse Osmosis, Mixed Bed	18,000 3000 11,000	36 6 22	0.2%
Sodium Hydroxide	Mixed Bed regeneration	11,000	0	(totally neutralized)
Scale and Corrosion inhibitor	Boiler/H2SG	13,000	130	1%
Anti-Scaleant	Reverse Osmosis, Deionizer	150 200	3 2	1%
Non-Oxidizing Biocide	Cooling Towers	11,000	22	0.2%

The majority of the water would be used in the cooling towers, and a significant fraction could be discharged to the air in vapor or mist form. The chemicals include significant quantities of unspecified “non-oxidizing biocide”, “corrosion inhibitor”, and “scale dispersant” as well as sodium hypochlorite (bleach) and sulfuric acid. The table indicates that only 1% or less of these chemicals will be discharged in wastewater. The remaining portions would therefore leave the facility as hazardous or solid waste or as an undisclosed air emission. No mention is made of the fraction of dissolved solids in the naturally



1 occurring water that would also be discharged. This information is not disclosed, nor are effects or the  
2 costs of prevention, control and mitigation considered.

3 There are alternative cooling technologies (such as use of a mine pit heat exchanger, dry cooling  
4 towers, natural draft evaporative towers and combination cooling systems) that can mitigate this risk.  
5 Some are even more energy efficient and may be more cost effective than the proposed cooling approach.

6 **Q: Do you have recommendations for the Commission to consider in its cost and public interest**  
7 **analysis of Cooling Tower and ZLD Air Emissions?**

8 A: Yes. It is crucial to quantify and evaluate the air emissions, visual impairment, and  
9 health effects from the proposed cooling tower systems and ZLD system(s) and the costs of  
10 prevention, control and mitigation. The Commission should consider costs of various cooling  
11 alternatives and require ones that have less environmental and health impacts even if they have  
12 somewhat higher capital costs.

##### 13 **5. Cooling Water Blowdown ZLD**

14 **Q: Have you reviewed the Cooling Water Blowdown ZLD and found cost and public interest**  
15 **concerns?**

16 A: Yes, there are design problems that require Zero Liquid Discharge (ZLD) but Excelsior has not  
17 planned on ZLD for both sites. Excelsior must integrate ZLD into the West site plan, and the cost of  
18 this necessary addition must be considered.

19 For example, regarding the East site, Excelsior states:

20 Stringent conditions applying to discharges of mercury in the Lake Superior  
21 Basin watershed make it necessary for the East Range IGCC Power Station to  
22 eliminate all direct wastewater discharges to receiving waters...

23 Siting App., 3.1.6.3.2 Elimination of Cooling Tower Blowdown: East Range Site – Page 158

24 In addition, the Siting Application states:

25 The allowable quantity and concentration of chemical species in  
26 wastewater discharges from the IGCC Power Station are dependent in large part



1 on the characteristics of potential receiving waters in the Project's vicinity. In the  
2 case of the West Range and East Range Sites, the receiving waters are located in  
3 different watershed basins that have greatly different water quality criteria.  
4 Importantly with respect to wastewater discharges, the East Range Site is located  
5 within the Lake Superior Basin watershed, and the standards that apply to  
6 discharges of bioaccumulative chemicals of concern ("BCCs") in that basin  
7 effectively preclude discharges of cooling tower blowdown from Mesaba One  
8 and Mesaba Two. The reason for such discharge prohibitions is that mercury – a  
9 BCC – is found in the source waters for the East Range Site at concentrations  
10 nearly equal to the water quality criteria standard applied to end-of-the-pipe  
11 discharges. Siting Application, 3.4.2 Water Effluents – Pages 199-200

12 It appears that a primary reason the West Range "Greenfield" site is favored over the East Range  
13 "Brownfield" site is that the high surface water mercury levels at the East Range Site require a ZLD  
14 and the West Range site does not -- the cost and power efficiency loss supposedly caused by addition  
15 of a ZLD system is too great. The application does not consider that the mercury removal  
16 technology, such as reverse osmosis, ion exchange and activated carbon among others, can reduce the  
17 high surface water mercury levels before use possibly eliminating the need for the ZLD. The  
18 application also does not acknowledge that there is a strong likelihood that mercury, selenium and  
19 arsenic wastewater discharge limits will be reduced in the region of the West Range site in the near  
20 future, nor does it consider that the belief that a ZLD system is not needed for the West Range site is  
21 not correct. Excelsior's proposal does not address the prohibition of the "impaired waters" status of  
22 the Mississippi and Swan Rivers, and its inability to discharge and further impair these waters.

23 Not considering mercury removal technology for the East Range site or a ZLD system for the  
24 West Range site is limiting, shortsighted and inappropriately and unfairly skews the site location  
25 decision. Given the low flows likely available to dilute these discharges (see Cumulative Impacts), a  
26 ZLD system will likely be required for the West Range site anyway. In addition (see cooling tower air

Emissions comments), alternative, closed loop cooling systems are available that may have less impact on both the operating cost and the ZLD need.


**Q: Do you have recommendations that the commission consider regarding a ZLD system and the cost of incorporating ZLD into both sites and the potential cost if it is not included?**

**A:** The Commission must evaluate alternative feed water mercury removal technologies, consider alternative condensate cooling options and/or require that a ZLD be installed at the West Range site. The costs and public interest value of this system must be considered.

#### **6. Cumulative Effects of Mesaba Power and Minnesota Steel**

**A:** Neither Excelsior Energy nor Minnesota Steel Industries (MSI) has considered the combined costs of both proposals and the impact of these two projects in tandem if the West Range site is selected by for the Mesaba Power facility. While both companies claim to be aware of each other and even though MSI is further ahead in their permitting and financing, Excelsior has not mentioned MSI environmental or resource use issues and cost distribution in any of its submittals. If both projects go forward, there may not be sufficient resources for both projects at any cost, and to construct both in the West Greenfield site may be cost prohibitive due to infrastructure costs.

A map showing both proposed facilities and their boundaries would look about like this:





1 MSP proposed to construct a large steel-making facility that uses conventional and  
2 “commercially available” mining, ore, and metals processing technologies. Their unfortunate but  
3 professed intent to use “proven” technologies all but assures significant air, water and solid waste  
4 discharge impacts and significant costs of prevention, control, and mitigation that make many of  
5 Excelsior’s cost assessments invalid.

6 Most chemicals proposed for discharge to the air and water by MSI are identical to those  
7 proposed by Mesaba Power for the West Range site. Both proposed projects will also discharge to  
8 the same regional ambient air, and require significant revision of the West Site portion of the  
9 application. If Excelsior locates Mesaba Power at the West Range site, also in the same  
10 watershed, there can be no question that the surface and ground water resource availability,  
11 quality and impact assumptions used by Excelsior in its application for the West Range site are  
12 incorrect and need to be completely revised.

13 Excelsior mentions MSI only in conjunction with shared roads and natural gas pipelines,  
14 and only mentions these where cost savings may be realized. Infrastructure costs are deemed a  
15 “Trade Secret” by Excelsior. Yet the eastern boundary of Mesaba West Site and the western  
16 boundary of Minnesota Steel as currently proposed nearly join north of Marble.

17 **Q: Do you have recommendations for the Commission regarding consideration of MSI and the**  
18 **impacts of tandem projects in its cost and public interest analysis of Excelsior?**

19 **A:** Yes. I recommend that the Commission require revision of all of Excelsior’s assumed air and  
20 water quality, surface and ground water resources and infrastructure calculations to include  
21 cumulative cost benefits and costs incurred based on the assumption that the MSI is constructed  
22 as proposed. Then, require revaluation of the proposed West Range site overall costs and  
23 operating economics to reflect the MSI presence. If the Commission does not complete this  
24 analysis, it should remove the West Range site from further consideration.

25 **Q: Do you have concerns about statements regarding economic benefits and costs?**

26 **A:** Yes, I am concerned that economic benefits are overstated and that costs are not addressed.



1 In preparation for this testimony, I searched for studies regarding economic  
2 development costs and benefits and found a study of the specific project at issue which  
3 does not seem to have been entered in the record. This study, also by Labovitz School,  
4 addresses "economic impact" of the Mesaba project on Itasca County. It is problematic,  
5 in the same ways the Labovitz study produced by Excelsior is, and the findings and  
6 conclusions are suspect as the information it is based on comes from those interested in  
7 the development. Exhibit \_\_\_\_ (Rich 4), The Economic Impact of Constructing and  
8 Operating An Intergrated Gasification Combined-Cycle Power-Generation Facility on  
9 Itasca County, Labovitz School, University of Minnesota-Duluth (2006). There are no  
10 negatives addressed, no costs addressed, costs such as loss of tourism, local health  
11 impacts, loss of water supplies, etc., and does not address environmental costs not borne  
12 by the developer, or alternatives to the development that would be more beneficial.

13 The modeling assumptions are limited. Some are provided by U.S. government  
14 economic databases, and it is unclear to me who determines what the percentage of labor,  
15 equipment and materials that would be procured inside Minnesota or the particular region  
16 being evaluated. This is a key assumption in the model and should be addressed to be  
17 credible. Also, another key to determining indirect economic impact, the indirect  
18 employment, services and materials multiplier ratios, are not disclosed, and are hidden in  
19 the computer model. This is important because indirect economic impact comprises the  
20 bulk of the claimed economic benefits.

21 I worked with a similar state model at the former Minnesota Energy Agency. That  
22 model determines the future economic effects only if all the assumptions used never  
23 change, all the assumptions are corrected for physical, not economic constraints. All

1 negative impacts are also considered. There does not even appear to an attempt to include  
2 a “low”, “medium”, and “high” range or probability given the uncertainty of the global  
3 prices of energy, raw materials and other commodities that can cause the projects to fail.  
4 In addition, UMD only includes few disclaimers – especially disappointing since this  
5 developer driven type of study is suspect because it would also have shown grand  
6 numbers for the Hibbing chopsticks factory and the Cohasset biotech facility.

7 While I understand the developer interest in using studies that support their  
8 project, they should not be given great weight by the Commission. The Labovitz studies  
9 don’t even disclose or disclaim the potential economic risk these projects can pose. There  
10 is no impartiality and the results are not credible.

11 **Q: Does this conclude your testimony?**

12 **A:** Yes, it does.