

January 4, 2010

VIA HAND DELIVERY AND U.S. MAIL

Terry J. Romine
Executive Secretary
Public Service Commission
6 Saint Paul Street
Baltimore, Maryland 21202

Re: The Potomac Edison Company's Application for a Certificate of Public Convenience and Necessity To Construct the Maryland Segments of a 765 kV Electric Transmission Line and a Substation in Frederick County, Maryland

Dear Ms. Romine:

On December 21, 2009, The Potomac Edison Company ("Potomac Edison") filed an Application to Construct the Maryland Segments of a 765 kV Electric Transmission Line and a Substation in Frederick County, Maryland (the Maryland Segments of the "PATH Project")¹. On that same date, PATH Allegheny Virginia Transmission Corporation ("PATH-VA") filed a Motion to Withdraw Application and Terminate Proceeding ("Motion") with the Virginia State Corporation Commission in which PATH-VA requested approval to withdraw its application for authorization to construct those segments of the PATH Project in Virginia. In its December 21, 2009 Motion, PATH-VA stated its intention was to file a new application in 2010 based on the most current information then available with regard to the PATH Project and to propose a procedural schedule for the Commission's consideration that would be aligned with the existing procedural schedule for the pending application in West Virginia and the recently-filed

¹ The PATH Project is an approximately 276 mile transmission line stretching from West Virginia, into Virginia, and into Maryland where it is proposed to connect with the existing 500 kV transmission system in Maryland at the proposed Kemptown Substation.

application in Maryland for the portions of the PATH Project that will be constructed in those states.²

On December 29, 2009, PATH-VA amended its Motion to Withdraw to provide information regarding the sensitivity analyses ordered by the Virginia Hearing Examiner on December 4, 2009.³ In the amendment, PATH-VA quoted a letter from PJM Interconnection, L.L.C. (“PJM”) stating that the analyses “suggest that the PATH Project appears not to be needed in 2014.” PATH-VA stated that PJM’s full 2010 RTEP process will dictate when a future application for the PATH Project would be filed in Virginia but that it is not expected to be filed earlier than the third quarter of 2010.⁴

The West Virginia Commission’s procedural schedule for consideration of the PATH Project sets June 29, 2010 as the date for the filing of supplemental direct testimony regarding electrical need. This schedule will permit the West Virginia case to be updated with information on electrical need and a new projected in-service date after the results of a comprehensive analysis in the context of the 2010 RTEP process are known.

In Maryland, Potomac Edison will request that the Commission follow a similar procedural process as has been adopted in West Virginia. Potomac Edison will work with entities that wish to participate in the review of the PATH Project in Maryland to develop a schedule in Maryland that will permit the review of non-need issues associated with the project to proceed while accommodating the filing of supplemental electrical need testimony reflecting the outcome of the 2010 RTEP.⁵ Potomac Edison believes this supplemental testimony should

² In November 2009, the West Virginia Public Service Commission granted a motion for modification of the procedural schedule for consideration of the PATH Project and the Virginia Commission denied a similar motion.

³ The sensitivity analyses ordered by the Virginia Hearing Examiner were filed on January 4, 2010 and a copy of the filing is enclosed. These sensitivity analyses also relate to the timing of the electrical need for the PATH Project in Maryland and West Virginia.

⁴ On December 30, 2009 at the conclusion of oral argument on the Motion to Withdraw, the Virginia Hearing Examiner suspended the procedural schedule with regard to the filing of rebuttal testimony by PATH-VA, discovery and the start of the evidentiary hearing on January 19, 2010 pending the Virginia Commission’s consideration of the motion to withdraw.


⁵ Potomac Edison recognizes that the Federal Energy Regulatory Commission (“FERC”) backstop permitting authority could cause concern with the scheduling discussed above. At this time, Potomac Edison is willing to commit to the Commission that it would not seek FERC backstop siting authority under Section 216(b)(1)(C) of the Federal Power Act prior to June 29,

Terry J. Romine, Executive Secretary
January 4, 2010
Page 3

be filed contemporaneously with supplemental testimony in West Virginia. In addition, assuming the Motion to Withdraw is granted in Virginia, a new application for authorization to construct the PATH Project in that state would be expected to be filed shortly after supplemental need testimony is filed in West Virginia and Maryland, thereby further aligning consideration of the PATH Project in all three states where it is proposed to be constructed.

Potomac Edison will be available at the January 6, 2010 Administrative Meeting to provide the Commission with additional information on the procedural issues associated with this Application, including the tolling of the date when an application for the PATH Project could be filed with FERC.

Respectfully submitted,



J. Joseph Curran, III
Mindy L. Herman
Saul Ewing LLP
500 East Pratt Street
Baltimore, Maryland 21202
(410) 332-8600

Attachment
cc: Service List Attached

2011, a full year after the proposed filing date for the supplemental testimony on the need for the project.



HUNTON & WILLIAMS LLP
RIVERFRONT PLAZA, EAST TOWER
951 EAST BYRD STREET
RICHMOND, VIRGINIA 23219-4074

TEL 804 • 788 • 8200
FAX 804 • 788 • 8218

RICHARD D. GARY
DIRECT DIAL: 804 • 788 • 8330
EMAIL: rgary@hunton.com

January 4, 2010

FILE NO: 27364.71

Via Electronic Filing

Hon. Joel H. Peck
Clerk
State Corporation Commission
Document Control Center
Tyler Building, 1st Floor
1300 East Main Street
Richmond, Virginia 23219

**Application of
PATH Allegheny Virginia Transmission Corporation for
Certificates of Public Convenience and Necessity to Construct Facilities:
765 kV Transmission Line through Loudoun, Frederick, and Clarke Counties
Case No. PUE-2009-00043**

Dear Mr. Peck:

Hearing Examiner Alexander F. Skirpan, Jr. issued a Ruling on December 4, 2009 ("Ruling") that directed PATH Allegheny Virginia Transmission Corporation ("PATH-VA") "to present the results of PJM's load deliverability and generator deliverability tests for 2014, 2015 and 2016" for 6 specified scenarios ("sensitivity analyses"). (Ruling at 2) In addition, the Hearing Examiner asked that, along with the results of those sensitivity analyses, PATH-VA submit a schedule of changes in generation from its April 2009 load flow analysis. (Ruling at 3) At PATH-VA's request, PJM Interconnection, L.L.C. prepared those sensitivity analyses and the results are enclosed with explanatory text along with a schedule of generation changes from the April 2009 load flow analysis.

Sincerely yours,

Richard D. Gary

RDG/tms



Hon. Joel H. Peck

January 4, 2010

Page 2

Enclosure

cc: Hon. Alexander F. Skirpan, Jr.
William H. Chambliss, Esq.
Service List
Randall B. Palmer, Esq.
Noelle J. Coates, Esq.

PATH-VA Response to
Hearing Examiner's Ruling of December 4, 2009

The Hearing Examiner's ruling of December 4, 2009 directed PATH-VA to present the results of several sensitivity analyses related to the need for the PATH Project. These analyses incorporate the assumptions set forth below but such analyses are not the equivalent of a comprehensive RTEP analysis. Only the results of a comprehensive analysis in the context of the 2010 RTEP Process can be used to determine and support a definitive assessment as to the future need and in-service date for the PATH Project. While the results of these sensitivity analyses apply directly to the need date for the PATH Project, they suggest the potential for delays to other projects as well. In addition, these sensitivity analyses did not integrate any of the transmission system upgrades approved as part of the RTEP during 2009. The interactions among any potentially delayed projects and the transmission system, including the 2009 RTEP projects, must be examined in detail to ensure that no violations of reliability criteria exist before delaying previously approved projects. Lastly, as the sensitivity results demonstrate, the timing of criteria violations related to load deliverability analyses is noticeably impacted by the amount of demand response resources in an area under test. If, as expected, some number of RTEP projects are to be delayed as a result of the comprehensive 2010 RTEP analysis, it will be critical to examine the results of the 2013/14 RPM Base Residual Auction in that analysis to ensure that the appropriate need dates are identified.

At the request of PATH-VA as directed by the Hearing Examiner's December 4 ruling, PJM performed additional generation deliverability and load deliverability testing for the scenarios listed below:

1. PATH's April 2009 load flow analyses updated to reflect the following changes in generation: (i) all existing generation as of December 7, 2009, which is not scheduled to be retired before 2014; (ii) all proposed generation that cleared the May 2009 RPM Auction; and (iii) all proposed generation with a signed ISA as of December 7, 2009 ("Scenario 1 generation");
2. PATH's April 2009 load flow analyses updated for the changes in Scenario 1 generation, and updated to reflect PJM's 2010 load forecast;
3. PATH's April 2009 load flow analyses updated for the changes in Scenario 1 generation, and updated to reflect the demand response and energy efficiency resources that cleared the May 2009 RPM Auction;
4. PATH's April 2009 load flow analyses updated for the changes in Scenario 1 generation, and PJM's 2010 load forecast (*i.e.*, Scenario 2) and updated to

reflect the demand response and energy efficiency resources that cleared the May 2009 RPM Auction;

5. PATH's April 2009 load flow analyses updated for the changes in Scenario 1 generation, PJM's 2010 load forecast, and to reflect the demand response and energy efficiency resources that cleared the May 2009 RPM Auction (*i.e.*, Scenario 4), and updated to reflect the forecasted additional demand response and energy efficiency resources for Virginia shown in Table 6 on page 25 of Sierra Club witness Fagan's pre-filed direct testimony. The amounts for years 2014, 2015, and 2016 are shown as 367, 420, and 469, respectively, and
6. PATH's April 2009 load flow analyses updated for the changes in Scenario 1 generation, PJM's 2010 load forecast, the demand response and energy efficiency resources that cleared the May 2009 RPM Auction, and the forecasted additional demand response and energy efficiency resources for Virginia shown in Table 6 on page 25 of Sierra Club witness Fagan's pre-filed direct testimony (*i.e.*, Scenario 5) and updated to reflect the forecasted additional demand response and energy efficiency resources for the Mid-Atlantic shown in Table 6 on page 25 of Sierra Club witness Fagan's pre-filed direct testimony. The amounts for years 2014, 2015, and 2016 are shown as 1,825, 2,140, and 2,403, respectively.

The April 2009 study and the December 2009 sensitivity analyses started with the same base case and transmission topology. The April 2009 study used the PJM 2009 Load Forecast which included the demand response that cleared in the 2011/12 RPM base residual auction held in May 2008. The December 2009 sensitivity analyses used load forecast, demand response and energy efficiency assumptions consistent with the scenarios defined above. In addition, the December 2009 sensitivity analyses included updated generation information. All existing generation expected to be in-service beginning in June 2014 was included. Generation from recently announced retirements such as Eddystone 1 & 2, Cromby 1 & 2, Vineland 8, Kearny 11 & 12, Benning, Buzzard, Indian River 1 & 2 and Hudson 1 were all off-line in the case used for the December 2009 sensitivity analyses. New generation which had progressed to the point of executing an ISA as well as new generation that cleared in the May 2009 RPM base residual auction for 2012/13 were included in the case along with all of their associated network upgrades. Attachment A includes a table identifying these new generation resources, added to the analysis since the April 2009 study.

New Capacity Emergency Transfer Objectives (CETO) were calculated for each of the locational deliverability areas (LDA) that were tested under each scenario. The calculated CETOs are shown in the following table.

Scenario	Dominion	Mid-Atlantic	Southern Mid-Atlantic	Eastern Mid-Atlantic
S1	1340	8510	6890	9210
S2	2310	8160	6930	8790
S3	960	5460	5900	8100
S4	1930	5130	5950	7690
S5	1530	NA	NA	NA
S6	NA	3120	5670	6460

Table 1 – CETO Values Used in the December 2009 Sensitivity Analyses

The detailed results of the thermal analyses are shown in the attached spreadsheets, included in Attachment B. Each spreadsheet is labeled corresponding to the scenario that was tested. The results of the analyses from Scenario 5 and Scenario 6 were combined into a single table.

The detailed results of the reactive analyses are shown in the Table 2 below. Note that there were no voltage criteria violations identified for Scenarios 3 through 6 that would require the PATH Project in 2014. Although there are no voltage criteria violations in 2014 for Scenarios 3 through 6, the additional analysis that is described below suggests voltage criteria violations could occur as early as 2016, based on observed CETO margins and forecasted load growth. A more comprehensive analysis of these issues will be completed as part of the 2010 RTEP.

Item #	Contingency	Scenario 1 Mid-Atlantic Load Deliverability	Scenario 2 Mid-Atlantic Load Deliverability	Scenario 1 Eastern Mid- Atlantic Load Deliverability	Scenario 2 Eastern Mid- Atlantic Load Deliverability	Scenario 2 Southern Mid- Atlantic Load Deliverability
1	Bedington - Black Oak	Collapse	Collapse			
2	Bedington 500 kV capacitor	Collapse				
3	Doubt 250 kV capacitor	Collapse				
4	Keystone - Jacks Mountain	Collapse	Collapse			
5	Huntington - Conastone	Collapse	Collapse	Collapse	Collapse	
6	Conemaugh - Huntington	Collapse	Collapse	Collapse	Collapse	
7	South Bend - Keystone	Collapse	Collapse			
8	Doultz - Brighton	Collapse	Collapse			
9	Conastone - Brighton	Collapse				
10	Conemaugh - Keystone	Collapse				
11	Black Oak - Hatfield	Collapse	Collapse			
12	Conemaugh - Jacks Mountain	Collapse	Collapse			
13	Jacks Mountain - Juniata #2	Collapse	Collapse			
14	Jacks Mountain - Juniata #1	Collapse	Collapse			
15	Mt. Storm - T15	Collapse				
16	Doubt - T15	Collapse	Collapse			
17	Calvert Cliffs Generator #1	Collapse				
18	Calvert Cliffs Generator #2	Collapse				
19	Calvert Cliffs - Walpin Chapel #1	Collapse				
20	Calvert Cliffs - Walpin Chapel #2	Collapse	Collapse			
21	Bedington - Doubt	Collapse			Collapse	
22	Conastone - Peach Bottom	Collapse	Collapse	Collapse	Collapse	
23	South Bend - Yukon	Collapse	Collapse			
24	Susquehanna Generator #2	Collapse	Collapse	Collapse	Collapse	
25	Bethlehem Steel generators	Collapse	Collapse	Collapse	Collapse	
26	Rock Spring OT 3 & CT 4	Collapse				
27	Rock Spring CT 1 & CT 2	Collapse				Collapse
28	Juniata - Conbury - Susquehanna	Collapse				
29	Limerick Generator #2	Collapse		Collapse	Collapse	
30	Limerick Generator #1	Collapse	Collapse			
31	Mt. Storm - Meadow Brook #2	Collapse			Collapse	
32	Conastone 500 kV capacitor	Collapse			Collapse	
33	Juniata - TMI	Collapse		Collapse	Collapse	
34	TMI 500 kV capacitor	Collapse			Collapse	
35	Susquehanna 500 kV capacitor	Collapse			Collapse	
36	Jacks Mountain capacitor	Collapse	Collapse		Collapse	
37	Alburtis 500 kV capacitor	Collapse		Collapse	Collapse	
38	Juniata 500 kV capacitor	Collapse	Collapse		Collapse	
39	Huntington Generator #3	Collapse				
40	Peach Bottom Generator #3	Collapse				
41	Yukon - T174 tap	Collapse	Collapse			
42	Limerick 500 kV capacitor	Collapse		Collapse	Collapse	
43	Peach Bottom P04 generators	Collapse	Collapse		Collapse	

Table 2 – Voltage Violations Identified in the December 2009 Sensitivity Analyses

In addition to the voltage studies noted above, PJM was able to do limited “PV” or “power-voltage” analysis for Scenario 3 to evaluate the impact of critical contingencies on system voltages as power transfers are increased across the system. The results of the PV analysis are shown in the following figures. Figure 1 below shows the voltage magnitude at the Meadow Brook 500 kV Substation as transfers into the Mid-Atlantic LDA increase, for the contingency loss of the Bedington – Black Oak 500 kV line. Figure 1 shows that, with increasing levels of megawatt (MW) transfers to the Mid-

Atlantic LDA, the voltage at the Meadow Brook 500 kV Substation drops reaching a 5% voltage drop limit at 6,260 MW, the steady state stability limit at transfer levels of approximately 6,790 MW, and a voltage collapse at a transfer level of approximately 6,830 MW. The CETO for the Mid-Atlantic LDA for this scenario is shown at 5,460 MW.




Figure 1. Voltage Magnitude at Meadow Brook 500 kV vs. MW Transfer to Mid-Atlantic LDA for Scenario 3. (Contingency: Loss of Bedington to Black Oak 500 kV)

Figure 2 shows the post contingency voltage at the Meadow Brook 500 kV Substation versus the post contingency flow on the Meadow Brook – Loudoun 500 kV line. The steady state stability limit is indicated at the “knee of the curve” where the flow on the line reduces as transfers into the Mid-Atlantic LDA are increased. The knee of the curve is reached when the transfers into the Mid-Atlantic LDA are approximately 6,790 MW. Recall the CETO for the Mid-Atlantic LDA for this scenario is 5,460 MW.




Figure 2. Voltage Magnitude at Meadow Brook 500 kV vs. Post-Contingency Flow on Meadow Brook to Loudoun 500 kV for Scenario 3. (Contingency: Loss of Bedington to Black Oak 500 kV)

ATTACHMENT A

Bus	Area	Area #	Name	PMAX (MW)	December 2009 GD	PMAX	
ID	Name			PMAX (MW)	PMAX (MW)	Change (MW)	Reason for change
1HNSMLK.1	226 PENELEC	54		53.5	53.5	-0.5	CIR Changes
1HNSMLK.2	226 PENELEC	54		53.5	53.5	-0.5	CIR Changes
1HNSMLK.3	226 PENELEC	54		53.5	53.5	-0.5	CIR Changes
1HNSMLK.4	226 PENELEC	54		53.5	53.5	-0.5	CIR Changes
1HNSMLK.5	226 PENELEC	54		53.5	53.5	-0.5	CIR Changes
1Q59C	226 PENELEC	19		10	10	0	O53 ISA
1TMI1GEN	227 METED	786		810	24	-144	T182 Interim ISA
1CROMBY.1	230 PECO	144					Deactivation
1CROMBY.2	230 PECO	201				-201	Deactivation
1EDDYSTN1	230 PECO	279				-279	Deactivation
1EDDYSTN2	230 PECO	309				-309	Deactivation
1FORDACT1	230 PECO	157		176	19	-19	R81 ISA
1FORDACT2	230 PECO	157		176	19	-19	R81 ISA
1FORDAST1	230 PECO	233.1		245	11.9	-11.9	R81 ISA
1FORDBC1	230 PECO	157		176	19	-19	R81 ISA
1FORDBC2	230 PECO	157		176	19	-19	R81 ISA
1FORDBS1	230 PECO	233		245	12	-12	R81 ISA
1KEARNY.11	231 PSEG	130.3				-130.3	Deactivation
1KRNY9&10	231 PSEG	126				-126	Deactivation
3VNL.D.8-9	224 AEP	11				-11	Deactivation
4HR4	235 DP&L	189		187	2	-2	T51 ISA
1HR1	235 DP&L	121		126	5	-5	T51 ISA
2HR2	235 DP&L	121		126	5	-5	T51 ISA
3HR3	235 DP&L	121		126	5	-5	T51 ISA
5HRS	235 DP&L	126		125	-1	1	T52 ISA
6HR6	235 DP&L	126		125	-1	1	T52 ISA
7HR7	235 DP&L	126		125	-1	1	T52 ISA
8HR8	235 DP&L	187		190	3	-3	T52 ISA
1VAUGHN	235 DP&L	5		4	-1	1	T12 modification
105KEYSTN	205 AEP	50		55	5	-5	Q10 ISA
205KEYSTN	205 AEP	50		55	5	-5	Q10 ISA
305KEYSTN	205 AEP	50		55	5	-5	Q10 ISA
405KEYSTN	205 AEP	50		54	4	-4	Q10 ISA
405BSG1	205 AEP	260		280	20	-20	R62 ISA
105SOLIDA	205 AEP	165				-165	P30 Suspended
5109STUART	209 DAY	2.3		2.8	0.5	0.5	CIR Changes
2DRESD2U	222 CE	867		937	70	-70	Q49 Interim ISA
3DRESD3U	222 CE	867		937	70	-70	Q50 Interim ISA
1QUAD:U	222 CE	867		937	70	-70	Q51 Interim ISA
2QUAD:2U	222 CE	867		937	70	-70	Q51 Interim ISA
1EQUIS:R	222 CE	21.7		21	-0.7	0.7	CIR Changes
4EQUIS:R	222 CE	32.4		44	11.6	-11.6	CIR Changes
2EQUIS:B	222 CE	23.2		21	-2.2	2.2	CIR Changes
3EQUIS:B	222 CE	22.7		21	-1.7	1.7	CIR Changes
1R35	222 CE	50		50	0	0	R35 ISA
1033C	222 CE	4		4	0	0	O33 FSA
1059C	226 PENELEC	19.8		19.8	0	0	O59 FSA
1059E	226 PENELEC	79.2		79.2	0	0	O59 FSA
1P14C	222 CE	16		16	0	0	P14 FSA
1P26C	222 CE	4		4	0	0	P26 FSA
1P52C	201 AP	16		16	0	0	P52 FSA
1P58C	201 AP	16		16	0	0	P58 FSA
1P59C	201 AP	25		25	0	0	P59 Interim ISA
1Q34C	226 PENELEC	20		20	0	0	Q34 ISA
1Q38C	226 PENELEC	12		12	0	0	Q38 ISA

1 Q43	205 AEP		534		534		Q43 Intertin ISA
1 Q55C	201 AP		20		20		Q55 FSA
1 Q57C	222 CE		50		50		Q57 FSA
1 Q63C	226 PENELEC		16		16		Q63 FSA
1 Q72C	226 PENELEC		12		12		Q72 FSA
1 U2-059C	228 JCP&L		0.8		0.8		U2-59 ISA
1 S05C	205 AEP		40		40		S05 FSA
1 R52A_C	209 DAY		20		20		R52 FSA
1 S41_69	228 PL	12.5		-12.5			S41 Suspended ISA
1 S45C	209 DAY		20		20		S45 FSA
1 S51_1C	208 DAY		9.9		9.9		S51 FSA
1 S51_2C	208 DAY		9.9		9.9		S51 FSA
1 S60	231 PSEG		63		63		S60 FSA
1 S61	231 PSEG		20		20		S61 FSA
1 S64	227 METED		18		18		S64 FSA
1 S67	232 PSEG		101		101		S67 ISA
1 S70_1	201 AP		18.2		18.2		S70 FSA
1 S70_2	201 AP		18.2		18.2		S70 FSA
1 S71C	205 AEP		24		24		S71 FSA
1 S-073C	208 AEP		20		20		S73 FSA
1 S72C_1	205 AEP		30		30		S72 FSA
1 S-073C	205 AEP		20		20		S73 FSA
1 S72C_2	205 AEP		30		30		S72 FSA
1 S17#1	233 PEPCO		112.5		112.5		S17 FSA
1 S17#2	233 PEPCO		112.5		112.5		S17 FSA
1 S103	226 PENELEC		57		57		S103 FSA
1 S107 CT1	234 AEP		160		160		S107 FSA
1 S107 CT2	234 AEP		160		160		S107 FSA
1 S107 ST	234 AEP		260		260		S107 FSA
1 S121	234 AEP		63		63		S121 ISA
1 U4-014C_O	229 PL		3.8		3.8		U4-014 FSA
1 U4-030	222 CE		6		6		U4-030 FSA
1 U4-034C	205 AEP		5		5		U4-034 FSA
1 U4-035C	205 AEP		6		6		U4-035 FSA
1 U4-036C	231 PSEG		4.6		4.6		U4-036 FSA
1 U4-040C	227 METED		2		2		U4-040 FSA
1 U4-041C	227 METED		2		2		U4-041 FSA
1 U4-042C	227 METED		2		2		U4-042 FSA
1 U4-043C	227 METED		2		2		U4-043 FSA
1 U4-044C	227 METED		2		2		U4-044 FSA
1 U4-045C	226 PENELEC		2		2		U4-045 FSA
1 U4-046C	226 PENELEC		2		2		U4-046 FSA
1 V1-030 IC	231 PSEG		2		2		V1-030 FSA
1 V1-030 2C	231 PSEG		2.4		2.4		V1-030 FSA
1 V1-030 4C	231 PSEG		0.6		0.6		V1-030 FSA
1 V1-030 5C	231 PSEG		1.5		1.5		V1-030 FSA
1 V1-030 6C	231 PSEG		0.6		0.6		V1-030 FSA
1 V1-030 7C	231 PSEG		0.5		0.5		V1-030 FSA
1 V1-030 8C	231 PSEG		0.6		0.6		V1-030 FSA
1 V1-030 10	231 PSEG		2.9		2.9		V1-030 FSA
1 V1-030 12	231 PSEG		2.8		2.8		V1-030 FSA
1 T-39C	201 AP		3.6		3.6		T39 FSA

1T-41 1	231 PSEG	44.5	44.5	T41 cleared in 2012/13 RPM BRA
1T-41 2	231 PSEG	44.5	44.5	T41 cleared in 2012/13 RPM BRA
1T-41 3	231 PSEG	44.5	44.5	T41 cleared in 2012/13 RPM BRA
1T-41 4	231 PSEG	44.5	44.5	T41 cleared in 2012/13 RPM BRA
1T-42 O	231 PSEG	44	44	T42 FSA
1T-42 O	231 PSEG	44	44	T42 FSA
1T-43 1	231 PSEG	44.5	44.5	T43 FSA
1T-43 2	231 PSEG	44.5	44.5	T43 FSA
1T-43 3	231 PSEG	44.5	44.5	T43 FSA
1T-43 4	231 PSEG	44.5	44.5	T43 FSA
1T-45 1	231 PSEG	41	41	T45 FSA
1T-45 2	231 PSEG	41	41	T45 FSA
1T-45 3	231 PSEG	41	41	T45 FSA
1T-45 4	231 PSEG	41	41	T45 FSA
1T-45 5	231 PSEG	41	41	T45 FSA
1T-48C	209 DAY	10	10	T48 FSA
1T-54	234 AEP	6.6	6.6	T54 cleared in 2012/13 RPM BRA
1V-030 3C	231 PSEG	0.6	0.6	V1-030 FSA
1T55	234 AEP	15.3	2.9	T55 cleared in 2012/13 RPM BRA
1V-030 9C	231 PSEG	0.6	0.6	V1-030 FSA
1V-030 14	231 PSEG	2.1	2.1	V1-030 FSA
1T-59	234 AEP	12.9	12.9	T59 cleared in 2012/13 RPM BRA
1T-76	228 JCPL	27.3	27.3	T76 cleared in 2012/13 RPM BRA
1T-84C	234 AEP	35	35	T84 FSA
1T-84C	234 AEP	35	35	T84 FSA
1T-94	205 AEP	1035	1035	T94 FSA
1T-107	231 PSEG	312.5	312.5	T107 FSA
1T-107	231 PSEG	168.2	156.2	T107 FSA
1T-109	225 PJM 500	156.2	156.2	T108 FSA
1T-110	225 PJM 500	20	20	T110 FSA
1T-117C #	236 UGI	20	20	T110 FSA
1T-117C #	236 UGI	48	48	T117 FSA
1T-117E #	236 UGI	30	30	T117 FSA
1T-128C	205 AEP	22.7	22.7	T128 cleared in 2012/13 RPM BRA
1T-130C	205 AEP	60	60	T130 FSA
1T-131C	205 AEP	30	30	T131 FSA
1T-133	233 PEPCO	225	225	T132 FSA
1T-134	233 PEPCO	325	325	T134 FSA
1T-135	234 AEP	15	15	T135 FSA
1T-142C	205 AEP	80	60	T142 FSA
1T-146C	234 AEP	69.2	69.2	T146 FSA
1CE28CL12	222 CE	4	4	L12 CE28 FSA
1T-155	201 AP	6	6	T155 FSA
1T-156	201 AP	20	20	T156 FSA
1T-157C	201 AP	32	32	T157 FSA
1T-167	345 VAP	120	120	T167 FSA
1T-174	201 AP	185	185	T174 FSA
1T-174	201 AP	185	185	T174 FSA
1T-174	201 AP	185	185	T174 FSA
1T-174	201 AP	375	375	T174 FSA
1T-180	345 VAP	185	185	T180 FSA
1T-180	345 VAP	185	185	T180 FSA
1T-180	345 VAP	280	280	T180 FSA
1U1-10	225 PJM 500	18	18	U1-10 FSA
1U1-31 G	234 AEP	40	40	U1-031 FSA
1U1-31 G	234 AEP	40	40	U1-031 FSA

				45.5		45.5	
1	U1-56C	234	AEP				U1-056 FSA
1	U1-59C O	205	AEP		6.5		U1-059 FSA
1	U1-66	234	AEP		9		U1-066 FSA
1	U1-66	234	AEP		9		U1-066 FSA
1	U1-69	215	DLCO		30		U1-069 FSA
1	U1-75	201	AP		12		U1-075 FSA
1	U1-76	205	AEP		12		U1-076 FSA
1	U1-80	215	DLCO		35		U1-080 FSA
1	U1-90	209	DAY		12		U1-090 FSA
1	U2-031C	345	VAP		21.8		U2-031 FSA
1	U2-041C	205	AEP		19.5		U2-041 ISA
1	U2-045C	234	AEP		2.6		U2-045 FSA
1	U2-041C	205	AEP		19.5		U2-041 ISA
1	U2-068C	345	VAP		16.9		U2-068 FSA
1	U2-069C	229	PL		7.3		U2-069 FSA
1	U2-074	201	AP		300		U2-074 FSA
1	U2-074	201	AP		175		U2-074 FSA
1	U2-074	201	AP		175		U2-074 FSA
1	U2-085	229	PL	11.4		-11.4	U2-085 Withdrawn
1	N24 C	222	CE		2.2		N24 FSA
1	N25 C	222	CE		2.2		N25 FSA
1	N33 C 1	201	AP	12		-12	N33 Suspended
1	O21C	209	DAY	9.6		-9.6	O21 Withdrawn
1	O32C	226	PENELEC	20	10	-10	O52 ISA
1	U1-54 A	222	CE		33.6		U1-54 cleared in 2012/13 RPM BRA
1	U1-54 B	222	CE		12.1		U1-54 cleared in 2012/13 RPM BRA
1	P23C	231	PSEG	45.5		-45.5	P23 Withdrawn
1	P30	205	AEP	20		-20	P30 Suspended
1	P45C1	226	PENELEC	24		-24	P45 Withdrawn
1	P47C_2	226	PENELEC		20		P47 ISA
1	P54 GEN1	205	AEP	517.5		-517.5	P54 in service date postponed
1	P54_GEN2	205	AEP	517.5		-517.5	P54 in service date postponed
1	P80C	226	PENELEC		10.5		P80 ISA
1	Q08_OPT1	228	JCP&L	45		-45	Q08 Withdrawn
1	P24C	222	CE		4		P24 FSA
1	P25C	222	CE		4		P25 FSA
1	Q28C_A	229	PL	17		-17	Q28 Suspended
1	Q28C_B	229	PL	17		-17	Q28 Suspended
1	Q46	226	PENELEC		10		Q46 FSA
1	Q80GEN6	201	AP	750		-750	Q80 Withdrawn
1	R48C	205	AEP		9.6		R48 ISA
1	R52_1C	209	DAY		20		R52 FSA
1	R64C	205	AEP		30		R49 FSA
1	R52_2C	209	DAY		20		R52 FSA
1	R61C	205	AEP	70		-70	R61 Withdrawn
1	R57E	227	IMETED	2		-2	R57 ISA
1	R58	231	PSEG	55		-55	R58 Withdrawn
1	R60_1C	205	AEP		23.2		R60 FSA
1	R60_2C	205	AEP		23.2		R60 FSA
1	R60_3C	205	AEP		23.6		R60 FSA
1	R92C	226	PENELEC	14		-14	R92 no ISA/FSA
1	V2-002	226	PENELEC		2.7		V2-002 FSA
1	V2-003C_1	231	PSEG		0.9		V2-003 FSA
1	V2-009C_2	231	PSEG		1.9		V2-009 FSA
1	V2-009C_3	231	PSEG		2.4		V2-009 FSA
1	V2-009C_4	231	PSEG		1.4		V2-009 FSA
1	V2-010C	228	ICP&L		7.6		V2-010 FSA

1 V2-012C	231 PSEG		2.8	2.8	V2-012 FSA
1 V2-025C	231 PSEG		2.7	2.7	V2-025 FSA
1 V2-041C	234 AEP		1.5	1.5	V2-041 FSA
1 U3-032C	228 JCP&L		6.5	6.5	U3-032 FSA
5 1CHEST15	345 VAP	329	349	20	S80 ISA
6 1CHEST16	345 VAP	648	655	37	S79 ISA
1 SURREY 1	345 VAP	817.2	907.2	90	S113 & S114 ISA
1 N ANNA 1	345 VAP	924.3	1009.3	85	S108 & S112 ISA
2 1N ANNA2	345 VAP	908	993.7	55.7	S109 & S110 ISA
2 SURREY 2	345 VAP	820.1	910.1	90	S111 & S115 ISA
3 1MT STM3	345 VAP	506	550	44	S74 - S76 ISA
1 P08CT1	345 VAP	151		-151	P08 Withdrawn
1 P08CT2	345 VAP	151		-151	P08 Withdrawn
1 P08ST	345 VAP	273.8		-273.8	P08 Withdrawn
1 S8243	345 VAP	20	19	-1	S82 ISA
1 S83#4	345 VAP	20	19	-1	S83 ISA
1 S8445	345 VAP	20	19	-1	S84 ISA
1 S8546	345 VAP	20	19	-1	S85 ISA
1 S9945	345 VAP	20	19	-1	S99 Withdrawn
1 R19	345 VAP		340	-20	R19 ISA
1 R63	345 VAP		19	340	R63 ISA
1 R80ST	345 VAP	10	10	10	R80 ISA
1 R80CT1	345 VAP		25	25	R80 ISA
1 R80CT2	345 VAP		25	25	R80 ISA
1 S102	345 VAP		170	170	S102 ISA
1 S81	345 VAP		22	22	S81 ISA
1 T-49 9	225 PJM 500		9	9	T49 ISA
1 T-49 2	225 PJM 500		6	6	T49 ISA
1 T-49 3	225 PJM 500		6	6	T49 ISA
1 T-49 4	225 PJM 500		9	9	T49 ISA
1 T-49 6	225 PJM 500		6	6	T49 ISA
1 T-49 7	225 PJM 500		6	6	T49 ISA
1 T75	228 JCP&L		20	20	T75 ISA
1 U2-30C	201 AP		7.8	7.8	U2-300 ISA
1 U2-61C	201 AP		6.5	6.5	U2-301 ISA
1A 05BEVERL	205 AEP	175	181	6	S38 ISA
1B 05BEVERL	205 AEP	175	181	6	S38 ISA
1S 05BEVERL	205 AEP	250	258	8	S38 ISA
P FISK-BP	222 CE		97.3	97.3	Units missing from model
P FISK-RP	222 CE		98.9	99.9	Units missing from model
W3 CAYUGA1U	222 CE		30	30	Capacity of O51 (30 of 60 MW)
W4 CAYUGA2U	222 CE		30	30	Capacity of O51 (30 of 60 MW)
W2 CHESC2U	222 CE	48	0	-48	Wind Energy
A 1OMF_A	345 VAP	40	49	9	S50 ISA
B 1OMF_B	345 VAP	40	49	9	S50 ISA
H1 1MT STM1	345 VAP	262.5	279.5	17	S74 - S76 ISA
L1 1MT STM1	345 VAP	263.5	280.5	17	S74 - S76 ISA
H2 1MT STM2	345 VAP	263.5	279.5	16	S74 - S76 ISA
L2 1MT STM2	345 VAP	264.5	280.5	16	S74 - S76 ISA

ATTACHMENT B

Thermal Violations of NERC Reliability Standards Identified in the December 2009 Sensitivity Study

Scenario 1 Thermal

	Electrical Occurrence	Electrical Result	PJM Reliability Test	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
1	Outage of Conemaugh - Keystone 500 kV	Keystone - Jacks Min 500 kV exceeds its emergency rating and overloads (2015)	MAAC Load Deliverability	99.68	101.02	102.39	103.74	104.86	106.04	107.04	108.25	109.51	110.61	111.89
2	Outage of Kammer - South Canton 765 kV	Kammer - West Bellaire 345 kV exceeds its emergency rating and overloads (2015)	MAAC Load Deliverability	98.89	100.34	101.81	103.46	104.82	106.21	107.73	109.26	110.81	112.42	114.01
3	Outage of Conemaugh - Junia 500 kV	Junia - Junia 500 kV exceeds its emergency rating and overloads (2015)	MAAC Load Deliverability	99.16	100.16	101.18	102.17	102.95	103.75	104.40	105.23	106.10	106.82	107.68
4	Outage of Junia - Keystone 500 kV	Keystone - Junia 500 kV exceeds its emergency rating and overloads (2015)	MAAC Load Deliverability	99.14	100.14	101.16	102.16	102.94	103.75	104.40	105.23	106.10	106.84	107.70
5	Outage of Keystone - Jacks Mtn 500 kV	Keystone - Conemaugh 500 kV exceeds its emergency rating and overloads (2015)	MAAC Load Deliverability	98.57	100.09	101.63	103.18	104.47	105.85	107.04	108.44	109.90	111.20	112.70
6	Outage of Bedington - Black Oak 500 kV	Mt Storm - T157 - TAP 500 kV exceeds its emergency rating and overloads (2016)	MAAC Load Deliverability	97.37	98.96	100.53	102.27	103.87	105.72	107.55	109.36	111.22	113.08	115.10
7	Outage of Bedington - Black Oak 500 kV	T157 - TAP - Dobs 500 kV exceeds its emergency rating and overloads (2017)	MAAC Load Deliverability	96.77	98.38	99.96	101.71	103.32	105.19	107.04	108.86	110.73	112.60	114.63
8	Outage of Conemaugh - Jacks Mtn 500 kV	Keystone - Jacks Min 500 kV exceeds its emergency rating and overloads (2018)	MAAC Load Deliverability	96.90	97.90	98.91	99.90	100.69	101.50	102.16	103.00	103.87	104.61	105.48
9	Outage of Black Oak - Hatfield T157 - TAP - Dobs 500 kV	T157 - TAP - Dobs 500 kV exceeds its emergency rating and overloads (2018)	MAAC Load Deliverability	94.38	95.90	97.39	99.04	100.56	102.31	104.06	105.77	107.52	109.28	111.18
10	Outage of Black Oak - Hatfield 500 kV	Mt Storm - T157 - TAP 500 kV exceeds its emergency rating and overloads (2019)	MAAC Load Deliverability	93.31	94.81	96.29	97.93	99.43	101.17	102.90	104.60	106.35	108.09	109.98
11	Outage of Loudoun - Meadow Brook 500 kV	T157 - TAP - Dobs 500 kV exceeds its emergency rating and overloads (2019)	MAAC Load Deliverability	93.08	94.61	96.12	97.79	99.33	101.11	102.86	104.59	106.37	108.15	110.08
12	Outage of Bath County - Valley 500 kV	Lexington - Dooms 500 kV exceeds its emergency rating and overloads (2019)	MAAC Load Deliverability	91.48	93.08	94.77	96.67	98.42	100.49	102.54	104.62	106.80	109.00	111.35
13	Outage of Loudoun - Meadow Brook 500 kV	Mt Storm - T157 - TAP 500 kV exceeds its emergency rating and overloads (2019)	MAAC Load Deliverability	92.05	93.57	95.06	96.72	98.25	100.01	101.75	103.46	105.23	107.00	108.92
14	Outage of Ft Martin-Harrison-Kammer 500 kV	Harrison - Prunytown 500 kV exceeds its emergency rating and overloads (2021)	MAAC Load Deliverability	86.87	88.58	90.40	92.53	94.48	96.84	99.22	101.70	104.36	107.08	110.00
15	Outage of Mt Storm - 502 Junction 500 kV	Prunytown - My Storm 500 kV exceeds its emergency rating and overloads (2022)	VAP Load Deliverability	83.20	84.92	86.82	89.02	91.12	93.66	96.11	98.66	101.44	104.26	107.33

Thermal Violations of NERC Reliability Standards Identified in the December 2009 Sensitivity Study

Scenario 1 Thermal

Thermal Violations of NERC Reliability Standards Identified in December 2009 Study

Scenario 2 Thermal

	Electrical Occurrence	Electrical Result	PJM Reliability Test	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
1	Outage of Kammer - South Canton 765 kV	Kammer - West Bellaire 345 kV exceeds its emergency rating and overloads (2015)	MAAC Load Deliverability	99.28	100.35	101.35	102.37	103.43	104.50	105.73	106.53	107.78	108.94	110.20
2	Outage of Conemaugh - Keystone 500 kV	Keystone - Jacks Mtn 500 kV exceeds its emergency rating and overloads (2015)	MAAC Load Deliverability	99.34	100.30	101.41	102.05	102.92	103.64	104.45	104.92	106.09	106.62	107.58
3	Outage of Bedington - Black Oak 500 kV	Mt Strom - T157_TAP 500 kV exceeds its emergency rating and overloads (2015)	MAAC Load Deliverability	98.54	100.12	101.41	102.90	104.41	106.04	107.81	109.17	110.88	112.58	114.34
4	Outage of Bedington - Black Oak 500 kV	T157_TAP - Doubs 500 kV exceeds its emergency rating and overheads (2016)	MAAC Load Deliverability	97.89	99.49	100.79	102.29	103.81	105.46	107.25	108.62	110.34	112.05	113.82
5	Outage of Conemaugh - Juniala 500 kV	Jacks Min - Juniala 500 kV exceeds its emergency rating and overloads (2016)	MAAC Load Deliverability	99.06	99.72	100.55	100.91	101.47	101.90	102.38	102.60	103.43	103.64	104.24
6	Outage of Juniala - Keystone 500 kV	Jacks Min - Juniala 500 kV exceeds its emergency rating and overloads (2016)	MAAC Load Deliverability	99.03	99.69	100.52	100.89	101.45	101.89	102.37	102.59	103.42	103.63	104.24
7	Outage of Keystone - Jacks Mtn 500 kV	Keystone - Conemaugh 500 kV exceeds its emergency rating and overheads (2016)	MAAC Load Deliverability	98.09	99.21	100.46	101.25	102.27	103.16	104.13	104.74	106.09	106.79	107.93
8	Outage of Black Oak - Hatfield 500 kV	T157_TAP - Doubs 500 kV exceeds its emergency rating and overheads (2017)	MAAC Load Deliverability	96.41	97.91	99.13	100.53	101.95	103.48	105.16	106.49	108.04	109.63	111.27
9	Outage of Bath County - Valley 500 kV	Lexington - Dooms 500 kV exceeds its emergency rating and overloads (2016)	MAAC Load Deliverability	94.96	96.65	98.06	99.80	101.58	103.49	105.58	107.33	109.40	111.56	113.71
10	Outage of Black Oak - Hatfield 500 kV	Mt Strom - T157_TAP 500 kV exceeds its emergency rating and overloads (2016)	MAAC Load Deliverability	95.31	96.79	98.00	99.38	100.79	102.31	103.97	105.23	106.83	108.41	110.04
11	Outage of Loudoun - Meadow Brook 500 kV	T157_TAP - Doubs 500 kV exceeds its emergency rating and overloads (2018)	MAAC Load Deliverability	95.06	96.58	97.82	99.25	100.69	102.25	103.94	105.24	106.86	108.50	110.18
12	Outage of Loudoun - Meadow Brook 500 kV	Mt Strom - T157_TAP 500 kV exceeds its emergency rating and overloads (2019)	MAAC Load Deliverability	94.02	95.52	96.75	98.16	99.80	101.14	102.82	104.11	105.73	107.34	109.01
13	Outage of Mt Strom - 502 Junction 500 kV	Prunytown - Mt Strom 500 kV exceeds its emergency rating and overloads (2019)	MAAC Load Deliverability	89.86	91.93	93.63	95.96	98.32	100.82	103.57	106.07	108.89	112.02	115.03

Thermal Violations of NERC Reliability Standards Identified in December 2009 Study

Scenario 2 Thermal

14	Outage of Ft Martin - Harrison - Kammer 500 kV	Harrison - Pruntytown 500 kV exceeds its emergency rating and overloads (2019)	MAAC Load Deliverability	91.01	92.69	94.17	96.07	98.06	100.15	102.50	104.54	107.07	109.71	112.35
15	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2020)	VAP Load Deliverability	86.52	88.59	90.29	92.62	94.98	97.48	100.23	102.73	105.55	108.68	111.69
16	Outage of Conemaugh - Jacks Mtn 500 kV	Keystone - Jacks Mtn 500 kV exceeds its emergency rating and overloads (2020)	MAAC Load Deliverability	96.77	97.43	98.26	98.64	99.21	99.66	100.15	100.39	101.22	101.46	102.08
17	Outage of Mt Storm - Meadow Brook 500 kV	Greenland Gap - Meadow Brook 500 kV exceeds its emergency rating and overloads	MAAC Load Deliverability	89.89	91.66	93.05	94.87	96.69	98.65	100.80	102.63	104.70	106.96	108.75
18	Outage of Ft Martin - Harrison - Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2021)	MAAC Load Deliverability	86.52	88.54	90.17	92.43	94.70	97.11	99.76	102.15	104.84	107.84	110.71
19	Outage of Mt Storm - Meadow Brook 500 kV	Mt Storm - Greenland Gap 500 kV exceeds its emergency rating and overloads (2021)	MAAC Load Deliverability	88.38	90.12	91.49	93.30	95.10	97.04	99.16	100.98	103.04	105.28	107.45
20	Outage of Ft Martin - Harrison - Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2021)	VAP	85.19	87.21	88.84	91.10	93.37	95.78	98.43	100.82	103.51	106.51	109.38
21	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	SWMAAC Load Deliverability	82.13	84.20	85.90	88.23	90.59	93.09	95.84	98.34	101.16	104.29	107.30
22	Outage of Ft Martin - Harrison - Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	SWMAAC Load Deliverability	80.53	82.55	84.18	86.44	88.71	91.12	93.77	96.16	98.85	101.85	104.72
23	Outage of Bath County - Valley 500 kV	Lexington - Dooms 500 kV exceeds its emergency rating and overloads (2023)	VAP Load Deliverability	85.20	86.89	88.30	90.04	91.82	93.73	95.82	97.57	99.64	101.80	103.95
24	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	PJM GD	78.89	80.96	82.65	84.99	87.35	89.85	92.60	95.09	97.91	101.05	104.06
25	Outage of Bedington - Black Oak 500 kV	T157 - TAP - Doubts 500 kV exceeds its emergency rating and overloads (2023)	SWMAAC Load Deliverability	86.71	88.31	89.61	91.11	92.63	94.28	96.07	97.44	99.16	100.87	102.64
26	Outage of Ft Martin - Harrison - Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	PJM GD	78.71	80.73	82.36	84.62	86.89	89.29	91.94	94.34	97.03	100.03	102.90
27	Outage of Bedington - Black Oak 500 kV	Mt Storm - T157 - TAP 500 kV exceeds its emergency rating and overloads (2024)	SWMAAC Load Deliverability	85.58	87.16	88.45	89.94	91.45	93.08	94.85	96.21	97.92	99.62	101.38
28	Outage of Dooms - Lexington 500 kV	Bath County - Valley 500 kV exceeds its emergency rating and overloads (2024)	MAAC Load Deliverability	84.87	86.38	87.63	89.15	90.69	92.36	94.19	95.69	97.49	99.34	101.19
29	Outage of Mt Storm - Meadow Brook 500 kV	Greenland Gap - Meadow Brook 500 kV exceeds its emergency rating and overloads	SWMAAC Load Deliverability	81.46	83.23	84.62	86.44	88.26	90.22	92.37	94.20	96.27	98.53	100.72
30	Outage of Bedington - Black Oak 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2024)	MAAC Load Deliverability	79.65	81.41	82.83	84.77	86.73	88.80	91.08	93.12	95.43	97.98	100.44

Thermal Violations of NERC Reliability Standards Identified in December 2009 Study

Scenario 3 Thermal

	Electrical Occurrence	Electrical Result	PJM Reliability Test	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
1	Outage of Bedington - Black Oak 500 kV	T157 - TAP - Doubs 500 kV exceeds its emergency rating and overloads (2021)	MAAC Load Deliverability	86.17	89.78	91.36	93.11	94.72	96.59	98.44	100.26	102.13	104.00	106.03
2	Outage of Bedington - Black Oak 500 kV	Mt Storm - T157 - TAP 500 kV exceeds its emergency rating and overloads (2022)	MAAC Load Deliverability	87.16	88.75	90.32	92.06	93.66	95.51	97.34	99.15	101.01	102.87	104.89
3	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	VAP Load Deliverability	80.36	82.08	83.98	86.18	88.28	90.82	93.27	95.82	98.60	101.42	104.49
4	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	MAAC Load Deliverability	79.01	80.73	82.63	84.83	86.93	89.47	91.92	94.47	97.25	100.07	103.14
5	Outage of Ft Martin - Harrison - Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2024)	Deliverability	79.41	81.06	82.87	84.96	86.97	89.39	91.72	94.14	96.78	99.44	102.35
6	Outage of Bath County - Valley 500 kV	Lexington - Dooms 500 kV exceeds its emergency rating and overloads (2024)	MAAC Load Deliverability	82.35	83.95	85.64	87.54	89.29	91.36	93.41	95.49	97.67	99.87	102.22
7	Outage of Bath County - Valley 500 kV	Lexington - Dooms 500 kV exceeds its emergency rating and overloads (2024)	VAP Load Deliverability	81.41	83.01	84.70	86.60	88.35	90.42	92.47	94.55	96.73	98.93	101.28
8	Outage of Black Oak - Hatfield 500 kV	T157 - TAP - Doubs 500 kV exceeds its emergency rating and overloads (2024)	MAAC Load Deliverability	83.90	85.42	86.91	88.56	90.08	91.83	93.58	95.29	97.04	98.80	100.70
9	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2024)	SWAAC Load Deliverability	76.46	78.18	80.08	82.28	84.38	86.92	89.37	91.92	94.70	97.52	100.59
10	Outage of Ft Martin - Harrison - Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2024)	MAAC Load Deliverability	77.09	78.74	80.55	82.64	84.65	87.07	89.40	91.82	94.46	97.12	100.03

Thermal Violations of NERC Reliability Standards Identified in December 2009 Study

Scenario 4 Thermal

	Electrical Occurrence	Electrical Result	PJM Reliability Test	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
1	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2021)	VAP	85.11	87.18	88.88	91.21	93.57	95.07	98.82	101.32	104.14	107.27	110.28
2	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2021)	MAAC Load Deliverability	84.63	86.70	88.40	90.73	93.09	95.59	98.34	100.84	103.66	106.79	109.80
3	Outage of Bedington - Black Oak 500 kV	T157 - TAP - Doubs 500 kV exceeds its emergency rating and overloads (2021)	MAAC Load Deliverability	89.88	91.48	92.78	94.28	95.80	97.45	99.24	100.61	102.33	104.04	105.81
4	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2021)	SWMAC Load Deliverability	84.34	86.41	88.11	90.44	92.80	95.30	98.05	100.55	103.37	106.50	109.51
5	Outage of Ft Martin - Harrison Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2022)	VAP Load Deliverability	83.91	85.93	87.56	89.82	92.09	94.50	97.15	99.54	102.23	105.23	108.10
6	Outage of Ft Martin - Harrison Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2022)	SWMAC Load Deliverability	83.10	85.12	86.75	89.01	91.28	93.69	96.34	98.73	101.42	104.42	107.29
7	Outage of Bedington - Black Oak 500 kV	Mt Storm - T157 - TAP 500 kV exceeds its emergency rating and overloads (2022)	MAAC Load Deliverability	88.86	90.43	91.72	93.21	94.72	96.35	98.12	99.48	101.19	102.89	104.65
8	Outage of Ft Martin - Harrison Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2022)	MAAC Load Deliverability	82.51	84.53	86.16	88.42	90.69	93.10	95.75	98.14	100.83	103.83	106.70
9	Outage of Bath County - Valley 500 kV	Lexington - Dooms 500 kV exceeds its emergency rating and overloads (2023)	MAAC Load Deliverability	84.91	86.60	88.01	89.75	91.53	93.44	95.53	97.28	99.35	101.51	103.66
10	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	PJM GD	79.20	81.28	82.97	85.31	87.67	90.16	92.92	95.41	98.23	101.37	104.38
11	Outage of Bath County - Valley 500 kV	Lexington - Dooms 500 kV exceeds its emergency rating and overloads (2023)	VAP Load Deliverability	83.74	85.43	86.84	88.58	90.36	92.27	94.36	96.11	98.18	100.34	102.49
12	Outage of Ft Martin - Harrison Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	PJM GD	78.95	80.97	82.60	84.86	87.13	89.54	92.19	94.58	97.27	100.27	103.14
13	Outage of Mt Storm - Meadow Brook 500 kV	Greenland Gap - Meadow Brook 500 kV exceeds its emergency rating and overloads	MAAC Load Deliverability	82.83	84.70	86.09	87.91	89.73	91.69	93.84	95.67	97.74	100.00	102.19
14	Outage of Ft Martin - Harrison Kammer 500 kV	Harrison - Pruntytown 500 kV exceeds its emergency rating and overloads (2024)	MAAC Load Deliverability	79.86	81.54	83.02	84.92	86.90	89.00	91.35	93.39	95.92	98.56	101.20
15	Outage of Mt Storm - Meadow Brook 500 kV	Mt Storm - Greenland Gap 500 kV exceeds its emergency rating and overloads (2024)	MAAC Load Deliverability	81.50	83.24	84.61	86.42	88.22	90.16	92.28	94.10	96.18	98.40	100.57
16	Outage of Mt Storm - Meadow Brook 500 kV	Greenland Gap - Meadow Brook 500 kV exceeds its emergency rating and overloads	SWMAC Load Deliverability	80.84	82.61	84.00	85.82	87.64	89.60	91.75	93.58	95.65	97.91	100.10

Thermal Violations of NERC Reliability Standards Identified in December 2009 Study

Scenarios 5 and 6 Thermal

		Electrical Occurrence	Electrical Result	PJM Reliability Test										
				2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
1	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2021)	VAP Load Deliverability	84.37	86.71	88.63	91.19	93.78	96.50	99.26	101.74	104.56	107.69	110.70
2	Outage of Ft Martin - Harrison - Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2022)	VAP Load Deliverability	83.23	86.45	87.26	89.69	92.14	94.72	97.36	99.76	102.44	105.44	108.31
3	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2022)	MAC Load Deliverability	81.23	83.57	85.49	88.05	90.64	93.36	96.11	98.60	101.42	104.55	107.56
4	Outage of Bath County - Valley 500 kV	Lexington - Deoms 500 kV exceeds its emergency rating and overloads (2022)	VAP Load Deliverability	84.01	86.27	88.15	90.35	92.60	94.98	97.03	98.82	100.90	103.06	105.20
5	Outage of Ft Martin - Harrison - Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	MAC Load Deliverability	79.71	81.93	83.74	86.17	88.62	91.20	93.84	96.24	98.92	101.92	104.79
6	Outage of Mt Storm - 502 Junction 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	PJM GD	79.20	81.28	82.97	85.31	87.67	90.16	92.92	95.41	98.23	101.37	104.38
7	Outage of Bedington - Black Oak 500 kV	T157_TAP - Doubs 500 kV exceeds its emergency rating and overloads (2023)	MAC Load Deliverability	83.25	85.52	87.37	89.43	91.51	93.70	95.49	96.86	98.58	100.29	102.06
8	Outage of Ft Martin - Harrison - Kammer 500 kV	Pruntytown - Mt Storm 500 kV exceeds its emergency rating and overloads (2023)	PJM GD	78.95	80.97	82.60	84.86	87.13	89.54	92.19	94.58	97.27	100.27	103.14
9	Outage of Bedington - Black Oak 500 kV	Mt Storm - T167_TAP 500 kV exceeds its emergency rating and overloads (2024)	MAC Load Deliverability	82.25	84.49	86.34	88.38	90.44	92.62	94.39	95.76	97.46	99.17	100.92
10	Outage of Bath County - Valley 500 kV	Lexington - Deoms 500 kV exceeds its emergency rating and overloads (2024)	MAC Load Deliverability	79.04	81.30	83.18	85.38	87.63	90.01	92.11	93.85	95.93	98.09	100.23