

Legalelectric, Inc.

Carol Overland Attorney at Law, MN #254617

Energy Consultant—Transmission, Power Plants, Nuclear Waste
overland@legalelectric.org

P. O. Box 176
Red Wing, Minnesota 55066
612.227.8638

P.O. Box 69
Port Penn, Delaware 19731
302.834.3466

January 15, 2010

Hearing Examiner Ruth Price
Delaware Public Service Commission
861 Silver Lake Boulevard
Cannon Building, Suite 100
Dover, DE 19904

RE: Delmarva Power Integrated Resource Plan
Docket No.: 10-02

Dear Hearing Examiner Price, et al.:

Thank you for the opportunity to make this comment. I am writing this as an individual, a member of the public, and a half-time resident of the state of Delaware at the above address. I am not making this comment in the course of representation of any party. For the record, I am a utility regulatory attorney and energy consultant, licensed in the state of Minnesota and also currently admitted pro hac vice representing Stop the Lines! on New Jersey's Susquehanna-Roseland transmission project. In my work, I've come across many documents and information that should be a part of this IRP docket, and as an interested member of the public and resident, I am sending this to assure that it gets in the record.

I make the above statement because at the public hearing on December 3, 2008, IRP Docket 07-20, my rights to comment were improperly restricted. This comment is in writing so that my status as a half-time Delaware resident is clear and that the Comment will be received in its entirety.

The issues I raised at the December 3, 2008, IRP Docket 07-20, remain issues today.

Necessary documents to include in the IRP

PJM 2010 Load Forecast (attached)

PJM 3Q State of the Market – too large to attach. It can be found online at:

http://www.monitoringanalytics.com/reports/PJM_State_of_the_Market/2009.shtml

North America Electric Council 2009 Long Term Reliability Assessment:

<http://www.nerc.com/page.php?cid=4|61>

TABLE F-1**PJM RTO HISTORICAL PEAKS
(MW)****SUMMER**

| YEAR | NORMALIZED BASE | NORMALIZED COOLING | NORMALIZED TOTAL | UNRESTRICTED PEAK | PEAK DATE/TIME |
|-------------|------------------------|---------------------------|-------------------------|--------------------------|----------------------------|
| 1998 | 72,950 | 38,170 | 111,120 | 114,996 | Tuesday 07/21/1998 17:00 |
| 1999 | 73,990 | 42,980 | 116,970 | 121,655 | Tuesday 07/06/1999 17:00 |
| 2000 | 76,300 | 40,080 | 116,380 | 114,178 | Wednesday 08/09/2000 17:00 |
| 2001 | 75,990 | 45,080 | 121,070 | 131,116 | Thursday 08/09/2001 16:00 |
| 2002 | 77,140 | 48,120 | 125,260 | 130,360 | Thursday 08/01/2002 17:00 |
| 2003 | 77,650 | 46,700 | 124,350 | 126,332 | Thursday 08/21/2003 17:00 |
| 2004 | | | 130,645 | 120,235 | Wednesday 06/09/2004 17:00 |
| 2005 | | | 133,550 | 134,219 | Tuesday 07/26/2005 16:00 |
| 2006 | | | 134,905 | 145,951 | Wednesday 08/02/2006 17:00 |
| 2007 | | | 136,095 | 140,948 | Wednesday 08/08/2007 16:00 |
| 2008 | | | 136,315 | 130,792 | Monday 06/09/2008 17:00 |
| 2009 | | | 133,780 | 126,944 | Monday 08/10/2009 17:00 |

WINTER

| YEAR | NORMALIZED BASE | NORMALIZED HEATING | NORMALIZED TOTAL | UNRESTRICTED PEAK | PEAK DATE/TIME |
|-------------|------------------------|---------------------------|-------------------------|--------------------------|----------------------------|
| 97/98 | | | | 88,970 | Wednesday 01/14/1998 19:00 |
| 98/99 | | | | 99,982 | Tuesday 01/05/1999 19:00 |
| 99/00 | | | | 102,359 | Thursday 01/27/2000 20:00 |
| 00/01 | | | | 101,717 | Wednesday 12/20/2000 19:00 |
| 01/02 | | | | 97,294 | Thursday 01/03/2002 19:00 |
| 02/03 | | | | 112,755 | Thursday 01/23/2003 19:00 |
| 03/04 | | | 108,110 | 106,760 | Monday 01/26/2004 19:00 |
| 04/05 | | | 110,250 | 114,061 | Monday 12/20/2004 19:00 |
| 05/06 | | | 111,745 | 110,415 | Wednesday 12/14/2005 19:00 |
| 06/07 | | | 112,455 | 118,800 | Monday 02/05/2007 20:00 |
| 07/08 | | | 113,185 | 111,724 | Thursday 01/03/2008 19:00 |
| 08/09 | | | 113,150 | 117,169 | Friday 01/16/2009 19:00 |

Notes: Normalized values for 1998 - 2003 are calculated by PJM staff using the bottom-up coincident peak weather-normalization methodology.


Normalized values for 2004 - 2009 are calculated by PJM staff using a methodology consistent with the PJM Load Forecast Model.

All times are shown in hour ending Eastern Prevailing Time.

All historic peak values reflect the membership of the PJM RTO as of December 31, 2009.

Peak demand has significantly decreased since 2006

The most important issue is that the PJM and DPL peak demand history must be part of the IRP. I've reviewed the documents on-line at the Delmarva site (why isn't everything on the DPS IRP site, such as presentation and notes from workshops?) and I don't see any mention of decreased demand. The PJM 2010 Load Forecast report has just been released and it clearly shows that demand is down in PJM and DPL and it has been since a peak in 2006. See chart preceding. This also applies to DPL:



PJM 2010 Load Forecast Report. The system infrastructure is built, or not built, based on peak demand. This historic information must be part of the IRP.

Energy use is down since a peak in 2005

It's also important to look at energy use. Decreased demand is also demonstrated in the DPL SEC filings, the 2009 figures should be filled in as soon as the 10-K is available:

DELMARVA POWER & LIGHT

2008 SEC 10-K <http://www.secinfo.com/d12wBc.s1f.htm> ; 2006 SEC 10-K <http://www.secinfo.com/d12wBc.uh.htm>

| Delmarva | 2009 | 2008 | 2007 | 2006 | 2005 |
|-------------------------|------|--------|--------|--------|--------|
| Regulated T&D Sales GWh | | | | | |
| Residential | | 5,038 | 5,333 | 5,170 | 5,578 |
| Commercial | | 5,275 | 5,471 | 5,357 | 5,410 |
| Industrial | | 2,652 | 2,825 | 2,899 | 3,063 |
| Other | | 50 | 51 | 51 | 50 |
| TOTAL: | | 13,015 | 13,680 | 13,477 | 14,101 |
| | | | | | |

| Default T&D Sales GWh | | 2008 | 2007 | 2006 | 2005 |
|--------------------------|--|--------------|--------------|--------------|---------------|
| Residential | | 4,923 | 5,257 | 5,154 | 5,589 |
| Commercial | | 2,263 | 2,291 | 3,472 | 4,822 |
| Industrial | | 357 | 551 | 983 | 1,720 |
| Other | | 43 | 45 | 49 | 51 |
| TOTAL: | | 7,586 | 8,144 | 9,658 | 12,182 |

In 2008, DPL delivered a total of 13,015,000 megawatt hours of electricity to its customers, of which 39% was delivered to residential customers, 41% to commercial customers and 20% to industrial customers. In 2007, DPL delivered a total of 13,680,000 megawatt hours of electricity, of which 39% was delivered to residential customers, 40% to commercial customers and 21% to industrial customers.

From the Monitoring Analytics' PJM 3Q State of the Market, PJM peak load for 3rd Quarter 2009 was down 2,676 MW, 2.1%, from 3rd Quarter 2008; real-time load was down 4.5%, day ahead load dropped 8%, and prices dropped 48% to \$37.42/MWh. Monitoring Analytics PJM 3Q Quarterly Report, November, 2009, p. 5, 7. That drop is also reflected in the just released 2010 PJM Load Forecast, which shows that the historic peak demand was in 2006, base year for the 2007 RTEP and the basis for the claim of need for the Susquehanna-Roseland, PATH and Mid-Atlantic Power Pathway:

The full chart for historical peak demand (p. 70) was several pages above – considering the PJM historical peak demand, the PJM 2010 forecast (p. 24) is inexplicable, and is contradicted by the 2009 NERC Reliability Assessment -- NERC paints a very different picture for this timeframe:


RFC – A five percent drop in peak demand compared to last-year's forecast for 2009. In 2011 and 2012, the annual growth rates increase and then decline through 2018.

2009 NERC Reliability Assessment, p. 14. It is in DPL's interest to overstate demand, and to build infrastructure for overstated demand, because a more robust system can carry increased market transactions. This is in DPL's interest, but it is not in the public or ratepayer interest to build and pay for infrastructure that is not needed and only benefits DPL's corporate bottom line.

Mid-Atlantic Power Pathway (MAPP) is not needed

The Mid-Atlantic Power Pathway is a 500kV transmission project that, together with PATH and Susquehanna-Roseland, grew out of the 2007 RTEP. The 2007 RTEP was based on the historic demand peak of 2006, a demand that has not been sustained, thankfully. Based on decreased demand, the MAPP leg from Indian River to Salem was withdrawn and the rest of MAPP was delayed. Now PEPCO and PJM have asked for a "procedural suspension," based on "PATH withdrawal," but it is much more than that. As time goes on, the "need" case for these lines has fallen apart – there is no need. The next RTEP must include updated historical demand and forecast information, which will show very clearly MAPP is not needed, as it does for PATH and Susquehanna-Roseland, and that they will not be needed in the forecast range nor will they be needed at any time in the foreseeable future.

MAPP is the NE part of Line 4 of Project Mountaineer – transmission for coal. This transmission would also enable the Delaware Electric Co-op's announced plan to build a new coal plan with Dominion. As a facilitator for new and existing coal generation and other non-renewable central station power, it is outmoded and against public policy.



Cost apportionment for PJM's "backbone" transmission projects has been rejected by the 7th Circuit, which objected to foisting the costs on those who would receive zero benefit. The 7th Circuit decision is attached.

This is a time when we can plan our energy future

The heat is off, demand has dropped and there is no need for new fossil generation or transmission. What the IRP can and should include is Delmarva Power's plan to increase renewable generation that is dispatchable, such as the PSC ordered wind project with natural gas back up.


Respectfully submitted,

Carol A. Overland

Carol A. Overland, Energy Consultant

cc: Service List:

PJM Load Forecast Report January 2010



Prepared by PJM Resource Adequacy Planning Department

TABLE OF CONTENTS

| | TABLE NUMBER | CHART PAGE | TABLE PAGE |
|---|-----------------|---------------|---------------|
| EXECUTIVE SUMMARY | | | 1 |
| FORECAST COMPARISON: | | | |
| Each Zone and PJM RTO – Comparison to Prior Summer Peak Forecasts | A-1 | | 25 |
| Each Zone and PJM RTO – Comparison to Prior Winter Peak Forecasts | A-2 | | 27 |
| PEAK LOAD FORECAST AND ANNUAL GROWTH RATES: | | | |
| Seasonal Unrestricted PJM Control Area Peak Forecasts of each NERC Region | | | 29 |
| Summer Peak Forecasts and Growth Rates of each Zone, Geographic Region and PJM RTO | B-1 | 3, 5-24 | 33 |
| Winter Peak Forecasts and Growth Rates of each Zone, Geographic Region and PJM RTO | B-2 | 4, 5-24 | 37 |
| Spring Peak Forecasts of each Zone, Geographic Region and PJM RTO | B-3 | | 41 |
| Fall Peak Forecasts of each Zone, Geographic Region and PJM RTO | B-4 | | 43 |
| Monthly Peak Forecasts of each Zone, Geographic Region and PJM RTO | B-5 | | 45 |
| Monthly Peak Forecasts of FE/GPU and PLGrp | B-6 | | 47 |
| Load Management Placed Under PJM Coordination by Zone, used in Planning | B-7 | | 48 |
| Energy Efficiency Programs used in Planning | B-8 | | 50 |
| Adjustments to Summer Peak Forecasts | B-9 | | 51 |
| Summer Coincident Peak Load Forecasts of each Zone, Locational Deliverability Area and PJM RTO (RPM Forecast) | B-10 | | 53 |

| | TABLE NUMBER | CHART PAGE | TABLE PAGE |
|--|-------------------------|-----------------------|-----------------------|
| LOCATIONAL DELIVERABILITY AREA | | | |
| SEASONAL PEAKS: | | | |
| Central Mid-Atlantic: BGE, MetEd, PEPCO, PL and UGI Seasonal Peaks | C-1 | | 54 |
| Western Mid-Atlantic: MetEd, PENLC, PL and UGI Seasonal Peaks | C-2 | | 55 |
| Eastern Mid-Atlantic: AE, DPL, JCPL, PECO, PS and RECO Seasonal Peaks | C-3 | | 56 |
| Southern Mid-Atlantic: BGE and PEPCO Seasonal Peaks | C-4 | | 57 |
| Mid-Atlantic and APS: AE, APS, BGE, DPL, JCPL, MetEd, PECO, PNLC, PEPCO, PS, RECO and UGI Seasonal Peaks | C-5 | | 58 |
| EXTREME WEATHER (90/10) PEAK LOAD FORECASTS: | | | |
| Summer 90/10 Peak Forecasts of each Zone, Geographic Region and PJM RTO | D-1 | | 59 |
| Winter 90/10 Peak Forecasts of each Zone, Geographic Region and PJM RTO | D-2 | | 61 |
| NET ENERGY FORECAST AND ANNUAL GROWTH RATES: | | | |
| Annual Net Energy Forecasts of each Zone, Geographic Region and PJM RTO | E-1 | | 63 |
| Monthly Net Energy Forecasts of each Zone, Geographic Region and PJM RTO | E-2 | | 67 |
| Monthly Net Energy Forecasts of FE/GPU and PLGrp | E-3 | | 69 |
| PJM HISTORICAL DATA: | | | |
| Historical RTO Summer and Winter Peaks | F-1 | | 70 |
| Historical RTO Net Energy | F-2 | | 71 |
| ECONOMIC GROWTH: | | | |
| Average Economic Growth of each Zone and RTO | G-1 | | 72 |

TERMS AND ABBREVIATIONS USED IN THIS REPORT

| | |
|-----------------------------|--|
| AE | Atlantic Electric zone (part of Pepco Holdings, Inc) |
| AEP | American Electric Power zone (incorporated 10/1/2004) |
| APP | Appalachian Power, sub-zone of AEP |
| APS | Allegheny Power zone (incorporated 4/1/2002) |
| ATSI | American Transmission Systems, Inc. zone (to be incorporated 6/1/2011) |
| Base Load | Average peak load on non-holiday weekdays with no heating or cooling load. Base load is insensitive to weather. |
| BGE | Baltimore Gas & Electric zone |
| CEI | Cleveland Electric Illuminating, sub-zone of ATSI |
| COMED | Commonwealth Edison zone (incorporated 5/1/2004) |
| Contractually Interruptible | Load Management from customers responding to direction from a control center |
| Cooling Load | The weather-sensitive portion of summer peak load |
| CSP | Columbus Southern Power, sub-zone of AEP |
| Direct Control | Load Management achieved directly by a signal from a control center |
| DAY | Dayton Power & Light zone (incorporated 10/1/2004) |
| DLCO | Duquesne Lighting Company zone (incorporated 1/1/2005) |
| DPL | Delmarva Power & Light zone (part of Pepco Holdings, Inc) |
| FE/GPU | The combination of FirstEnergy's Jersey Central Power & Light, Metropolitan Edison, and Pennsylvania Electric zones (formerly GPU) |
| Heating Load | The weather-sensitive portion of winter peak load |
| INM | Indiana Michigan Power, sub-zone of AEP |
| JCPL | Jersey Central Power & Light zone |
| KP | Kentucky Power, sub-zone of AEP |
| METED | Metropolitan Edison zone |
| MP | Monongahela Power, sub-zone of APS |
| NERC | North American Electric Reliability Corporation |

| | |
|-------------------|---|
| Net Energy | Net Energy for Load, measured as net generation of main generating units plus energy receipts minus energy deliveries |
| OEP | Ohio Edison, sub-zone of ATSI |
| OP | Ohio Power, sub-zone of AEP |
| PECO | PECO Energy zone |
| PED | Potomac Edison, sub-zone of APS |
| PEPCO | Potomac Electric Power zone (part of Pepco Holdings, Inc) |
| PL | PPL Electric Utilities, sub-zone of PLGroup |
| PLGroup/PLGRP | Pennsylvania Power & Light zone |
| PENLC | Pennsylvania Electric zone |
| PP | Pennsylvania Power, sub-zone of ATSI |
| PS | Public Service Electric & Gas zone |
| RECO | Rockland Electric (East) zone (incorporated 3/1/2002) |
| TOL | Toledo Edison, sub-zone of ATSI |
| UGI | UGI Utilities, sub-zone of PLGroup |
| Unrestricted Peak | Peak load prior to any reduction for load management, accelerated energy efficiency or voltage reduction. |
| WP | West Penn Power, sub-zone of APS |
| Zone | Areas within the PJM Control Area, as defined in the PJM Reliability Assurance Agreement |

2010 PJM LOAD FORECAST REPORT

EXECUTIVE SUMMARY

- This report presents an independent load forecast prepared by PJM staff.
- The report includes long-term forecasts of peak loads, net energy, load management and energy efficiency for each PJM zone, region, and the total RTO.
- This year's report includes the load of American Transmission Systems, Inc (ATSI), which is scheduled to be integrated into the PJM RTO on June 1, 2011.
- Several tables have been expanded in this year's report:
 - The Regional Summary tables have been revised to more closely represent the type of information provided to NERC and regional authorities.
 - The 'C' tables have been expanded to include extreme weather (90/10) forecasts in addition to the base (50/50) forecast;
 - Also, the data file that accompanies publication of this document has been expanded to include forecasts for all regions and Locational Deliverability Areas.
- All load models were estimated with historical data from January 1998 through August 2009. The models were simulated with weather data from years 1974 through 2008, which generated 455 scenarios. The economic forecast used was Moody's Economy.com's November 2009 release.
- The models for several zones have been revised:
 - AE: The Gross Metropolitan Product (GMP) for the Vineland, NJ metropolitan area was added. The GMP for AE zone is now the sum of Atlantic City and Vineland;
 - AEP: The GMP of the Kalamazoo MI metropolitan area was dropped, while the GMPs of the Elkhart IN, Kingsport TN, Lynchburg VA and Huntington WV areas were added. The weather station data from Charleston WV was dropped, while data from Fort Wayne IN and Roanoke VA were added. The new weather station mixture and weights for AEP zone are: Columbus 50%, Fort Wayne 20%, Roanoke 30%;
 - DOM: The GMP combination of Richmond VA, Roanoke VA, and Virginia Beach VA was replaced with the Gross State Product of Virginia;
 - DPL: The weather station data from Philadelphia PA was replaced by Wilmington DE (weighted 70%) and Wallops Island VA (weighted 30%).
- The summer peak forecast of AEP zone was adjusted downward by 600 MW to account for anticipated lingering impacts of the recession, judged by PJM staff not to be reflected in the forecast model.


- The PJM RTO weather normalized summer peak for 2009 was 133,780 MW. The projection for the 2010 PJM RTO summer peak is 135,750 MW, an increase of 1,970 MW, or 1.5%, from the 2009 normalized peak.
- Summer peak load growth for PJM RTO (with ATSI) is projected to average 1.7% per year over the next 10 years, and 1.4% over the next 15 years. The PJM RTO summer peak is forecasted to be 174,724 MW in 2020, a 10-year increase of 26,933 MW, and reaches 182,665 MW in 2025, a 15-year increase of 34,874 MW. Annualized 10-year growth rates for individual zones range from 1.0% to 2.5%.
- Summer peak load growth for PJM RTO (without ATSI) is projected to average 1.7% per year over the next 10 years, and 1.5% over the next 15 years. The PJM RTO summer peak is forecasted to be 161,047 MW in 2020, a 10-year increase of 25,297 MW, and reaches 168,824 MW in 2025, a 15-year increase of 33,074 MW.
- Winter peak load growth for PJM RTO (with ATSI) is projected to average 1.4% per year over the next 10-year period, and 1.2% over the next 15-years. The PJM RTO winter peak load in 2019/20 is forecasted to be 141,072 MW, a 10-year increase of 17,943 MW, and reaches 146,481 MW in 2024/25, a 15-year increase of 23,352 MW. Annualized 10-year growth rates for individual zones range from 0.8 to 2.1%.
- Compared to the 2009 Load Report, the new PJM RTO summer peak forecast shows the following changes for three years of interest:
 - The next delivery year – 2010 -288 MW (-0.2%)
 - The next RPM auction year – 2013 244 MW (0.2%)
13,189 MW (8.9%) – with ATSI
 - The next RTEP study year – 2015 709 MW (0.5%)
13,992 MW (9.2%) – with ATSI
- Based on the forecast contained within this report, the PJM RTO will continue to be summer peaking during the next 15 years.

NOTE:


Unless noted otherwise, all peak values are unrestricted peaks, which represent the peak load prior to reductions for load management or energy efficiency impacts.

All compound growth rates are calculated from the first year of the forecast.


PJM SUMMER PEAK LOAD GROWTH RATE 2010 - 2020




**PJM WINTER PEAK LOAD GROWTH RATE
2010 - 2020**




**SUMMER PEAK DEMAND FOR AE
GEOGRAPHIC ZONE**




**WINTER PEAK DEMAND FOR AE
GEOGRAPHIC ZONE**




**SUMMER PEAK DEMAND FOR BGE
GEOGRAPHIC ZONE**




**WINTER PEAK DEMAND FOR BGE
GEOGRAPHIC ZONE**




SUMMER PEAK DEMAND FOR DPL GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR DPL GEOGRAPHIC ZONE




SUMMER PEAK DEMAND FOR JCPL GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR JCPL GEOGRAPHIC ZONE




SUMMER PEAK DEMAND FOR METED GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR METED GEOGRAPHIC ZONE




SUMMER PEAK DEMAND FOR PECO GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR PECO GEOGRAPHIC ZONE




**SUMMER PEAK DEMAND FOR PENLC
GEOGRAPHIC ZONE**




**WINTER PEAK DEMAND FOR PENLC
GEOGRAPHIC ZONE**




SUMMER PEAK DEMAND FOR PEP GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR PEP GEOGRAPHIC ZONE




SUMMER PEAK DEMAND FOR PL GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR PL GEOGRAPHIC ZONE




**SUMMER PEAK DEMAND FOR PS
GEOGRAPHIC ZONE**




**WINTER PEAK DEMAND FOR PS
GEOGRAPHIC ZONE**




SUMMER PEAK DEMAND FOR RECO GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR RECO GEOGRAPHIC ZONE




**SUMMER PEAK DEMAND FOR UGI
GEOGRAPHIC ZONE**




**WINTER PEAK DEMAND FOR UGI
GEOGRAPHIC ZONE**




SUMMER PEAK DEMAND FOR AEP GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR AEP GEOGRAPHIC ZONE




**SUMMER PEAK DEMAND FOR APS
GEOGRAPHIC ZONE**




**WINTER PEAK DEMAND FOR APS
GEOGRAPHIC ZONE**




SUMMER PEAK DEMAND FOR ATSI GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR ATSI GEOGRAPHIC ZONE




SUMMER PEAK DEMAND FOR COMED GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR COMED GEOGRAPHIC ZONE




SUMMER PEAK DEMAND FOR DAYTON GEOGRAPHIC ZONE




WINTER PEAK DEMAND FOR DAYTON GEOGRAPHIC ZONE




**SUMMER PEAK DEMAND FOR DLCO
GEOGRAPHIC ZONE**




**WINTER PEAK DEMAND FOR DLCO
GEOGRAPHIC ZONE**




SUMMER PEAK DEMAND FOR DOM GEOGRAPHIC ZONE



WINTER PEAK DEMAND FOR DOM GEOGRAPHIC ZONE



SUMMER PEAK DEMAND FOR PJM RTO GEOGRAPHIC ZONE



WINTER PEAK DEMAND FOR PJM RTO GEOGRAPHIC ZONE




Table A-1

**PJM MID-ATLANTIC REGION
SUMMER PEAK LOAD COMPARISONS OF THE CURRENT FORECAST
TO THE JANUARY 2009 LOAD FORECAST REPORT**

INCREASE OR DECREASE OVER PRIOR FORECAST

| | 2010 | | 2015 | | 2020 | |
|------------------|-------------|----------|-------------|----------|-------------|----------|
| | MW | % | MW | % | MW | % |
| AE | (27) | -1.0% | (102) | -3.0% | (129) | -3.6% |
| BGE | 10 | 0.1% | 64 | 0.8% | 6 | 0.1% |
| DPL | 21 | 0.5% | (215) | -4.7% | (368) | -7.4% |
| JCPL | (64) | -1.0% | (57) | -0.8% | (80) | -1.0% |
| METED | 14 | 0.5% | 64 | 2.0% | 80 | 2.4% |
| PECO | 69 | 0.8% | 235 | 2.6% | 205 | 2.1% |
| PENLC | 37 | 1.3% | 78 | 2.5% | 65 | 1.9% |
| PEPCO | 22 | 0.3% | 26 | 0.3% | (2) | 0.0% |
| PL | 6 | 0.1% | 167 | 2.2% | 181 | 2.3% |
| PS | (101) | -0.9% | (106) | -0.9% | (144) | -1.1% |
| RECO | (6) | -1.4% | (4) | -0.8% | (8) | -1.6% |
| UGI | (1) | -0.5% | 2 | 1.0% | 2 | 1.0% |
| PJM MID-ATLANTIC | (172) | -0.3% | 77 | 0.1% | (215) | -0.3% |
| FE/GPU | (14) | -0.1% | 68 | 0.5% | 41 | 0.3% |
| PLGRP | 9 | 0.1% | 169 | 2.1% | 189 | 2.3% |

Table A-1

**PJM WESTERN REGION, PJM SOUTHERN REGION AND PJM RTO
SUMMER PEAK LOAD COMPARISONS OF THE CURRENT FORECAST
TO THE JANUARY 2009 LOAD FORECAST REPORT**

INCREASE OR DECREASE OVER PRIOR FORECAST

| | 2010 | | 2015 | | 2020 | |
|----------------------------|-------------|----------|-------------|----------|-------------|----------|
| | MW | % | MW | % | MW | % |
| AEP | (530) | -2.2% | (162) | -0.6% | (61) | -0.2% |
| APS | (44) | -0.5% | (38) | -0.4% | (129) | -1.3% |
| ATSI | 13,040 | - | 14,430 | - | 14,888 | - |
| COMED | (267) | -1.2% | (229) | -0.9% | (93) | -0.3% |
| DAY | (46) | -1.3% | (77) | -2.0% | (126) | -3.2% |
| DLCO | 18 | 0.6% | 37 | 1.2% | 26 | 0.8% |
| PJM WESTERN (with ATSI) | 11,811 | - | 13,547 | - | 14,030 | - |
| PJM WESTERN (without ATSI) | (954) | -1.6% | (553) | -0.8% | (473) | -0.7% |
| DOM | 515 | 2.7% | 1,087 | 5.0% | 1,328 | 5.5% |
| PJM RTO (with ATSI) | 11,753 | - | 13,992 | - | 14,367 | - |
| PJM RTO (without ATSI) | (288) | -0.2% | 709 | 0.5% | 690 | 0.4% |

Table A-2

**PJM MID-ATLANTIC REGION
WINTER PEAK LOAD COMPARISONS OF THE CURRENT FORECAST
TO THE JANUARY 2009 LOAD FORECAST REPORT**

INCREASE OR DECREASE OVER PRIOR FORECAST

| | 09/10 | | 14/15 | | 19/20 | |
|------------------|--------------|----------|--------------|----------|--------------|----------|
| | MW | % | MW | % | MW | % |
| AE | (32) | -1.8% | (117) | -5.4% | (152) | -6.6% |
| BGE | 5 | 0.1% | 31 | 0.5% | 17 | 0.3% |
| DPL | 0 | 0.0% | (132) | -3.6% | (207) | -5.3% |
| JCPL | (41) | -1.0% | (40) | -0.9% | (58) | -1.2% |
| METED | 16 | 0.6% | 75 | 2.7% | 95 | 3.3% |
| PECO | 65 | 1.0% | 197 | 2.8% | 199 | 2.8% |
| PENLC | 21 | 0.8% | 86 | 2.8% | 84 | 2.5% |
| PEPCO | 30 | 0.6% | 51 | 0.9% | 54 | 0.9% |
| PL | 10 | 0.1% | 185 | 2.4% | 217 | 2.8% |
| PS | (74) | -1.0% | (72) | -0.9% | (94) | -1.2% |
| RECO | (4) | -1.7% | (4) | -1.6% | (5) | -1.9% |
| UGI | (2) | -1.0% | 1 | 0.5% | 1 | 0.5% |
| PJM MID-ATLANTIC | (112) | -0.2% | 142 | 0.3% | 62 | 0.1% |
| FE/GPU | (14) | -0.2% | 118 | 1.2% | 108 | 1.0% |
| PLGRP | (2) | 0.0% | 179 | 2.3% | 209 | 2.6% |

Table A-2

**PJM WESTERN REGION, PJM SOUTHERN REGION AND PJM RTO
WINTER PEAK LOAD COMPARISONS OF THE CURRENT FORECAST
TO THE JANUARY 2009 LOAD FORECAST REPORT**

INCREASE OR DECREASE OVER PRIOR FORECAST

| | 09/10 | | 14/15 | | 19/20 | |
|----------------------------|--------------|----------|--------------|----------|--------------|----------|
| | MW | % | MW | % | MW | % |
| AEP | (575) | -2.5% | (326) | -1.3% | (261) | -1.1% |
| APS | 98 | 1.2% | 204 | 2.3% | 190 | 2.0% |
| ATSI | 10,518 | - | 11,358 | - | 11,651 | - |
| COMED | 8 | 0.1% | 25 | 0.1% | 146 | 0.8% |
| DAY | 22 | 0.8% | (58) | -1.8% | (96) | -3.0% |
| DLCO | 11 | 0.5% | 18 | 0.8% | 8 | 0.3% |
| PJM WESTERN (with ATSI) | 9,827 | - | 10,943 | - | 11,361 | - |
| PJM WESTERN (without ATSI) | (549) | -1.1% | (243) | -0.4% | (160) | -0.3% |
| DOM | 396 | 2.4% | 840 | 4.5% | 1,121 | 5.6% |
| PJM RTO (with ATSI) | 10,379 | - | 12,228 | - | 12,714 | - |
| PJM RTO (without ATSI) | (8) | 0.0% | 1,076 | 0.9% | 1,367 | 1.1% |

PJM CONTROL AREA - JANUARY 2010
SUMMER TOTAL INTERNAL DEMAND FORECAST (MW) FOR EACH NERC REGION
2010-2020

| | | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | Annual Growth Rate (10 yr) |
|---------------------------------------|---|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|---|
| PJM - RELIABILITYFIRST (with ATSI) | | 129,102 | 132,736 | 137,025 | 140,029 | 142,104 | 143,913 | 145,377 | 146,837 | 148,168 | 149,609 | 150,983 | 1.6% |
| | % | | 2.8% | 3.2% | 2.2% | 1.5% | 1.3% | 1.0% | 1.0% | 0.9% | 1.0% | 0.9% | |
| PJM - SERC | | 19,779 | 20,488 | 21,365 | 21,958 | 22,476 | 22,982 | 23,353 | 23,843 | 24,316 | 24,830 | 25,387 | 2.5% |
| | % | | 3.6% | 4.3% | 2.8% | 2.4% | 2.3% | 1.6% | 2.1% | 2.0% | 2.1% | 2.2% | |
| PJM RTO (with ATSI) | | 147,791 | 152,028 | 157,167 | 160,631 | 163,093 | 165,402 | 167,403 | 169,297 | 171,081 | 172,869 | 174,724 | 1.7% |
| | % | | 2.9% | 3.4% | 2.2% | 1.5% | 1.4% | 1.2% | 1.1% | 1.1% | 1.0% | 1.1% | |
| PJM - RELIABILITYFIRST (without ATSI) | | 116,701 | 120,024 | 123,960 | 126,656 | 128,482 | 130,184 | 131,608 | 132,963 | 134,259 | 135,580 | 136,848 | 1.6% |
| | % | | 2.8% | 3.3% | 2.2% | 1.4% | 1.3% | 1.1% | 1.0% | 1.0% | 1.0% | 0.9% | |
| PJM RTO (without ATSI) | | 135,750 | 139,654 | 144,426 | 147,686 | 149,988 | 152,119 | 154,014 | 155,845 | 157,519 | 159,311 | 161,047 | 1.7% |
| | % | | 2.9% | 3.4% | 2.3% | 1.6% | 1.4% | 1.2% | 1.2% | 1.1% | 1.1% | 1.1% | |

Notes:
Projected PJM seasonal peak load at normal peak weather conditions in the absense of any load reductions due to load management, voltage reductions or voluntary curtailments.
The above forecasts incorporate all load in the PJM Control Area, including members and non-members.
All growth rates are calculated from the first year of the forecast.

PJM CONTROL AREA - JANUARY 2010
SUMMER TOTAL INTERNAL DEMAND FORECAST (MW) FOR EACH NERC REGION
2021-2025

| | | 2021 | 2022 | 2023 | 2024 | 2025 | Annual Growth Rate (15 yr) |
|---------------------------------------|---|-------------|-------------|-------------|-------------|-------------|---------------------------------------|
| PJM - RELIABILITYFIRST (with ATSI) | | 152,068 | 153,073 | 154,085 | 155,184 | 156,358 | 1.3% |
| | % | 0.7% | 0.7% | 0.7% | 0.7% | 0.8% | |
| PJM - SERC | | 25,861 | 26,359 | 26,912 | 27,436 | 28,013 | 2.3% |
| | % | 1.9% | 1.9% | 2.1% | 1.9% | 2.1% | |
| PJM RTO (with ATSI) | | 176,382 | 177,894 | 179,385 | 180,936 | 182,665 | 1.4% |
| | % | 0.9% | 0.9% | 0.8% | 0.9% | 1.0% | |
| PJM - RELIABILITYFIRST (without ATSI) | | 137,905 | 138,903 | 139,853 | 140,918 | 142,027 | 1.3% |
| | % | 0.8% | 0.7% | 0.7% | 0.8% | 0.8% | |
| PJM RTO (without ATSI) | | 162,659 | 164,144 | 165,595 | 167,120 | 168,824 | 1.5% |
| | % | 1.0% | 0.9% | 0.9% | 0.9% | 1.0% | |

Notes:

Projected PJM seasonal peak load at normal peak weather conditions in the absense of any load reductions due to load management, voltage reductions or voluntary curtailments.

The above forecasts incorporate all load in the PJM Control Area, including members and non-members.

All growth rates are calculated from the first year of the forecast.

PJM CONTROL AREA - JANUARY 2010
WINTER TOTAL INTERNAL DEMAND FORECAST (MW) FOR EACH NERC REGION
2009/10-2019/20

| | | 09/10 | 10/11 | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 | Annual Growth Rate (10 yr) |
|---------------------------------------|---|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|---|
| PJM - RELIABILITYFIRST (with ATSI) | | 106,670 | 108,563 | 111,371 | 113,370 | 114,714 | 116,058 | 117,323 | 118,564 | 119,465 | 120,084 | 120,685 | 1.2% |
| | % | | 1.8% | 2.6% | 1.8% | 1.2% | 1.2% | 1.1% | 1.1% | 0.8% | 0.5% | 0.5% | |
| PJM - SERC | | 17,169 | 17,540 | 18,154 | 18,683 | 19,075 | 19,391 | 19,751 | 20,091 | 20,422 | 20,778 | 21,104 | 2.1% |
| | % | | 2.2% | 3.5% | 2.9% | 2.1% | 1.7% | 1.9% | 1.7% | 1.6% | 1.7% | 1.6% | |
| PJM RTO (with ATSI) | | 123,129 | 125,182 | 128,631 | 131,401 | 133,193 | 134,856 | 136,311 | 137,687 | 138,925 | 140,090 | 141,072 | 1.4% |
| | % | | 1.7% | 2.8% | 2.2% | 1.4% | 1.2% | 1.1% | 1.0% | 0.9% | 0.8% | 0.7% | |
| PJM - RELIABILITYFIRST (without ATSI) | | 96,228 | 98,011 | 100,577 | 102,424 | 103,613 | 104,890 | 106,067 | 107,172 | 107,986 | 108,616 | 109,236 | 1.3% |
| | % | | 1.9% | 2.6% | 1.8% | 1.2% | 1.2% | 1.1% | 1.0% | 0.8% | 0.6% | 0.6% | |
| PJM RTO (without ATSI) | | 112,742 | 114,746 | 117,912 | 120,496 | 122,148 | 123,704 | 125,042 | 126,356 | 127,505 | 128,607 | 129,725 | 1.4% |
| | % | | 1.8% | 2.8% | 2.2% | 1.4% | 1.3% | 1.1% | 1.1% | 0.9% | 0.9% | 0.9% | |

Notes:
Projected PJM seasonal peak load at normal peak weather conditions in the absense of any load reductions due to load management, voltage reductions or voluntary curtailments.
The above forecasts incorporate all load in the PJM Control Area, including members and non-members.
All growth rates are calculated from the first year of the forecast.

PJM CONTROL AREA - JANUARY 2010
WINTER TOTAL INTERNAL DEMAND FORECAST (MW) FOR EACH NERC REGION
2020/21-2024/25

| | | 20/21 | 21/22 | 22/23 | 23/24 | 24/25 | Annual Growth Rate (15 yr) |
|---------------------------------------|---|--------------|--------------|--------------|--------------|--------------|---------------------------------------|
| PJM - RELIABILITYFIRST (with ATSI) | | 121,762 | 122,777 | 123,438 | 124,060 | 124,282 | 1.0% |
| | % | 0.9% | 0.8% | 0.5% | 0.5% | 0.2% | |
| PJM - SERC | | 21,470 | 21,845 | 22,235 | 22,625 | 23,008 | 2.0% |
| | % | 1.7% | 1.7% | 1.8% | 1.8% | 1.7% | |
| PJM RTO (with ATSI) | | 142,400 | 143,601 | 144,643 | 145,666 | 146,481 | 1.2% |
| | % | 0.9% | 0.8% | 0.7% | 0.7% | 0.6% | |
| PJM - RELIABILITYFIRST (without ATSI) | | 110,280 | 111,148 | 111,768 | 112,394 | 112,706 | 1.1% |
| | % | 1.0% | 0.8% | 0.6% | 0.6% | 0.3% | |
| PJM RTO (without ATSI) | | 130,908 | 132,033 | 133,061 | 134,086 | 135,028 | 1.2% |
| | % | 0.9% | 0.9% | 0.8% | 0.8% | 0.7% | |

Notes:
Projected PJM seasonal peak load at normal peak weather conditions in the absense of any load reductions due to load management, voltage reductions or voluntary curtailments.
The above forecasts incorporate all load in the PJM Control Area, including members and non-members.
All growth rates are calculated from the first year of the forecast.

Table B-1

**SUMMER PEAK LOAD (MW) AND GROWTH RATES FOR
EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION
2010-2020**

| | | METERED 2009 | UNRESTRICTED 2009 | NORMAL 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | Annual Growth Rate (10 yr) |
|------------------------------|---|-----------------|----------------------|----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|----------------------------------|
| AE | | 2,707 | 2,707 | 2,650 | 2,734 | 2,897 | 3,032 | 3,136 | 3,198 | 3,249 | 3,288 | 3,332 | 3,372 | 3,405 | 3,443 | 2.3% |
| | % | | | | 3.2% | 6.0% | 4.7% | 3.4% | 2.0% | 1.6% | 1.2% | 1.3% | 1.2% | 1.0% | 1.1% | |
| BGE | | 6,596 | 6,596 | 7,290 | 7,456 | 7,656 | 7,781 | 7,926 | 8,076 | 8,240 | 8,351 | 8,488 | 8,609 | 8,761 | 8,919 | 1.8% |
| | % | | | | 2.3% | 2.7% | 1.6% | 1.9% | 1.9% | 2.0% | 1.3% | 1.6% | 1.4% | 1.8% | 1.8% | |
| DPL | | 3,843 | 3,843 | 3,960 | 4,023 | 4,089 | 4,153 | 4,219 | 4,279 | 4,339 | 4,383 | 4,435 | 4,488 | 4,539 | 4,601 | 1.4% |
| | % | | | | 1.6% | 1.6% | 1.6% | 1.6% | 1.4% | 1.4% | 1.0% | 1.2% | 1.2% | 1.1% | 1.4% | |
| JCPL | | 5,738 | 5,738 | 6,310 | 6,440 | 6,625 | 6,843 | 7,000 | 7,115 | 7,212 | 7,323 | 7,373 | 7,451 | 7,533 | 7,611 | 1.7% |
| | % | | | | 2.1% | 2.9% | 3.3% | 2.3% | 1.6% | 1.4% | 1.5% | 0.7% | 1.1% | 1.1% | 1.0% | |
| METED | | 2,839 | 2,839 | 2,890 | 2,920 | 3,006 | 3,112 | 3,189 | 3,243 | 3,283 | 3,314 | 3,346 | 3,375 | 3,407 | 3,444 | 1.7% |
| | % | | | | 1.0% | 2.9% | 3.5% | 2.5% | 1.7% | 1.2% | 0.9% | 1.0% | 0.9% | 0.9% | 1.1% | |
| PECO | | 7,993 | 8,009 | 8,590 | 8,528 | 8,700 | 8,991 | 9,175 | 9,327 | 9,447 | 9,519 | 9,601 | 9,680 | 9,751 | 9,821 | 1.4% |
| | % | | | | -0.7% | 2.0% | 3.3% | 2.0% | 1.7% | 1.3% | 0.8% | 0.9% | 0.8% | 0.7% | 0.7% | |
| PENLC | | 2,810 | 2,817 | 2,810 | 2,843 | 2,908 | 2,994 | 3,063 | 3,119 | 3,176 | 3,223 | 3,273 | 3,310 | 3,365 | 3,420 | 1.9% |
| | % | | | | 1.2% | 2.3% | 3.0% | 2.3% | 1.8% | 1.8% | 1.5% | 1.6% | 1.1% | 1.7% | 1.6% | |
| PEPCO | | 6,325 | 6,325 | 6,960 | 7,048 | 7,144 | 7,273 | 7,371 | 7,457 | 7,538 | 7,591 | 7,668 | 7,740 | 7,822 | 7,909 | 1.2% |
| | % | | | | 1.3% | 1.4% | 1.8% | 1.3% | 1.2% | 1.1% | 0.7% | 1.0% | 0.9% | 1.1% | 1.1% | |
| PL | | 6,845 | 6,853 | 7,140 | 7,161 | 7,345 | 7,554 | 7,727 | 7,835 | 7,924 | 7,986 | 8,044 | 8,096 | 8,155 | 8,213 | 1.4% |
| | % | | | | 0.3% | 2.6% | 2.8% | 2.3% | 1.4% | 1.1% | 0.8% | 0.7% | 0.6% | 0.7% | 0.7% | |
| PS | | 9,687 | 9,687 | 10,740 | 10,921 | 11,147 | 11,427 | 11,621 | 11,771 | 11,907 | 12,006 | 12,105 | 12,194 | 12,305 | 12,428 | 1.3% |
| | % | | | | 1.7% | 2.1% | 2.5% | 1.7% | 1.3% | 1.2% | 0.8% | 0.8% | 0.7% | 0.9% | 1.0% | |
| RECO | | 371 | 371 | 430 | 435 | 444 | 452 | 462 | 468 | 473 | 477 | 481 | 483 | 489 | 493 | 1.3% |
| | % | | | | 1.2% | 2.1% | 1.8% | 2.2% | 1.3% | 1.1% | 0.8% | 0.8% | 0.4% | 1.2% | 0.8% | |
| UGI | | 181 | 181 | 190 | 190 | 194 | 199 | 202 | 204 | 206 | 207 | 208 | 208 | 209 | 210 | 1.0% |
| | % | | | | 0.0% | 2.1% | 2.6% | 1.5% | 1.0% | 1.0% | 0.5% | 0.5% | 0.0% | 0.5% | 0.5% | |
| DIVERSITY - MID-ATLANTIC (-) | | | | | 530 | 488 | 599 | 498 | 512 | 514 | 380 | 367 | 373 | 322 | 385 | |
| PJM MID-ATLANTIC | | 55,436 | 55,548 | 59,480 | 60,169 | 61,667 | 63,212 | 64,593 | 65,580 | 66,480 | 67,288 | 67,987 | 68,633 | 69,419 | 70,127 | 1.5% |
| | % | | | | 1.2% | 2.5% | 2.5% | 2.2% | 1.5% | 1.4% | 1.2% | 1.0% | 1.0% | 1.1% | 1.0% | |
| FE/GPU | | 11,256 | 11,262 | 11,850 | 12,038 | 12,389 | 12,814 | 13,124 | 13,339 | 13,526 | 13,699 | 13,862 | 14,021 | 14,182 | 14,326 | 1.8% |
| | % | | | | 1.6% | 2.9% | 3.4% | 2.4% | 1.6% | 1.4% | 1.3% | 1.2% | 1.1% | 1.1% | 1.0% | |
| PLGRP | | 7,025 | 7,034 | 7,300 | 7,314 | 7,510 | 7,721 | 7,896 | 8,006 | 8,092 | 8,167 | 8,220 | 8,277 | 8,337 | 8,388 | 1.4% |
| | % | | | | 0.2% | 2.7% | 2.8% | 2.3% | 1.4% | 1.1% | 0.9% | 0.6% | 0.7% | 0.7% | 0.6% | |

Note:

Normal 2009 and all forecast values are non-coincident as estimated by PJM staff.

Normal 2009 and all forecast values represent unrestricted peaks.

All average growth rates are calculated from the first year of the forecast.

Table B-1 (Continued)

**SUMMER PEAK LOAD (MW) AND GROWTH RATES FOR
EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION
2021-2025**

| | | 2021 | 2022 | 2023 | 2024 | 2025 | Annual Growth Rate (15 yr) |
|------------------------------|---|-------------|-------------|-------------|-------------|-------------|---|
| AE | | 3,470 | 3,500 | 3,535 | 3,565 | 3,601 | 1.9% |
| | % | 0.8% | 0.9% | 1.0% | 0.8% | 1.0% | |
| BGE | | 9,025 | 9,137 | 9,267 | 9,394 | 9,523 | 1.6% |
| | % | 1.2% | 1.2% | 1.4% | 1.4% | 1.4% | |
| DPL | | 4,651 | 4,703 | 4,769 | 4,827 | 4,888 | 1.3% |
| | % | 1.1% | 1.1% | 1.4% | 1.2% | 1.3% | |
| JCPL | | 7,658 | 7,790 | 7,794 | 7,877 | 7,967 | 1.4% |
| | % | 0.6% | 1.7% | 0.1% | 1.1% | 1.1% | |
| METED | | 3,468 | 3,495 | 3,523 | 3,550 | 3,590 | 1.4% |
| | % | 0.7% | 0.8% | 0.8% | 0.8% | 1.1% | |
| PECO | | 9,861 | 9,894 | 9,943 | 9,985 | 10,045 | 1.1% |
| | % | 0.4% | 0.3% | 0.5% | 0.4% | 0.6% | |
| PENLC | | 3,459 | 3,499 | 3,543 | 3,578 | 3,623 | 1.6% |
| | % | 1.1% | 1.2% | 1.3% | 1.0% | 1.3% | |
| PEPCO | | 7,968 | 8,033 | 8,108 | 8,177 | 8,257 | 1.1% |
| | % | 0.7% | 0.8% | 0.9% | 0.9% | 1.0% | |
| PL | | 8,241 | 8,282 | 8,314 | 8,350 | 8,410 | 1.1% |
| | % | 0.3% | 0.5% | 0.4% | 0.4% | 0.7% | |
| PS | | 12,498 | 12,575 | 12,645 | 12,722 | 12,848 | 1.1% |
| | % | 0.6% | 0.6% | 0.6% | 0.6% | 1.0% | |
| RECO | | 496 | 499 | 503 | 505 | 509 | 1.1% |
| | % | 0.6% | 0.6% | 0.8% | 0.4% | 0.8% | |
| UGI | | 210 | 210 | 211 | 211 | 212 | 0.7% |
| | % | 0.0% | 0.0% | 0.5% | 0.0% | 0.5% | |
| DIVERSITY - MID-ATLANTIC (-) | | 240 | 250 | 222 | 201 | 235 | |
| PJM MID-ATLANTIC | | 70,765 | 71,367 | 71,933 | 72,540 | 73,238 | 1.3% |
| | % | 0.9% | 0.9% | 0.8% | 0.8% | 1.0% | |
| FE/GPU | | 14,465 | 14,604 | 14,732 | 14,888 | 15,055 | 1.5% |
| | % | 1.0% | 1.0% | 0.9% | 1.1% | 1.1% | |
| PLGRP | | 8,432 | 8,472 | 8,498 | 8,542 | 8,598 | 1.1% |
| | % | 0.5% | 0.5% | 0.3% | 0.5% | 0.7% | |

Table B-1

**SUMMER PEAK LOAD (MW) AND GROWTH RATES FOR
EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGIONS AND RTO
2010-2020**

| | | METERED | UNRESTRICTED | NORMAL | | | | | | | | | | | Annual Growth Rate (10 yr) |
|-------------------------------|---|---------|--------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|----------------------------------|
| | | 2009 | 2009 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 |
| AEP | | 21,887 | 21,887 | 23,470 | 23,287 | 23,856 | 24,649 | 25,136 | 25,448 | 25,735 | 25,897 | 26,106 | 26,270 | 26,439 | 26,631 |
| | % | | | | -0.8% | 2.4% | 3.3% | 2.0% | 1.2% | 1.1% | 0.6% | 0.8% | 0.6% | 0.6% | 0.7% |
| APS | | 7,860 | 7,871 | 8,490 | 8,661 | 8,872 | 9,057 | 9,223 | 9,338 | 9,449 | 9,511 | 9,599 | 9,682 | 9,789 | 9,909 |
| | % | | | | 2.0% | 2.4% | 2.1% | 1.8% | 1.2% | 1.2% | 0.7% | 0.9% | 0.9% | 1.1% | 1.2% |
| ATSI | | 12,310 | 12,310 | | 13,040 | 13,338 | 13,801 | 14,089 | 14,269 | 14,430 | 14,508 | 14,614 | 14,692 | 14,781 | 14,888 |
| | % | | | | | 2.3% | 3.5% | 2.1% | 1.3% | 1.1% | 0.5% | 0.7% | 0.5% | 0.6% | 0.7% |
| COMED | | 21,218 | 21,218 | 22,180 | 22,536 | 23,372 | 24,460 | 25,217 | 25,699 | 26,205 | 26,542 | 26,878 | 27,191 | 27,582 | 27,965 |
| | % | | | | 1.6% | 3.7% | 4.7% | 3.1% | 1.9% | 2.0% | 1.3% | 1.3% | 1.2% | 1.4% | 1.4% |
| DAY | | 3,327 | 3,327 | 3,310 | 3,368 | 3,479 | 3,628 | 3,707 | 3,745 | 3,779 | 3,791 | 3,804 | 3,811 | 3,825 | 3,835 |
| | % | | | | 1.8% | 3.3% | 4.3% | 2.2% | 1.0% | 0.9% | 0.3% | 0.3% | 0.2% | 0.4% | 0.3% |
| DLCO | | 2,732 | 2,732 | 2,890 | 2,883 | 2,921 | 2,995 | 3,054 | 3,099 | 3,142 | 3,171 | 3,209 | 3,245 | 3,280 | 3,318 |
| | % | | | | -0.2% | 1.3% | 2.5% | 2.0% | 1.5% | 1.4% | 0.9% | 1.2% | 1.1% | 1.1% | 1.2% |
| DIVERSITY - WESTERN (-) | | | | | 1,684 | 1,739 | 1,936 | 1,923 | 1,955 | 2,011 | 1,973 | 2,011 | 2,080 | 2,082 | 2,192 |
| PJM WESTERN (with ATSI) | | | | | 72,091 | 74,099 | 76,654 | 78,503 | 79,643 | 80,729 | 81,447 | 82,199 | 82,811 | 83,614 | 84,354 |
| | % | | | | | 2.8% | 3.4% | 2.4% | 1.5% | 1.4% | 0.9% | 0.9% | 0.7% | 1.0% | 0.9% |
| DIVERSITY - WESTERN (-) | | | | | 1,409 | 1,377 | 1,466 | 1,551 | 1,672 | 1,681 | 1,610 | 1,679 | 1,712 | 1,766 | 1,807 |
| PJM WESTERN (without ATSI) | | 55,149 | 55,168 | 59,010 | 59,326 | 61,123 | 63,323 | 64,786 | 65,657 | 66,629 | 67,302 | 67,917 | 68,487 | 69,149 | 69,851 |
| | % | | | | 0.5% | 3.0% | 3.6% | 2.3% | 1.3% | 1.5% | 1.0% | 0.9% | 0.8% | 1.0% | 1.0% |
| DOM | | 18,137 | 18,153 | 19,010 | 19,779 | 20,488 | 21,365 | 21,958 | 22,476 | 22,982 | 23,353 | 23,843 | 24,316 | 24,830 | 25,387 |
| | % | | | | 4.0% | 3.6% | 4.3% | 2.8% | 2.4% | 2.3% | 1.6% | 2.1% | 2.0% | 2.1% | 2.2% |
| DIVERSITY - INTERREGIONAL (-) | | | | | 4,248 | 4,226 | 4,064 | 4,423 | 4,606 | 4,789 | 4,685 | 4,732 | 4,679 | 4,994 | 5,144 |
| PJM RTO (with ATSI) | | | | | 147,791 | 152,028 | 157,167 | 160,631 | 163,093 | 165,402 | 167,403 | 169,297 | 171,081 | 172,869 | 174,724 |
| | % | | | | | 2.9% | 3.4% | 2.2% | 1.5% | 1.4% | 1.2% | 1.1% | 1.1% | 1.0% | 1.1% |
| DIVERSITY - INTERREGIONAL (-) | | | | | 3,524 | 3,624 | 3,474 | 3,651 | 3,725 | 3,972 | 3,929 | 3,902 | 3,917 | 4,087 | 4,318 |
| PJM RTO (without ATSI) | | 126,805 | 126,944 | 133,780 | 135,750 | 139,654 | 144,426 | 147,686 | 149,988 | 152,119 | 154,014 | 155,845 | 157,519 | 159,311 | 161,047 |
| | % | | | | 1.5% | 2.9% | 3.4% | 2.3% | 1.6% | 1.4% | 1.2% | 1.2% | 1.1% | 1.1% | 1.1% |

Note:

Normal 2009 and all forecast values are non-coincident as estimated by PJM staff.

Normal 2009 and all forecast values represent unrestricted peaks.

All average growth rates are calculated from the first year of the forecast.

Table B-1 (Continued)

**SUMMER PEAK LOAD (MW) AND GROWTH RATES FOR
EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGIONS AND RTO
2021-2025**

| | | 2021 | 2022 | 2023 | 2024 | 2025 | Annual Growth Rate (15 yr) |
|-------------------------------|---|---------|---------|---------|---------|---------|----------------------------------|
| AEP | | 26,745 | 26,874 | 27,023 | 27,173 | 27,340 | 1.1% |
| | % | 0.4% | 0.5% | 0.6% | 0.6% | 0.6% | |
| APS | | 9,985 | 10,065 | 10,156 | 10,243 | 10,361 | 1.2% |
| | % | 0.8% | 0.8% | 0.9% | 0.9% | 1.2% | |
| ATSI | | 14,904 | 14,940 | 14,975 | 15,012 | 15,081 | 1.0% |
| | % | 0.1% | 0.2% | 0.2% | 0.2% | 0.5% | |
| COMED | | 28,188 | 28,365 | 28,507 | 28,647 | 28,846 | 1.7% |
| | % | 0.8% | 0.6% | 0.5% | 0.5% | 0.7% | |
| DAY | | 3,834 | 3,837 | 3,837 | 3,845 | 3,858 | 0.9% |
| | % | 0.0% | 0.1% | 0.0% | 0.2% | 0.3% | |
| DLCO | | 3,340 | 3,360 | 3,387 | 3,412 | 3,448 | 1.2% |
| | % | 0.7% | 0.6% | 0.8% | 0.7% | 1.1% | |
| DIVERSITY - WESTERN (-) | | 2,083 | 2,110 | 2,144 | 2,092 | 2,155 | |
| PJM WESTERN (with ATSI) | | 84,913 | 85,331 | 85,741 | 86,240 | 86,779 | 1.2% |
| | % | 0.7% | 0.5% | 0.5% | 0.6% | 0.6% | |
| DIVERSITY - WESTERN (-) | | 1,699 | 1,732 | 1,745 | 1,758 | 1,851 | |
| PJM WESTERN (without ATSI) | | 70,393 | 70,769 | 71,165 | 71,562 | 72,002 | 1.3% |
| | % | 0.8% | 0.5% | 0.6% | 0.6% | 0.6% | |
| DOM | | 25,861 | 26,359 | 26,912 | 27,436 | 28,013 | 2.3% |
| | % | 1.9% | 1.9% | 2.1% | 1.9% | 2.1% | |
| DIVERSITY - INTERREGIONAL (-) | | 5,157 | 5,163 | 5,201 | 5,280 | 5,365 | |
| PJM RTO (with ATSI) | | 176,382 | 177,894 | 179,385 | 180,936 | 182,665 | 1.4% |
| | % | 0.9% | 0.9% | 0.8% | 0.9% | 1.0% | |
| DIVERSITY - INTERREGIONAL (-) | | 4,360 | 4,351 | 4,415 | 4,418 | 4,429 | |
| PJM RTO (without ATSI) | | 162,659 | 164,144 | 165,595 | 167,120 | 168,824 | 1.5% |
| | % | 1.0% | 0.9% | 0.9% | 0.9% | 1.0% | |

Note:

Normal 2009 and all forecast values are non-coincident as estimated by PJM staff.

Normal 2009 and all forecast values represent unrestricted peaks.

Table B-2

**WINTER PEAK LOAD (MW) AND GROWTH RATES FOR
EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION
2009/10-2019/20**

| | | METERED | UNRESTRICTED | NORMAL | | | | | | | | | | | Annual Growth Rate (10 yr) |
|------------------------------|---|---------|--------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|----------------------------------|
| | | 08/09 | 08/09 | 08/09 | 09/10 | 10/11 | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 |
| AE | | 1,776 | 1,776 | 1,750 | 1,773 | 1,817 | 1,915 | 1,977 | 2,017 | 2,046 | 2,073 | 2,093 | 2,110 | 2,131 | 2,142 |
| | % | | | | 1.3% | 2.5% | 5.4% | 3.2% | 2.0% | 1.4% | 1.3% | 1.0% | 0.8% | 1.0% | 0.5% |
| BGE | | 6,083 | 6,083 | 5,970 | 6,022 | 6,116 | 6,195 | 6,252 | 6,320 | 6,388 | 6,461 | 6,529 | 6,590 | 6,655 | 6,714 |
| | % | | | | 0.9% | 1.6% | 1.3% | 0.9% | 1.1% | 1.1% | 1.1% | 1.1% | 0.9% | 1.0% | 0.9% |
| DPL | | 3,493 | 3,493 | 3,310 | 3,301 | 3,339 | 3,382 | 3,425 | 3,458 | 3,499 | 3,538 | 3,573 | 3,606 | 3,639 | 3,663 |
| | % | | | | -0.3% | 1.2% | 1.3% | 1.3% | 1.0% | 1.2% | 1.1% | 1.0% | 0.9% | 0.9% | 0.7% |
| JCPL | | 3,937 | 3,937 | 3,930 | 3,986 | 4,066 | 4,183 | 4,285 | 4,337 | 4,405 | 4,462 | 4,506 | 4,543 | 4,584 | 4,606 |
| | % | | | | 1.4% | 2.0% | 2.9% | 2.4% | 1.2% | 1.6% | 1.3% | 1.0% | 0.8% | 0.9% | 0.5% |
| METED | | 2,622 | 2,622 | 2,590 | 2,571 | 2,640 | 2,723 | 2,795 | 2,838 | 2,870 | 2,900 | 2,939 | 2,959 | 2,984 | 3,000 |
| | % | | | | -0.7% | 2.7% | 3.1% | 2.6% | 1.5% | 1.1% | 1.0% | 1.3% | 0.7% | 0.8% | 0.5% |
| PECO | | 6,777 | 6,777 | 6,620 | 6,503 | 6,587 | 6,775 | 6,928 | 7,035 | 7,113 | 7,187 | 7,262 | 7,308 | 7,361 | 7,389 |
| | % | | | | -1.8% | 1.3% | 2.9% | 2.3% | 1.5% | 1.1% | 1.0% | 1.0% | 0.6% | 0.7% | 0.4% |
| PENLC | | 2,866 | 2,866 | 2,820 | 2,796 | 2,863 | 2,952 | 3,030 | 3,086 | 3,139 | 3,192 | 3,252 | 3,301 | 3,351 | 3,390 |
| | % | | | | -0.9% | 2.4% | 3.1% | 2.6% | 1.8% | 1.7% | 1.7% | 1.9% | 1.5% | 1.5% | 1.2% |
| PEPCO | | 5,554 | 5,554 | 5,430 | 5,481 | 5,553 | 5,656 | 5,750 | 5,822 | 5,872 | 5,934 | 5,996 | 6,053 | 6,118 | 6,171 |
| | % | | | | 0.9% | 1.3% | 1.9% | 1.7% | 1.3% | 0.9% | 1.1% | 1.0% | 1.0% | 1.1% | 0.9% |
| PL | | 7,414 | 7,414 | 7,210 | 7,169 | 7,284 | 7,447 | 7,588 | 7,680 | 7,758 | 7,814 | 7,882 | 7,919 | 7,956 | 7,980 |
| | % | | | | -0.6% | 1.6% | 2.2% | 1.9% | 1.2% | 1.0% | 0.7% | 0.9% | 0.5% | 0.5% | 0.3% |
| PS | | 6,848 | 6,848 | 6,940 | 6,982 | 7,091 | 7,248 | 7,389 | 7,454 | 7,534 | 7,603 | 7,680 | 7,731 | 7,782 | 7,818 |
| | % | | | | 0.6% | 1.6% | 2.2% | 1.9% | 0.9% | 1.1% | 0.9% | 1.0% | 0.7% | 0.7% | 0.5% |
| RECO | | 255 | 255 | 235 | 235 | 237 | 239 | 241 | 243 | 245 | 247 | 248 | 250 | 252 | 254 |
| | % | | | | 0.0% | 0.9% | 0.8% | 0.8% | 0.8% | 0.8% | 0.8% | 0.4% | 0.8% | 0.8% | 0.8% |
| UGI | | 197 | 197 | 195 | 194 | 197 | 200 | 203 | 205 | 207 | 208 | 209 | 209 | 210 | 210 |
| | % | | | | -0.5% | 1.5% | 1.5% | 1.5% | 1.0% | 1.0% | 0.5% | 0.5% | 0.0% | 0.5% | 0.0% |
| DIVERSITY - MID-ATLANTIC (-) | | | | | 603 | 487 | 488 | 569 | 574 | 599 | 613 | 580 | 580 | 595 | 563 |
| PJM MID-ATLANTIC | | 47,460 | 47,460 | 46,190 | 46,410 | 47,303 | 48,427 | 49,294 | 49,921 | 50,477 | 51,006 | 51,589 | 51,999 | 52,428 | 52,774 |
| | % | | | | 0.5% | 1.9% | 2.4% | 1.8% | 1.3% | 1.1% | 1.0% | 1.1% | 0.8% | 0.8% | 0.7% |
| FE/GPU | | 9,381 | 9,381 | 9,220 | 9,282 | 9,508 | 9,794 | 10,034 | 10,190 | 10,341 | 10,482 | 10,612 | 10,723 | 10,831 | 10,916 |
| | % | | | | 0.7% | 2.4% | 3.0% | 2.5% | 1.6% | 1.5% | 1.4% | 1.2% | 1.0% | 1.0% | 0.8% |
| PLGRP | | 7,609 | 7,609 | 7,350 | 7,342 | 7,466 | 7,632 | 7,768 | 7,854 | 7,939 | 7,996 | 8,056 | 8,099 | 8,128 | 8,159 |
| | % | | | | -0.1% | 1.7% | 2.2% | 1.8% | 1.1% | 1.1% | 0.7% | 0.8% | 0.5% | 0.4% | 0.4% |

Note:

Normal 08/09 and all forecast values are non-coincident as estimated by PJM staff.

Normal 08/09 and all forecast values represent unrestricted peaks.

All average growth rates are calculated from the first year of the forecast.

Table B-2 (Continued)

**WINTER PEAK LOAD (MW) AND GROWTH RATES FOR
EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION
2020/21-2024/25**

| | | 20/21 | 21/22 | 22/23 | 23/24 | 24/25 | Annual Growth Rate (15 yr) |
|------------------------------|---|--------------|--------------|--------------|--------------|--------------|---|
| AE | | 2,168 | 2,182 | 2,202 | 2,216 | 2,224 | 1.5% |
| | % | 1.2% | 0.6% | 0.9% | 0.6% | 0.4% | |
| BGE | | 6,776 | 6,843 | 6,904 | 6,962 | 7,015 | 1.0% |
| | % | 0.9% | 1.0% | 0.9% | 0.8% | 0.8% | |
| DPL | | 3,710 | 3,749 | 3,787 | 3,829 | 3,850 | 1.0% |
| | % | 1.3% | 1.1% | 1.0% | 1.1% | 0.5% | |
| JCPL | | 4,666 | 4,698 | 4,738 | 4,772 | 4,791 | 1.2% |
| | % | 1.3% | 0.7% | 0.9% | 0.7% | 0.4% | |
| METED | | 3,024 | 3,055 | 3,081 | 3,098 | 3,115 | 1.3% |
| | % | 0.8% | 1.0% | 0.9% | 0.6% | 0.5% | |
| PECO | | 7,433 | 7,483 | 7,516 | 7,536 | 7,555 | 1.0% |
| | % | 0.6% | 0.7% | 0.4% | 0.3% | 0.3% | |
| PENLC | | 3,437 | 3,488 | 3,535 | 3,574 | 3,608 | 1.7% |
| | % | 1.4% | 1.5% | 1.3% | 1.1% | 1.0% | |
| PEPCO | | 6,225 | 6,290 | 6,350 | 6,406 | 6,458 | 1.1% |
| | % | 0.9% | 1.0% | 1.0% | 0.9% | 0.8% | |
| PL | | 8,024 | 8,069 | 8,105 | 8,121 | 8,136 | 0.8% |
| | % | 0.6% | 0.6% | 0.4% | 0.2% | 0.2% | |
| PS | | 7,888 | 7,933 | 7,994 | 8,032 | 8,053 | 1.0% |
| | % | 0.9% | 0.6% | 0.8% | 0.5% | 0.3% | |
| RECO | | 257 | 259 | 261 | 263 | 265 | 0.8% |
| | % | 1.2% | 0.8% | 0.8% | 0.8% | 0.8% | |
| UGI | | 211 | 211 | 212 | 211 | 212 | 0.6% |
| | % | 0.5% | 0.0% | 0.5% | -0.5% | 0.5% | |
| DIVERSITY - MID-ATLANTIC (-) | | 640 | 596 | 653 | 639 | 595 | |
| PJM MID-ATLANTIC | | 53,179 | 53,664 | 54,032 | 54,381 | 54,687 | 1.1% |
| | % | 0.8% | 0.9% | 0.7% | 0.6% | 0.6% | |
| FE/GPU | | 11,052 | 11,157 | 11,257 | 11,348 | 11,431 | 1.4% |
| | % | 1.2% | 1.0% | 0.9% | 0.8% | 0.7% | |
| PLGRP | | 8,206 | 8,246 | 8,275 | 8,295 | 8,313 | 0.8% |
| | % | 0.6% | 0.5% | 0.4% | 0.2% | 0.2% | |

Table B-2

**WINTER PEAK LOAD (MW) AND GROWTH RATES FOR
EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO
2009/10-2019/20**

| | | METERED 08/09 | UNRESTRICTED 08/09 | NORMAL 08/09 | 09/10 | 10/11 | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 | Annual Growth Rate (10 yr) |
|---|---|------------------|-----------------------|-----------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|----------------------------------|
| AEP | | 24,434 | 24,434 | 22,930 | 22,310 | 22,597 | 23,115 | 23,441 | 23,657 | 23,832 | 24,005 | 24,253 | 24,310 | 24,355 | 24,410 | 0.9% |
| | % | | | | -2.7% | 1.3% | 2.3% | 1.4% | 0.9% | 0.7% | 0.7% | 1.0% | 0.2% | 0.2% | 0.2% | |
| APS | | 8,527 | 8,527 | 8,300 | 8,449 | 8,646 | 8,840 | 8,995 | 9,123 | 9,225 | 9,307 | 9,396 | 9,477 | 9,558 | 9,639 | 1.3% |
| | % | | | | 1.8% | 2.3% | 2.2% | 1.8% | 1.4% | 1.1% | 0.9% | 1.0% | 0.9% | 0.9% | 0.8% | |
| ATSI | | 10,463 | 10,463 | 0 | 10,518 | 10,654 | 10,925 | 11,135 | 11,265 | 11,358 | 11,435 | 11,536 | 11,573 | 11,625 | 11,651 | 1.0% |
| | % | | | | 1.3% | 2.5% | 1.9% | 1.2% | 0.8% | 0.7% | 0.9% | 0.3% | 0.4% | 0.2% | 0.2% | |
| COMED | | 16,328 | 16,328 | 15,750 | 15,588 | 15,862 | 16,567 | 17,142 | 17,400 | 17,749 | 18,047 | 18,329 | 18,512 | 18,719 | 18,851 | 1.9% |
| | % | | | | -1.0% | 1.8% | 4.4% | 3.5% | 1.5% | 2.0% | 1.7% | 1.6% | 1.0% | 1.1% | 0.7% | |
| DAY | | 3,124 | 3,124 | 2,920 | 2,918 | 2,958 | 3,029 | 3,084 | 3,102 | 3,118 | 3,131 | 3,150 | 3,152 | 3,155 | 3,147 | 0.8% |
| | % | | | | -0.1% | 1.4% | 2.4% | 1.8% | 0.6% | 0.5% | 0.4% | 0.6% | 0.1% | 0.1% | -0.3% | |
| DLCO | | 2,245 | 2,245 | 2,160 | 2,137 | 2,149 | 2,182 | 2,206 | 2,218 | 2,233 | 2,255 | 2,281 | 2,292 | 2,311 | 2,305 | 0.8% |
| | % | | | | -1.1% | 0.6% | 1.5% | 1.1% | 0.5% | 0.7% | 1.0% | 1.2% | 0.5% | 0.8% | -0.3% | |
| DIVERSITY - WESTERN (-) PJM WESTERN (with ATSI) | | | | | 1,279 | 1,246 | 1,244 | 1,265 | 1,270 | 1,377 | 1,451 | 1,501 | 1,444 | 1,505 | 1,390 | |
| | % | | | | 60,641 | 61,620 | 63,414 | 64,738 | 65,495 | 66,138 | 66,729 | 67,444 | 67,872 | 68,218 | 68,613 | 1.2% |
| | | | | | | 1.6% | 2.9% | 2.1% | 1.2% | 1.0% | 0.9% | 1.1% | 0.6% | 0.5% | 0.6% | |
| DIVERSITY - WESTERN (-) PJM WESTERN (without ATSI) | | 53,464 | 53,464 | 50,570 | 1,137 | 1,121 | 1,158 | 1,107 | 1,122 | 1,205 | 1,269 | 1,369 | 1,334 | 1,325 | 1,260 | |
| | % | | | | 50,265 | 51,091 | 52,575 | 53,761 | 54,378 | 54,952 | 55,476 | 56,040 | 56,409 | 56,773 | 57,092 | 1.3% |
| | | | | | -0.6% | 1.6% | 2.9% | 2.3% | 1.1% | 1.1% | 1.0% | 1.0% | 0.7% | 0.6% | 0.6% | |
| DOM | | 17,904 | 17,904 | 16,710 | 17,169 | 17,540 | 18,154 | 18,683 | 19,075 | 19,391 | 19,751 | 20,091 | 20,422 | 20,778 | 21,104 | 2.1% |
| | % | | | | 2.7% | 2.2% | 3.5% | 2.9% | 2.1% | 1.7% | 1.9% | 1.7% | 1.6% | 1.7% | 1.6% | |
| DIVERSITY - INTERREGIONAL (-) PJM RTO (with ATSI) | | | | | 1,091 | 1,281 | 1,364 | 1,314 | 1,298 | 1,150 | 1,175 | 1,437 | 1,368 | 1,334 | 1,419 | |
| | % | | | | 123,129 | 125,182 | 128,631 | 131,401 | 133,193 | 134,856 | 136,311 | 137,687 | 138,925 | 140,090 | 141,072 | 1.4% |
| | | | | | | 1.7% | 2.8% | 2.2% | 1.4% | 1.2% | 1.1% | 1.0% | 0.9% | 0.8% | 0.7% | |
| DIVERSITY - INTERREGIONAL (-) PJM RTO (without ATSI) | | 117,169 | 117,169 | 112,100 | 1,102 | 1,188 | 1,244 | 1,242 | 1,226 | 1,116 | 1,191 | 1,364 | 1,325 | 1,372 | 1,245 | |
| | % | | | | 112,742 | 114,746 | 117,912 | 120,496 | 122,148 | 123,704 | 125,042 | 126,356 | 127,505 | 128,607 | 129,725 | 1.4% |
| | | | | | 0.6% | 1.8% | 2.8% | 2.2% | 1.4% | 1.3% | 1.1% | 1.1% | 0.9% | 0.9% | 0.9% | |

Note:

Normal 08/09 and all forecast values are non-coincident as estimated by PJM staff.

Normal 08/09 and all forecast values represent unrestricted peaks.

All average growth rates are calculated from the first year of the forecast.

Table B-2 (Continued)

**WINTER PEAK LOAD (MW) AND GROWTH RATES FOR
EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO
2020/21-2024/25**

| | | 20/21 | 21/22 | 22/23 | 23/24 | 24/25 | Annual Growth Rate (15 yr) |
|-------------------------------|---|--------------|--------------|--------------|--------------|--------------|---|
| AEP | | 24,550 | 24,721 | 24,868 | 24,897 | 24,883 | 0.7% |
| | % | 0.6% | 0.7% | 0.6% | 0.1% | -0.1% | |
| APS | | 9,738 | 9,843 | 9,926 | 10,004 | 10,076 | 1.2% |
| | % | 1.0% | 1.1% | 0.8% | 0.8% | 0.7% | |
| ATSI | | 11,694 | 11,752 | 11,794 | 11,799 | 11,801 | 0.8% |
| | % | 0.4% | 0.5% | 0.4% | 0.0% | 0.0% | |
| COMED | | 19,097 | 19,259 | 19,422 | 19,509 | 19,458 | 1.5% |
| | % | 1.3% | 0.8% | 0.8% | 0.4% | -0.3% | |
| DAY | | 3,155 | 3,168 | 3,173 | 3,171 | 3,161 | 0.5% |
| | % | 0.3% | 0.4% | 0.2% | -0.1% | -0.3% | |
| DLCO | | 2,328 | 2,339 | 2,360 | 2,369 | 2,361 | 0.7% |
| | % | 1.0% | 0.5% | 0.9% | 0.4% | -0.3% | |
| DIVERSITY - WESTERN (-) | | 1,544 | 1,598 | 1,669 | 1,621 | 1,472 | |
| PJM WESTERN (with ATSI) | | 69,018 | 69,484 | 69,874 | 70,128 | 70,268 | 1.0% |
| | % | 0.6% | 0.7% | 0.6% | 0.4% | 0.2% | |
| DIVERSITY - WESTERN (-) | | 1,375 | 1,417 | 1,524 | 1,478 | 1,323 | |
| PJM WESTERN (without ATSI) | | 57,493 | 57,913 | 58,225 | 58,472 | 58,616 | 1.0% |
| | % | 0.7% | 0.7% | 0.5% | 0.4% | 0.2% | |
| DOM | | 21,470 | 21,845 | 22,235 | 22,625 | 23,008 | 2.0% |
| | % | 1.7% | 1.7% | 1.8% | 1.8% | 1.7% | |
| DIVERSITY - INTERREGIONAL (-) | | 1,267 | 1,392 | 1,498 | 1,468 | 1,482 | |
| PJM RTO (with ATSI) | | 142,400 | 143,601 | 144,643 | 145,666 | 146,481 | 1.2% |
| | % | 0.9% | 0.8% | 0.7% | 0.7% | 0.6% | |
| DIVERSITY - INTERREGIONAL (-) | | 1,234 | 1,389 | 1,431 | 1,392 | 1,283 | |
| PJM RTO (without ATSI) | | 130,908 | 132,033 | 133,061 | 134,086 | 135,028 | 1.2% |
| | % | 0.9% | 0.9% | 0.8% | 0.8% | 0.7% | |

Table B-3

**SPRING (APRIL) PEAK LOAD (MW) FOR
EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION
2010-2025**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|------------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| AE | 1,505 | 1,588 | 1,693 | 1,757 | 1,812 | 1,848 | 1,865 | 1,882 | 1,914 | 1,938 | 1,980 | 1,991 | 1,994 | 2,012 | 2,051 | 2,073 |
| BGE | 4,955 | 5,044 | 5,081 | 5,159 | 5,312 | 5,458 | 5,494 | 5,505 | 5,617 | 5,673 | 5,882 | 5,986 | 5,951 | 6,038 | 6,083 | 6,198 |
| DPL | 2,611 | 2,611 | 2,634 | 2,667 | 2,712 | 2,755 | 2,762 | 2,779 | 2,812 | 2,835 | 2,892 | 2,927 | 2,914 | 2,958 | 3,005 | 3,047 |
| JCPL | 3,378 | 3,461 | 3,589 | 3,674 | 3,749 | 3,843 | 3,844 | 3,874 | 3,927 | 3,964 | 4,063 | 4,097 | 4,079 | 4,116 | 4,178 | 4,228 |
| METED | 2,252 | 2,298 | 2,372 | 2,430 | 2,482 | 2,521 | 2,522 | 2,537 | 2,570 | 2,592 | 2,635 | 2,653 | 2,647 | 2,673 | 2,699 | 2,734 |
| PECO | 5,583 | 5,619 | 5,833 | 5,958 | 6,089 | 6,226 | 6,193 | 6,208 | 6,296 | 6,333 | 6,476 | 6,526 | 6,435 | 6,464 | 6,496 | 6,561 |
| PENLC | 2,470 | 2,520 | 2,603 | 2,662 | 2,728 | 2,791 | 2,816 | 2,856 | 2,906 | 2,950 | 3,019 | 3,060 | 3,070 | 3,115 | 3,154 | 3,205 |
| PEPCO | 4,568 | 4,575 | 4,643 | 4,725 | 4,800 | 4,869 | 4,866 | 4,877 | 4,953 | 4,994 | 5,108 | 5,182 | 5,136 | 5,153 | 5,227 | 5,301 |
| PL | 5,784 | 5,884 | 6,064 | 6,191 | 6,307 | 6,399 | 6,412 | 6,433 | 6,495 | 6,524 | 6,620 | 6,657 | 6,627 | 6,661 | 6,695 | 6,759 |
| PS | 6,445 | 6,496 | 6,670 | 6,799 | 6,922 | 7,079 | 7,051 | 7,083 | 7,199 | 7,240 | 7,424 | 7,458 | 7,427 | 7,444 | 7,519 | 7,627 |
| RECO | 220 | 221 | 224 | 226 | 230 | 232 | 234 | 236 | 237 | 239 | 241 | 243 | 244 | 246 | 248 | 250 |
| UGI | 150 | 153 | 156 | 159 | 161 | 163 | 163 | 163 | 164 | 164 | 166 | 166 | 165 | 165 | 166 | 167 |
| DIVERSITY - MID-ATLANTIC (-) | 2,040 | 1,938 | 1,640 | 1,407 | 1,643 | 2,001 | 1,893 | 1,734 | 1,581 | 1,364 | 2,018 | 2,276 | 1,754 | 1,732 | 1,476 | 1,719 |
| PJM MID-ATLANTIC | 37,881 | 38,532 | 39,922 | 41,000 | 41,661 | 42,183 | 42,329 | 42,699 | 43,509 | 44,082 | 44,488 | 44,670 | 44,935 | 45,313 | 46,045 | 46,431 |
| FE/GPU | 7,773 | 7,930 | 8,277 | 8,536 | 8,720 | 8,869 | 8,915 | 9,018 | 9,169 | 9,311 | 9,469 | 9,575 | 9,596 | 9,674 | 9,826 | 9,988 |
| PLGRP | 5,750 | 5,883 | 6,084 | 6,242 | 6,334 | 6,393 | 6,448 | 6,492 | 6,552 | 6,598 | 6,636 | 6,667 | 6,702 | 6,719 | 6,779 | 6,824 |

Table B-3
SPRING (APRIL) PEAK LOAD (MW) FOR
EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO
2010-2025

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|-------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| AEP | 18,456 | 18,802 | 19,379 | 19,717 | 19,977 | 20,245 | 20,314 | 20,376 | 20,576 | 20,628 | 20,829 | 20,962 | 20,977 | 21,025 | 21,030 | 21,193 |
| APS | 6,911 | 7,049 | 7,208 | 7,331 | 7,449 | 7,546 | 7,563 | 7,610 | 7,703 | 7,770 | 7,902 | 7,966 | 7,960 | 8,047 | 8,134 | 8,231 |
| ATSI | 9,530 | 9,499 | 9,818 | 10,028 | 10,149 | 10,359 | 10,306 | 10,321 | 10,434 | 10,456 | 10,636 | 10,685 | 10,542 | 10,573 | 10,653 | 10,661 |
| COMED | 13,703 | 14,043 | 14,941 | 15,594 | 16,015 | 16,457 | 16,516 | 16,673 | 17,172 | 17,435 | 17,836 | 18,018 | 17,859 | 17,870 | 18,343 | 18,508 |
| DAY | 2,452 | 2,473 | 2,567 | 2,622 | 2,650 | 2,686 | 2,678 | 2,671 | 2,687 | 2,685 | 2,714 | 2,718 | 2,693 | 2,692 | 2,698 | 2,707 |
| DLCO | 1,953 | 1,953 | 1,989 | 2,036 | 2,073 | 2,116 | 2,111 | 2,104 | 2,157 | 2,180 | 2,226 | 2,251 | 2,216 | 2,235 | 2,281 | 2,297 |
| DIVERSITY - WESTERN (-) | 1,898 | 2,031 | 2,120 | 2,087 | 1,976 | 2,656 | 2,362 | 2,455 | 2,373 | 2,403 | 2,717 | 2,940 | 2,394 | 2,527 | 2,467 | 2,441 |
| PJM WESTERN (with ATSI) | 51,107 | 51,788 | 53,782 | 55,241 | 56,337 | 56,753 | 57,126 | 57,300 | 58,356 | 58,751 | 59,426 | 59,660 | 59,853 | 59,915 | 60,672 | 61,156 |
| DIVERSITY - WESTERN (-) | 1,697 | 1,891 | 1,981 | 2,013 | 2,214 | 2,439 | 2,330 | 2,155 | 2,373 | 2,321 | 2,466 | 2,505 | 2,467 | 2,230 | 2,262 | 2,529 |
| PJM WESTERN (without ATSI) | 41,778 | 42,429 | 44,103 | 45,287 | 45,950 | 46,611 | 46,852 | 47,279 | 47,922 | 48,377 | 49,041 | 49,410 | 49,238 | 49,639 | 50,224 | 50,407 |
| DOM | 13,628 | 13,918 | 14,439 | 14,833 | 15,202 | 15,631 | 15,789 | 16,041 | 16,424 | 16,736 | 17,137 | 17,513 | 17,675 | 18,068 | 18,489 | 18,926 |
| DIVERSITY - INTERREGIONAL (-) | 1,950 | 1,822 | 2,050 | 2,097 | 2,577 | 2,276 | 2,133 | 1,893 | 2,239 | 2,292 | 2,053 | 1,729 | 2,446 | 2,366 | 2,322 | 2,784 |
| PJM RTO (with ATSI) | 100,666 | 102,416 | 106,093 | 108,977 | 110,623 | 112,291 | 113,111 | 114,147 | 116,050 | 117,277 | 118,998 | 120,114 | 120,017 | 120,930 | 122,884 | 123,729 |
| DIVERSITY - INTERREGIONAL (-) | 1,707 | 1,838 | 1,919 | 1,807 | 2,174 | 1,822 | 1,704 | 1,895 | 2,234 | 2,361 | 1,755 | 1,799 | 2,261 | 2,523 | 2,438 | 2,252 |
| PJM RTO (without ATSI) | 91,580 | 93,041 | 96,545 | 99,313 | 100,639 | 102,603 | 103,266 | 104,124 | 105,621 | 106,834 | 108,911 | 109,794 | 109,587 | 110,497 | 112,320 | 113,512 |

Table B-4

**FALL (OCTOBER) PEAK LOAD (MW) FOR
EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION
2010-2025**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|------------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| AE | 1,581 | 1,711 | 1,826 | 1,891 | 1,927 | 1,955 | 1,981 | 2,019 | 2,063 | 2,088 | 2,096 | 2,111 | 2,137 | 2,173 | 2,206 | 2,228 |
| BGE | 4,748 | 4,880 | 5,037 | 5,102 | 5,195 | 5,242 | 5,309 | 5,436 | 5,584 | 5,670 | 5,688 | 5,728 | 5,830 | 5,962 | 6,079 | 6,146 |
| DPL | 2,525 | 2,573 | 2,648 | 2,679 | 2,701 | 2,716 | 2,740 | 2,781 | 2,842 | 2,871 | 2,871 | 2,890 | 2,928 | 2,992 | 3,042 | 3,072 |
| JCPL | 3,505 | 3,647 | 3,852 | 3,939 | 3,996 | 4,040 | 4,068 | 4,153 | 4,249 | 4,299 | 4,310 | 4,327 | 4,376 | 4,449 | 4,536 | 4,574 |
| METED | 2,141 | 2,222 | 2,316 | 2,365 | 2,394 | 2,410 | 2,434 | 2,468 | 2,505 | 2,528 | 2,529 | 2,538 | 2,568 | 2,605 | 2,639 | 2,659 |
| PECO | 5,525 | 5,710 | 6,022 | 6,129 | 6,184 | 6,239 | 6,273 | 6,372 | 6,496 | 6,532 | 6,518 | 6,520 | 6,550 | 6,630 | 6,715 | 6,731 |
| PENLC | 2,451 | 2,543 | 2,638 | 2,690 | 2,719 | 2,768 | 2,827 | 2,880 | 2,938 | 2,980 | 2,996 | 3,026 | 3,091 | 3,137 | 3,186 | 3,211 |
| PEPCO | 4,636 | 4,668 | 4,879 | 4,928 | 4,957 | 4,980 | 4,951 | 5,061 | 5,172 | 5,218 | 5,221 | 5,237 | 5,246 | 5,357 | 5,450 | 5,492 |
| PL | 5,595 | 5,770 | 5,956 | 6,054 | 6,100 | 6,149 | 6,192 | 6,266 | 6,320 | 6,371 | 6,360 | 6,369 | 6,422 | 6,477 | 6,531 | 6,533 |
| PS | 6,735 | 6,911 | 7,230 | 7,367 | 7,421 | 7,476 | 7,467 | 7,622 | 7,744 | 7,832 | 7,825 | 7,809 | 7,852 | 8,006 | 8,126 | 8,157 |
| RECO | 237 | 241 | 252 | 254 | 255 | 255 | 253 | 258 | 264 | 265 | 263 | 261 | 262 | 267 | 272 | 272 |
| UGI | 148 | 153 | 157 | 160 | 161 | 161 | 162 | 164 | 164 | 164 | 164 | 164 | 165 | 166 | 166 | 166 |
| DIVERSITY - MID-ATLANTIC (-) | 1,183 | 1,265 | 1,480 | 1,464 | 1,440 | 1,316 | 1,352 | 1,438 | 1,501 | 1,557 | 1,374 | 1,337 | 1,649 | 1,597 | 1,614 | 1,624 |
| PJM MID-ATLANTIC | 38,644 | 39,764 | 41,333 | 42,094 | 42,570 | 43,075 | 43,305 | 44,042 | 44,840 | 45,261 | 45,467 | 45,643 | 45,778 | 46,624 | 47,334 | 47,617 |
| FE/GPU | 7,935 | 8,210 | 8,549 | 8,732 | 8,871 | 8,993 | 9,092 | 9,242 | 9,379 | 9,497 | 9,569 | 9,629 | 9,736 | 9,869 | 10,039 | 10,145 |
| PLGRP | 5,727 | 5,904 | 6,069 | 6,173 | 6,225 | 6,282 | 6,341 | 6,403 | 6,447 | 6,494 | 6,499 | 6,525 | 6,574 | 6,610 | 6,653 | 6,660 |

Table B-4

**FALL (OCTOBER) PEAK LOAD (MW) FOR
EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO
2010-2025**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|-------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| AEP | 17,776 | 18,320 | 18,963 | 19,152 | 19,325 | 19,383 | 19,468 | 19,650 | 19,854 | 19,964 | 19,936 | 19,925 | 20,080 | 20,253 | 20,454 | 20,516 |
| APS | 6,635 | 6,826 | 7,028 | 7,099 | 7,183 | 7,219 | 7,282 | 7,371 | 7,481 | 7,529 | 7,570 | 7,614 | 7,697 | 7,801 | 7,893 | 7,967 |
| ATSI | 9,061 | 9,361 | 9,719 | 9,867 | 9,956 | 10,005 | 10,068 | 10,175 | 10,266 | 10,321 | 10,299 | 10,304 | 10,349 | 10,420 | 10,484 | 10,508 |
| COMED | 13,561 | 14,333 | 15,333 | 15,758 | 16,088 | 16,361 | 16,528 | 16,879 | 17,251 | 17,529 | 17,663 | 17,736 | 17,834 | 18,080 | 18,309 | 18,427 |
| DAY | 2,363 | 2,463 | 2,580 | 2,612 | 2,632 | 2,633 | 2,636 | 2,656 | 2,680 | 2,683 | 2,665 | 2,657 | 2,664 | 2,680 | 2,698 | 2,702 |
| DLCO | 1,888 | 1,923 | 1,992 | 2,024 | 2,049 | 2,065 | 2,074 | 2,111 | 2,147 | 2,169 | 2,175 | 2,175 | 2,193 | 2,227 | 2,256 | 2,273 |
| DIVERSITY - WESTERN (-) | 1,277 | 1,236 | 1,600 | 1,559 | 1,631 | 1,546 | 1,389 | 1,527 | 1,800 | 1,829 | 1,729 | 1,610 | 1,565 | 1,754 | 1,971 | 2,023 |
| PJM WESTERN (with ATSI) | 50,007 | 51,990 | 54,015 | 54,953 | 55,602 | 56,120 | 56,667 | 57,315 | 57,879 | 58,366 | 58,579 | 58,801 | 59,252 | 59,707 | 60,123 | 60,370 |
| DIVERSITY - WESTERN (-) | 1,048 | 1,050 | 1,408 | 1,328 | 1,418 | 1,301 | 1,198 | 1,304 | 1,519 | 1,581 | 1,459 | 1,425 | 1,357 | 1,518 | 1,711 | 1,759 |
| PJM WESTERN (without ATSI) | 41,175 | 42,815 | 44,488 | 45,317 | 45,859 | 46,360 | 46,790 | 47,363 | 47,894 | 48,293 | 48,550 | 48,682 | 49,111 | 49,523 | 49,899 | 50,126 |
| DOM | 13,646 | 14,234 | 14,938 | 15,269 | 15,549 | 15,801 | 16,079 | 16,444 | 16,853 | 17,180 | 17,403 | 17,680 | 18,057 | 18,472 | 18,913 | 19,257 |
| DIVERSITY - INTERREGIONAL (-) | 1,590 | 1,644 | 2,017 | 1,882 | 1,947 | 1,904 | 1,962 | 1,999 | 2,034 | 2,073 | 1,967 | 2,213 | 2,101 | 1,992 | 2,097 | 1,994 |
| PJM RTO (with ATSI) | 100,707 | 104,344 | 108,269 | 110,434 | 111,774 | 113,092 | 114,089 | 115,802 | 117,538 | 118,734 | 119,482 | 119,911 | 120,986 | 122,811 | 124,273 | 125,250 |
| DIVERSITY - INTERREGIONAL (-) | 1,426 | 1,535 | 1,678 | 1,670 | 1,639 | 1,716 | 1,896 | 1,734 | 1,891 | 1,824 | 1,734 | 1,760 | 1,798 | 1,777 | 1,854 | 1,876 |
| PJM RTO (without ATSI) | 92,039 | 95,278 | 99,081 | 101,010 | 102,339 | 103,520 | 104,278 | 106,115 | 107,696 | 108,910 | 109,686 | 110,245 | 111,148 | 112,842 | 114,292 | 115,124 |

Table B-5

**MONTHLY PEAK FORECAST (MW) FOR EACH
PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION**

| | AE | BGE | DPL | JCPL | METED | PECO | PENLC | PEPCO | PL | PS | RECO | UGI | MID-ATLANTIC DIVERSITY | PJM MID- ATLANTIC |
|----------|-----------|------------|------------|-------------|--------------|-------------|--------------|--------------|-----------|-----------|-------------|------------|-----------------------------------|------------------------------|
| Jan 2010 | 1,773 | 6,022 | 3,301 | 3,981 | 2,571 | 6,503 | 2,796 | 5,481 | 7,169 | 6,982 | 228 | 194 | 591 | 46,410 |
| Feb 2010 | 1,707 | 5,817 | 3,187 | 3,804 | 2,513 | 6,305 | 2,736 | 5,287 | 6,964 | 6,741 | 217 | 186 | 612 | 44,852 |
| Mar 2010 | 1,576 | 5,297 | 2,884 | 3,583 | 2,390 | 5,903 | 2,598 | 4,729 | 6,338 | 6,441 | 214 | 169 | 1,350 | 40,772 |
| Apr 2010 | 1,505 | 4,955 | 2,611 | 3,378 | 2,252 | 5,583 | 2,470 | 4,568 | 5,784 | 6,445 | 220 | 150 | 2,040 | 37,881 |
| May 2010 | 1,812 | 5,737 | 2,979 | 4,489 | 2,399 | 6,542 | 2,379 | 5,585 | 5,779 | 8,303 | 325 | 144 | 1,821 | 44,652 |
| Jun 2010 | 2,399 | 6,851 | 3,660 | 5,830 | 2,788 | 8,041 | 2,749 | 6,613 | 6,768 | 10,161 | 399 | 176 | 500 | 55,935 |
| Jul 2010 | 2,734 | 7,456 | 4,023 | 6,440 | 2,920 | 8,528 | 2,843 | 7,048 | 7,161 | 10,921 | 435 | 190 | 530 | 60,169 |
| Aug 2010 | 2,612 | 7,133 | 3,825 | 5,847 | 2,825 | 8,265 | 2,791 | 6,763 | 6,902 | 10,126 | 389 | 181 | 308 | 57,351 |
| Sep 2010 | 2,197 | 6,373 | 3,309 | 5,064 | 2,507 | 7,151 | 2,602 | 6,058 | 6,297 | 9,026 | 337 | 163 | 735 | 50,349 |
| Oct 2010 | 1,581 | 4,748 | 2,525 | 3,505 | 2,141 | 5,525 | 2,451 | 4,636 | 5,595 | 6,735 | 237 | 148 | 1,183 | 38,644 |
| Nov 2010 | 1,562 | 4,927 | 2,675 | 3,568 | 2,275 | 5,712 | 2,589 | 4,533 | 6,117 | 6,461 | 219 | 167 | 446 | 40,359 |
| Dec 2010 | 1,807 | 5,765 | 3,150 | 4,064 | 2,558 | 6,417 | 2,823 | 5,259 | 6,952 | 7,069 | 237 | 195 | 420 | 45,876 |
| | | | | | | | | | | | | | | |
| | AE | BGE | DPL | JCPL | METED | PECO | PENLC | PEPCO | PL | PS | RECO | UGI | DIVERSITY | MID-ATLANTIC |
| Jan 2011 | 1,817 | 6,116 | 3,339 | 4,066 | 2,640 | 6,587 | 2,863 | 5,553 | 7,284 | 7,091 | 230 | 197 | 480 | 47,303 |
| Feb 2011 | 1,746 | 5,873 | 3,218 | 3,875 | 2,573 | 6,354 | 2,793 | 5,347 | 7,071 | 6,834 | 219 | 188 | 256 | 45,835 |
| Mar 2011 | 1,624 | 5,349 | 2,872 | 3,653 | 2,434 | 5,888 | 2,652 | 4,750 | 6,430 | 6,494 | 216 | 171 | 1,256 | 41,277 |
| Apr 2011 | 1,588 | 5,044 | 2,611 | 3,461 | 2,298 | 5,619 | 2,520 | 4,575 | 5,884 | 6,496 | 221 | 153 | 1,938 | 38,532 |
| May 2011 | 1,922 | 5,891 | 3,017 | 4,633 | 2,464 | 6,675 | 2,444 | 5,656 | 5,957 | 8,464 | 331 | 147 | 1,722 | 45,879 |
| Jun 2011 | 2,518 | 7,042 | 3,713 | 5,985 | 2,863 | 8,161 | 2,807 | 6,710 | 6,927 | 10,365 | 410 | 179 | 272 | 57,408 |
| Jul 2011 | 2,897 | 7,656 | 4,089 | 6,625 | 3,006 | 8,700 | 2,908 | 7,144 | 7,345 | 11,147 | 444 | 194 | 488 | 61,667 |
| Aug 2011 | 2,768 | 7,321 | 3,882 | 6,041 | 2,901 | 8,428 | 2,860 | 6,883 | 7,083 | 10,358 | 399 | 185 | 122 | 58,987 |
| Sep 2011 | 2,323 | 6,521 | 3,354 | 5,200 | 2,579 | 7,282 | 2,666 | 6,132 | 6,434 | 9,201 | 342 | 167 | 587 | 51,614 |
| Oct 2011 | 1,711 | 4,880 | 2,573 | 3,647 | 2,222 | 5,710 | 2,543 | 4,668 | 5,770 | 6,911 | 241 | 153 | 1,265 | 39,764 |
| Nov 2011 | 1,669 | 5,030 | 2,717 | 3,695 | 2,354 | 5,892 | 2,682 | 4,614 | 6,286 | 6,627 | 221 | 170 | 471 | 41,486 |
| Dec 2011 | 1,907 | 5,853 | 3,199 | 4,183 | 2,637 | 6,576 | 2,908 | 5,353 | 7,108 | 7,230 | 239 | 197 | 444 | 46,946 |
| | | | | | | | | | | | | | | |
| | AE | BGE | DPL | JCPL | METED | PECO | PENLC | PEPCO | PL | PS | RECO | UGI | DIVERSITY | MID-ATLANTIC |
| Jan 2012 | 1,915 | 6,195 | 3,382 | 4,183 | 2,723 | 6,775 | 2,952 | 5,656 | 7,447 | 7,248 | 232 | 200 | 481 | 48,427 |
| Feb 2012 | 1,846 | 5,958 | 3,264 | 3,995 | 2,657 | 6,547 | 2,884 | 5,458 | 7,222 | 6,999 | 221 | 191 | 323 | 46,919 |
| Mar 2012 | 1,719 | 5,348 | 2,874 | 3,747 | 2,488 | 6,021 | 2,728 | 4,800 | 6,584 | 6,604 | 217 | 173 | 1,111 | 42,192 |
| Apr 2012 | 1,693 | 5,081 | 2,634 | 3,589 | 2,372 | 5,833 | 2,603 | 4,643 | 6,064 | 6,670 | 224 | 156 | 1,640 | 39,922 |
| May 2012 | 2,059 | 6,003 | 3,054 | 4,839 | 2,551 | 6,943 | 2,535 | 5,773 | 6,185 | 8,719 | 339 | 152 | 1,495 | 47,657 |
| Jun 2012 | 2,677 | 7,169 | 3,767 | 6,205 | 2,950 | 8,435 | 2,898 | 6,861 | 7,126 | 10,588 | 417 | 184 | 968 | 58,309 |
| Jul 2012 | 3,032 | 7,781 | 4,153 | 6,843 | 3,112 | 8,991 | 2,994 | 7,273 | 7,554 | 11,427 | 452 | 199 | 599 | 63,212 |
| Aug 2012 | 2,902 | 7,497 | 3,960 | 6,254 | 3,008 | 8,720 | 2,953 | 7,076 | 7,308 | 10,626 | 407 | 190 | 442 | 60,459 |
| Sep 2012 | 2,442 | 6,620 | 3,398 | 5,373 | 2,665 | 7,517 | 2,743 | 6,222 | 6,612 | 9,368 | 348 | 171 | 733 | 52,746 |
| Oct 2012 | 1,826 | 5,037 | 2,648 | 3,852 | 2,316 | 6,022 | 2,638 | 4,879 | 5,956 | 7,230 | 252 | 157 | 1,480 | 41,333 |
| Nov 2012 | 1,749 | 5,101 | 2,764 | 3,828 | 2,436 | 6,094 | 2,767 | 4,706 | 6,442 | 6,805 | 223 | 174 | 523 | 42,566 |
| Dec 2012 | 1,969 | 5,906 | 3,207 | 4,275 | 2,706 | 6,727 | 2,985 | 5,421 | 7,220 | 7,355 | 241 | 200 | 397 | 47,815 |

Table B-5

**MONTHLY PEAK FORECAST (MW) FOR EACH
EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO**

| | | | | | | | WESTERN DIVERSITY | PJM WESTERN | WESTERN DIVERSITY | PJM WESTERN | | INTERREGION DIVERSITY | PJM RTO | INTERREGION DIVERSITY | PJM RTO |
|----------|--------|-------|--------|--------|-------|-------|----------------------|----------------|----------------------|----------------|--------|--------------------------|----------|--------------------------|-----------|
| | AEP | APS | ATSI | COMED | DAY | DLCO | (w ATSI) | (w ATSI) | (wo ATSI) | (wo ATSI) | DOM | (w ATSI) | (w ATSI) | (wo ATSI) | (wo ATSI) |
| Jan 2010 | 22,310 | 8,449 | 10,518 | 15,431 | 2,918 | 2,137 | 1,122 | 60,641 | 980 | 50,265 | 17,169 | 1,091 | 123,129 | 1,102 | 112,742 |
| Feb 2010 | 21,645 | 8,183 | 10,311 | 14,977 | 2,805 | 2,069 | 1,135 | 58,855 | 1,008 | 48,671 | 16,562 | 1,621 | 118,648 | 1,477 | 108,608 |
| Mar 2010 | 19,978 | 7,482 | 9,965 | 14,028 | 2,585 | 1,973 | 1,093 | 54,918 | 1,153 | 44,893 | 14,729 | 1,452 | 108,967 | 1,181 | 99,213 |
| Apr 2010 | 18,456 | 6,911 | 9,530 | 13,703 | 2,452 | 1,953 | 1,898 | 51,107 | 1,697 | 41,778 | 13,628 | 1,950 | 100,666 | 1,707 | 91,580 |
| May 2010 | 19,111 | 6,896 | 10,025 | 16,161 | 2,644 | 2,250 | 1,970 | 55,117 | 1,683 | 45,379 | 15,589 | 3,572 | 111,786 | 3,263 | 102,357 |
| Jun 2010 | 22,415 | 8,295 | 12,482 | 20,721 | 3,179 | 2,757 | 2,104 | 67,745 | 1,704 | 55,663 | 18,493 | 4,263 | 137,910 | 3,457 | 126,634 |
| Jul 2010 | 23,287 | 8,661 | 13,040 | 22,536 | 3,368 | 2,883 | 1,684 | 72,091 | 1,409 | 59,326 | 19,779 | 4,248 | 147,791 | 3,524 | 135,750 |
| Aug 2010 | 22,851 | 8,366 | 12,489 | 21,527 | 3,283 | 2,774 | 1,766 | 69,524 | 1,053 | 57,748 | 19,159 | 4,943 | 141,091 | 4,561 | 129,697 |
| Sep 2010 | 20,817 | 7,700 | 11,096 | 18,601 | 2,950 | 2,520 | 1,471 | 62,213 | 1,329 | 51,259 | 16,906 | 3,483 | 125,985 | 3,209 | 115,305 |
| Oct 2010 | 17,776 | 6,635 | 9,061 | 13,561 | 2,363 | 1,888 | 1,277 | 50,007 | 1,048 | 41,175 | 13,646 | 1,590 | 100,707 | 1,426 | 92,039 |
| Nov 2010 | 19,081 | 7,192 | 9,538 | 13,975 | 2,509 | 1,941 | 596 | 53,640 | 594 | 44,104 | 13,945 | 696 | 107,248 | 624 | 97,784 |
| Dec 2010 | 21,607 | 8,271 | 10,616 | 15,862 | 2,843 | 2,146 | 1,133 | 60,212 | 998 | 49,731 | 16,436 | 1,307 | 121,217 | 1,202 | 110,841 |
| | | | | | | | | | | | | | | | |
| | AEP | APS | ATSI | COMED | DAY | DLCO | DIVERSITY | WESTERN | DIVERSITY | WESTERN | DOM | DIVERSITY | PJM RTO | DIVERSITY | PJM RTO |
| Jan 2011 | 22,597 | 8,646 | 10,654 | 15,798 | 2,958 | 2,149 | 1,182 | 61,620 | 1,057 | 51,091 | 17,540 | 1,281 | 125,182 | 1,188 | 114,746 |
| Feb 2011 | 21,857 | 8,347 | 10,408 | 15,282 | 2,841 | 2,075 | 1,171 | 59,639 | 1,020 | 49,382 | 16,927 | 1,951 | 120,450 | 1,789 | 110,355 |
| Mar 2011 | 20,225 | 7,624 | 9,884 | 14,193 | 2,597 | 1,969 | 1,174 | 55,318 | 1,334 | 45,274 | 14,958 | 1,200 | 110,353 | 1,072 | 100,437 |
| Apr 2011 | 18,802 | 7,049 | 9,499 | 14,043 | 2,473 | 1,953 | 2,031 | 51,788 | 1,891 | 42,429 | 13,918 | 1,822 | 102,416 | 1,838 | 93,041 |
| May 2011 | 19,683 | 7,076 | 10,201 | 16,742 | 2,713 | 2,278 | 1,796 | 56,897 | 1,537 | 46,955 | 16,077 | 3,364 | 115,489 | 3,011 | 105,900 |
| Jun 2011 | 22,989 | 8,486 | 12,686 | 21,379 | 3,269 | 2,786 | 2,027 | 69,568 | 1,697 | 57,212 | 19,081 | 4,473 | 141,584 | 3,742 | 129,959 |
| Jul 2011 | 23,856 | 8,872 | 13,338 | 23,372 | 3,479 | 2,921 | 1,739 | 74,099 | 1,377 | 61,123 | 20,488 | 4,226 | 152,028 | 3,624 | 139,654 |
| Aug 2011 | 23,487 | 8,570 | 12,789 | 22,396 | 3,391 | 2,814 | 1,750 | 71,697 | 892 | 59,766 | 19,867 | 5,123 | 145,428 | 5,041 | 133,579 |
| Sep 2011 | 21,289 | 7,824 | 11,337 | 19,338 | 3,044 | 2,548 | 1,397 | 63,983 | 1,316 | 52,727 | 17,506 | 3,770 | 129,333 | 3,390 | 118,457 |
| Oct 2011 | 18,320 | 6,826 | 9,361 | 14,333 | 2,463 | 1,923 | 1,236 | 51,990 | 1,050 | 42,815 | 14,234 | 1,644 | 104,344 | 1,535 | 95,278 |
| Nov 2011 | 19,588 | 7,381 | 9,817 | 14,711 | 2,595 | 1,977 | 697 | 55,372 | 661 | 45,591 | 14,466 | 713 | 110,611 | 718 | 100,825 |
| Dec 2011 | 22,133 | 8,460 | 10,898 | 16,567 | 2,922 | 2,182 | 1,131 | 62,031 | 1,016 | 51,248 | 17,032 | 1,460 | 124,549 | 1,354 | 113,872 |
| | | | | | | | | | | | | | | | |
| | AEP | APS | ATSI | COMED | DAY | DLCO | DIVERSITY | WESTERN | DIVERSITY | WESTERN | DOM | DIVERSITY | PJM RTO | DIVERSITY | PJM RTO |
| Jan 2012 | 23,115 | 8,840 | 10,925 | 16,491 | 3,029 | 2,176 | 1,162 | 63,414 | 1,076 | 52,575 | 18,154 | 1,364 | 128,631 | 1,244 | 117,912 |
| Feb 2012 | 22,411 | 8,542 | 10,692 | 15,999 | 2,920 | 2,109 | 1,229 | 61,444 | 1,095 | 50,886 | 17,549 | 1,948 | 123,964 | 1,802 | 113,552 |
| Mar 2012 | 20,710 | 7,773 | 10,130 | 14,864 | 2,676 | 1,986 | 1,249 | 56,890 | 1,315 | 46,694 | 15,302 | 1,683 | 112,701 | 1,364 | 102,824 |
| Apr 2012 | 19,379 | 7,208 | 9,818 | 14,941 | 2,567 | 1,989 | 2,120 | 53,782 | 1,981 | 44,103 | 14,439 | 2,050 | 106,093 | 1,919 | 96,545 |
| May 2012 | 20,448 | 7,251 | 10,603 | 17,765 | 2,844 | 2,339 | 1,999 | 59,251 | 1,574 | 49,073 | 16,790 | 3,928 | 119,770 | 3,631 | 109,889 |
| Jun 2012 | 23,716 | 8,631 | 13,089 | 22,634 | 3,412 | 2,867 | 2,488 | 71,861 | 1,918 | 59,342 | 19,885 | 3,846 | 146,209 | 3,741 | 133,795 |
| Jul 2012 | 24,649 | 9,057 | 13,801 | 24,460 | 3,628 | 2,995 | 1,936 | 76,654 | 1,466 | 63,323 | 21,365 | 4,064 | 157,167 | 3,474 | 144,426 |
| Aug 2012 | 24,299 | 8,756 | 13,284 | 23,680 | 3,540 | 2,907 | 2,134 | 74,332 | 1,266 | 61,916 | 20,727 | 5,128 | 150,390 | 4,931 | 138,171 |
| Sep 2012 | 21,671 | 7,981 | 11,598 | 20,304 | 3,155 | 2,592 | 1,769 | 65,532 | 1,518 | 54,185 | 18,211 | 4,339 | 132,150 | 3,841 | 121,301 |
| Oct 2012 | 18,963 | 7,028 | 9,719 | 15,333 | 2,580 | 1,992 | 1,600 | 54,015 | 1,408 | 44,488 | 14,938 | 2,017 | 108,269 | 1,678 | 99,081 |
| Nov 2012 | 20,143 | 7,565 | 10,138 | 15,463 | 2,683 | 2,021 | 863 | 57,150 | 880 | 46,995 | 15,042 | 860 | 113,898 | 783 | 103,820 |
| Dec 2012 | 22,392 | 8,598 | 11,122 | 17,142 | 2,997 | 2,206 | 867 | 63,590 | 761 | 52,574 | 17,534 | 1,455 | 127,484 | 1,297 | 116,626 |

Table B-6

**MONTHLY PEAK FORECAST (MW)
FOR FE/GPU AND PLGRP**

| | FE/GPU | PLGRP |
|----------|---------------|--------------|
| Jan 2010 | 9,282 | 7,342 |
| Feb 2010 | 8,987 | 7,135 |
| Mar 2010 | 8,311 | 6,367 |
| Apr 2010 | 7,773 | 5,750 |
| May 2010 | 8,937 | 5,804 |
| Jun 2010 | 11,062 | 6,909 |
| Jul 2010 | 12,038 | 7,314 |
| Aug 2010 | 11,291 | 7,083 |
| Sep 2010 | 10,023 | 6,459 |
| Oct 2010 | 7,935 | 5,727 |
| Nov 2010 | 8,363 | 6,279 |
| Dec 2010 | 9,417 | 7,131 |
| | | |
| | FE/GPU | PLGRP |
| Jan 2011 | 9,508 | 7,466 |
| Feb 2011 | 9,215 | 7,258 |
| Mar 2011 | 8,459 | 6,489 |
| Apr 2011 | 7,930 | 5,883 |
| May 2011 | 9,253 | 6,015 |
| Jun 2011 | 11,422 | 7,103 |
| Jul 2011 | 12,389 | 7,510 |
| Aug 2011 | 11,663 | 7,267 |
| Sep 2011 | 10,311 | 6,600 |
| Oct 2011 | 8,210 | 5,904 |
| Nov 2011 | 8,652 | 6,449 |
| Dec 2011 | 9,695 | 7,291 |
| | | |
| | FE/GPU | PLGRP |
| Jan 2012 | 9,794 | 7,632 |
| Feb 2012 | 9,493 | 7,413 |
| Mar 2012 | 8,726 | 6,665 |
| Apr 2012 | 8,277 | 6,084 |
| May 2012 | 9,647 | 6,249 |
| Jun 2012 | 11,797 | 7,266 |
| Jul 2012 | 12,814 | 7,721 |
| Aug 2012 | 12,070 | 7,498 |
| Sep 2012 | 10,592 | 6,771 |
| Oct 2012 | 8,549 | 6,069 |
| Nov 2012 | 8,938 | 6,598 |
| Dec 2012 | 9,950 | 7,417 |

Note: FE/GPU contains JCPL, METED, and PENLC zones; PLGRP contains PL and UGI zones.

THIS PAGE INTENTIONALLY LEFT BLANK

TABLE B-7

**PJM MID-ATLANTIC REGION LOAD MANAGEMENT
PLACED UNDER PJM COORDINATION - SUMMER (MW)**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|-----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| AE | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 40 | 25 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 |
| DIRECT CONTROL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL LOAD MANAGEMENT | 40 | 25 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 |
| BGE | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 485 | 591 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 | 1,029 |
| DIRECT CONTROL | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 |
| TOTAL LOAD MANAGEMENT | 727 | 833 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 |
| DPL | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 73 | 89 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 |
| DIRECT CONTROL | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 |
| TOTAL LOAD MANAGEMENT | 99 | 115 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 |
| JCPL | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 131 | 102 | 288 | 288 | 288 | 288 | 288 | 288 | 288 | 288 | 288 | 288 | 288 | 288 | 288 | 288 |
| DIRECT CONTROL | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| TOTAL LOAD MANAGEMENT | 155 | 126 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 |
| METED | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 132 | 116 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 | 242 |
| DIRECT CONTROL | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 |
| TOTAL LOAD MANAGEMENT | 134 | 118 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 |
| PECO | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 284 | 283 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 |
| DIRECT CONTROL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL LOAD MANAGEMENT | 284 | 283 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 |
| PENLC | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 83 | 67 | 260 | 260 | 260 | 260 | 260 | 260 | 260 | 260 | 260 | 260 | 260 | 260 | 260 | 260 |
| DIRECT CONTROL | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 | 8 |
| TOTAL LOAD MANAGEMENT | 91 | 75 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 |
| PEPCO | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 50 | 158 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 |
| DIRECT CONTROL | 13 | 13 | 13 | 13 | 13 | 13 | 13 | 13 | 13 | 13 | 13 | 13 | 13 | 13 | 13 | 13 |
| TOTAL LOAD MANAGEMENT | 63 | 171 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 |
| PL | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 357 | 379 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 |
| DIRECT CONTROL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL LOAD MANAGEMENT | 357 | 379 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 |
| PS | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 166 | 123 | 383 | 383 | 383 | 383 | 383 | 383 | 383 | 383 | 383 | 383 | 383 | 383 | 383 | 383 |
| DIRECT CONTROL | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 |
| TOTAL LOAD MANAGEMENT | 228 | 185 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 |
| RECO | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 1 | 1 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 |
| DIRECT CONTROL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL LOAD MANAGEMENT | 1 | 1 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 |
| UGI | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| DIRECT CONTROL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL LOAD MANAGEMENT | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PJM MID-ATLANTIC | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 1,802 | 1,934 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 | 4,197 |
| DIRECT CONTROL | 377 | 377 | 377 | 377 | 377 | 377 | 377 | 377 | 377 | 377 | 377 | 377 | 377 | 377 | 377 | 377 |
| TOTAL LOAD MANAGEMENT | 2,179 | 2,311 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 |

Notes: Forecast represents the amount of Demand Resources cleared in RPM auctions plus the 5-year average of Interruptible Load for Reliability/Active Load Management.

Winter load management is equal to Contractually Interruptible.

TABLE B-7

**PJM WESTERN REGION AND PJM SOUTHERN REGION LOAD MANAGEMENT
PLACED UNDER PJM COORDINATION - SUMMER (MW)**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|-----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| AEP | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 638 | 653 | 664 | 664 | 664 | 664 | 664 | 664 | 664 | 664 | 664 | 664 | 664 | 664 | 664 | 664 |
| DIRECT CONTROL | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| TOTAL LOAD MANAGEMENT | 662 | 677 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 |
| APS | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 187 | 232 | 263 | 263 | 263 | 263 | 263 | 263 | 263 | 263 | 263 | 263 | 263 | 263 | 263 | 263 |
| DIRECT CONTROL | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| TOTAL LOAD MANAGEMENT | 188 | 233 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 |
| ATSI | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| DIRECT CONTROL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL LOAD MANAGEMENT | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| COMED | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 614 | 717 | 571 | 571 | 571 | 571 | 571 | 571 | 571 | 571 | 571 | 571 | 571 | 571 | 571 | 571 |
| DIRECT CONTROL | 66 | 66 | 66 | 66 | 66 | 66 | 66 | 66 | 66 | 66 | 66 | 66 | 66 | 66 | 66 | 66 |
| TOTAL LOAD MANAGEMENT | 680 | 783 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 |
| DAY | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 51 | 65 | 106 | 106 | 106 | 106 | 106 | 106 | 106 | 106 | 106 | 106 | 106 | 106 | 106 | 106 |
| DIRECT CONTROL | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 |
| TOTAL LOAD MANAGEMENT | 54 | 68 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 |
| DLCO | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 40 | 40 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 |
| DIRECT CONTROL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL LOAD MANAGEMENT | 40 | 40 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 |
| PJM WESTERN | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 1,530 | 1,707 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 | 1,676 |
| DIRECT CONTROL | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 |
| TOTAL LOAD MANAGEMENT | 1,624 | 1,801 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 |
| DOM | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 109 | 211 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 |
| DIRECT CONTROL | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 |
| TOTAL LOAD MANAGEMENT | 120 | 222 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 |
| PJM RTO | | | | | | | | | | | | | | | | |
| CONTRACTUALLY INTERRUPTIBLE | 3,441 | 3,852 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 | 6,341 |
| DIRECT CONTROL | 482 | 482 | 482 | 482 | 482 | 482 | 482 | 482 | 482 | 482 | 482 | 482 | 482 | 482 | 482 | 482 |
| TOTAL LOAD MANAGEMENT | 3,923 | 4,334 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 |

Notes: Forecast represents the amount of Demand Resources cleared in RPM auctions plus the 5-year average of Interruptible Load for Reliability/Active Load Management.

Winter load management is equal to Contractually Interruptible.

TABLE B-8

**PJM MID-ATLANTIC REGION ENERGY EFFICIENCY PROGRAMS
AND SUM OF ENERGY EFFICIENCY AND LOAD MANAGEMENT - SUMMER (MW)**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|-------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| AE | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| LOAD MANAGEMENT | 40 | 25 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 |
| TOTAL | 40 | 25 | 74 | 74 | 74 | 74 | 74 | 74 | 74 | 74 | 74 | 74 | 74 | 74 | 74 | 74 |
| BGE | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 |
| LOAD MANAGEMENT | 727 | 833 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 | 1,271 |
| TOTAL | 727 | 833 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 | 1,371 |
| DPL | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 |
| LOAD MANAGEMENT | 99 | 115 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 | 274 |
| TOTAL | 99 | 115 | 286 | 286 | 286 | 286 | 286 | 286 | 286 | 286 | 286 | 286 | 286 | 286 | 286 | 286 |
| JCPL | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 |
| LOAD MANAGEMENT | 155 | 126 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 | 312 |
| TOTAL | 155 | 126 | 314 | 314 | 314 | 314 | 314 | 314 | 314 | 314 | 314 | 314 | 314 | 314 | 314 | 314 |
| METED | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 134 | 118 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 |
| TOTAL | 134 | 118 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 |
| PECO | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 |
| LOAD MANAGEMENT | 284 | 283 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 | 481 |
| TOTAL | 284 | 283 | 483 | 483 | 483 | 483 | 483 | 483 | 483 | 483 | 483 | 483 | 483 | 483 | 483 | 483 |
| PENLC | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 91 | 75 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 |
| TOTAL | 91 | 75 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 | 268 |
| PEPCO | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 |
| LOAD MANAGEMENT | 63 | 171 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 | 446 |
| TOTAL | 63 | 171 | 501 | 501 | 501 | 501 | 501 | 501 | 501 | 501 | 501 | 501 | 501 | 501 | 501 | 501 |
| PL | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 357 | 379 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 |
| TOTAL | 357 | 379 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 | 758 |
| PS | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 |
| LOAD MANAGEMENT | 228 | 185 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 | 445 |
| TOTAL | 228 | 185 | 448 | 448 | 448 | 448 | 448 | 448 | 448 | 448 | 448 | 448 | 448 | 448 | 448 | 448 |
| RECO | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 1 | 1 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 |
| TOTAL | 1 | 1 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 |
| UGI | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PJM MID-ATLANTIC | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 175 | 175 | 175 | 175 | 175 | 175 | 175 | 175 | 175 | 175 | 175 | 175 | 175 | 175 |
| LOAD MANAGEMENT | 2,179 | 2,311 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 | 4,574 |
| TOTAL | 2,179 | 2,311 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 | 4,749 |

Notes: Energy Efficiency values are impacts approved for use in PJM Reliability Pricing Model.
Load Management detail appears in Table B-7.

TABLE B-8

**PJM WESTERN REGION AND PJM SOUTHERN REGION ENERGY EFFICIENCY PROGRAMS
AND SUM OF ENERGY EFFICIENCY AND LOAD MANAGEMENT - SUMMER (MW)**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|-------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| AEP | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 662 | 677 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 |
| TOTAL | 662 | 677 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 | 688 |
| APS | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 188 | 233 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 |
| TOTAL | 188 | 233 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 |
| ATSI | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| COMED | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 |
| LOAD MANAGEMENT | 680 | 783 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 |
| TOTAL | 680 | 783 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 | 1,011 |
| DAY | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 54 | 68 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 |
| TOTAL | 54 | 68 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 | 109 |
| DLCO | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 40 | 40 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 |
| TOTAL | 40 | 40 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 |
| PJM WESTERN | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 | 374 |
| LOAD MANAGEMENT | 1,624 | 1,801 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 | 1,770 |
| TOTAL | 1,624 | 1,801 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 | 2,144 |
| DOM | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| LOAD MANAGEMENT | 120 | 222 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 |
| TOTAL | 120 | 222 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 | 479 |
| PJM RTO | | | | | | | | | | | | | | | | |
| ENERGY EFFICIENCY | 0 | 0 | 549 | 549 | 549 | 549 | 549 | 549 | 549 | 549 | 549 | 549 | 549 | 549 | 549 | 549 |
| LOAD MANAGEMENT | 3,923 | 4,334 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 | 6,823 |
| TOTAL | 3,923 | 4,334 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 | 7,372 |

Notes: Energy Efficiency values are impacts approved for use in PJM Reliability Pricing Model.
Load Management detail appears in Table B-7.

Table B-9

**ADJUSTMENTS TO SUMMER PEAK LOAD (MW) FOR
EACH PJM ZONE AND RTO
2010-2025**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|---------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| AE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| BGE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| DPL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| JCPL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| METED | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PECO | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PENLC | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PEPCO | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PS | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RECO | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| UGI | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AEP | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 |
| APS | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ATSI | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| COMED | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| DAY | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| DLCO | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| DOM | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PJM RTO | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 | -600 |

Notes: Adjustment values presented here are reflected in Tables B-1 through B-6 and Table B-10.

Adjustments are large, unanticipated load changes deemed by PJM to not be captured in the forecast model.

Table B-10

**SUMMER COINCIDENT PEAK LOAD (MW) FOR
EACH PJM ZONE, LOCATIONAL DELIVERABILITY AREA AND RTO
2010-2025**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|----------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| AE | 2,628 | 2,788 | 2,920 | 3,019 | 3,076 | 3,123 | 3,167 | 3,208 | 3,249 | 3,278 | 3,308 | 3,341 | 3,370 | 3,404 | 3,433 | 3,466 |
| BGE | 7,173 | 7,363 | 7,488 | 7,621 | 7,762 | 7,918 | 8,043 | 8,174 | 8,294 | 8,433 | 8,571 | 8,689 | 8,798 | 8,923 | 9,048 | 9,166 |
| DPL | 3,873 | 3,935 | 3,998 | 4,059 | 4,113 | 4,166 | 4,219 | 4,270 | 4,322 | 4,367 | 4,421 | 4,477 | 4,528 | 4,592 | 4,648 | 4,704 |
| JCPL | 6,203 | 6,376 | 6,593 | 6,733 | 6,841 | 6,931 | 7,039 | 7,096 | 7,178 | 7,247 | 7,312 | 7,373 | 7,493 | 7,503 | 7,587 | 7,668 |
| METED | 2,803 | 2,886 | 2,990 | 3,064 | 3,111 | 3,149 | 3,186 | 3,218 | 3,248 | 3,276 | 3,309 | 3,337 | 3,365 | 3,390 | 3,418 | 3,454 |
| PECO | 8,212 | 8,368 | 8,656 | 8,830 | 8,963 | 9,068 | 9,158 | 9,242 | 9,321 | 9,379 | 9,432 | 9,483 | 9,518 | 9,564 | 9,610 | 9,662 |
| PENLC | 2,710 | 2,779 | 2,863 | 2,929 | 2,980 | 3,035 | 3,089 | 3,138 | 3,175 | 3,227 | 3,275 | 3,322 | 3,362 | 3,404 | 3,439 | 3,482 |
| PEPCO | 6,787 | 6,872 | 7,001 | 7,094 | 7,173 | 7,244 | 7,310 | 7,383 | 7,455 | 7,529 | 7,601 | 7,671 | 7,734 | 7,807 | 7,876 | 7,947 |
| PL | 6,883 | 7,055 | 7,275 | 7,433 | 7,527 | 7,607 | 7,680 | 7,738 | 7,798 | 7,846 | 7,893 | 7,934 | 7,973 | 8,002 | 8,043 | 8,094 |
| PS | 10,523 | 10,736 | 11,010 | 11,188 | 11,322 | 11,443 | 11,562 | 11,657 | 11,748 | 11,845 | 11,943 | 12,032 | 12,107 | 12,176 | 12,253 | 12,365 |
| RECO | 417 | 425 | 435 | 444 | 450 | 454 | 459 | 463 | 466 | 470 | 474 | 478 | 481 | 484 | 486 | 490 |
| UGI | 182 | 186 | 190 | 194 | 196 | 197 | 198 | 200 | 200 | 201 | 201 | 202 | 202 | 203 | 203 | 204 |
| | | | | | | | | | | | | | | | | |
| AEP | 22,358 | 22,894 | 23,671 | 24,084 | 24,372 | 24,625 | 24,832 | 25,026 | 25,193 | 25,334 | 25,469 | 25,624 | 25,755 | 25,894 | 26,041 | 26,187 |
| APS | 8,328 | 8,523 | 8,700 | 8,859 | 8,961 | 9,061 | 9,146 | 9,234 | 9,309 | 9,408 | 9,506 | 9,595 | 9,671 | 9,764 | 9,858 | 9,954 |
| ATSI | - | 12,634 | 13,068 | 13,364 | 13,521 | 13,664 | 13,774 | 13,874 | 13,959 | 14,021 | 14,084 | 14,140 | 14,172 | 14,218 | 14,253 | 14,310 |
| COMED | 21,652 | 22,389 | 23,442 | 24,138 | 24,587 | 25,040 | 25,425 | 25,742 | 26,031 | 26,379 | 26,723 | 26,974 | 27,138 | 27,257 | 27,390 | 27,578 |
| DAY | 3,207 | 3,307 | 3,447 | 3,521 | 3,557 | 3,584 | 3,602 | 3,615 | 3,622 | 3,632 | 3,638 | 3,645 | 3,648 | 3,649 | 3,655 | 3,666 |
| DLCO | 2,757 | 2,793 | 2,869 | 2,922 | 2,963 | 3,007 | 3,038 | 3,077 | 3,114 | 3,146 | 3,176 | 3,203 | 3,224 | 3,252 | 3,279 | 3,307 |
| | | | | | | | | | | | | | | | | |
| DOM | 19,056 | 19,721 | 20,551 | 21,138 | 21,619 | 22,085 | 22,478 | 22,943 | 23,399 | 23,853 | 24,389 | 24,863 | 25,355 | 25,898 | 26,416 | 26,961 |
| | | | | | | | | | | | | | | | | |
| PJM RTO | 135,750 | 152,028 | 157,167 | 160,631 | 163,093 | 165,402 | 167,403 | 169,297 | 171,081 | 172,869 | 174,724 | 176,382 | 177,894 | 179,385 | 180,936 | 182,665 |
| | | | | | | | | | | | | | | | | |
| MAAC | 58,394 | 59,769 | 61,419 | 62,608 | 63,514 | 64,335 | 65,110 | 65,787 | 66,454 | 67,098 | 67,740 | 68,339 | 68,931 | 69,452 | 70,044 | 70,702 |
| Eastern MAAC | 31,856 | 32,628 | 33,612 | 34,273 | 34,765 | 35,185 | 35,604 | 35,936 | 36,284 | 36,586 | 36,890 | 37,184 | 37,497 | 37,723 | 38,017 | 38,355 |
| Southwest MAAC | 13,960 | 14,235 | 14,489 | 14,715 | 14,935 | 15,162 | 15,353 | 15,557 | 15,749 | 15,962 | 16,172 | 16,360 | 16,532 | 16,730 | 16,924 | 17,113 |
| MAAC and APS | 66,722 | 68,292 | 70,119 | 71,467 | 72,475 | 73,396 | 74,256 | 75,021 | 75,763 | 76,506 | 77,246 | 77,934 | 78,602 | 79,216 | 79,902 | 80,656 |

Notes: Load values for Zones and Locational Deliverability Areas are coincident with the PJM RTO peak.

Assumes integration of ATSI zone into PJM RTO on June 1, 2011.

This table will be used for the Reliability Pricing Model.

TABLE C-1

**PJM LOCATIONAL DELIVERABILITY AREAS
CENTRAL MID-ATLANTIC: BGE, METED, PEPKO, PL AND UGI
SEASONAL PEAKS - MW**

| YEAR | BASE (50/50) FORECAST | | | |
|-------------|------------------------------|------------------------------|----------------------------|------------------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 17,111 | 24,505 | 16,714 | 21,299 |
| 2011 | 17,454 | 25,094 | 17,146 | 21,684 |
| 2012 | 17,882 | 25,696 | 17,757 | 22,088 |
| 2013 | 18,221 | 26,184 | 18,069 | 22,449 |
| 2014 | 18,511 | 26,558 | 18,303 | 22,711 |
| 2015 | 18,706 | 26,914 | 18,395 | 22,944 |
| 2016 | 18,902 | 27,219 | 18,528 | 23,174 |
| 2017 | 19,084 | 27,521 | 18,888 | 23,374 |
| 2018 | 19,271 | 27,819 | 19,187 | 23,567 |
| 2019 | 19,343 | 28,132 | 19,377 | 23,747 |
| 2020 | 19,613 | 28,436 | 19,377 | 23,922 |
| 2021 | 19,798 | 28,680 | 19,447 | 24,118 |
| 2022 | 19,905 | 28,944 | 19,627 | 24,304 |
| 2023 | 20,074 | 29,187 | 19,943 | 24,448 |
| 2024 | 20,106 | 29,480 | 20,235 | 24,611 |
| 2025 | 20,456 | 29,778 | 20,386 | 24,773 |

| YEAR | EXTREME WEATHER (90/10) FORECAST | | | |
|-------------|---|------------------------------|----------------------------|------------------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 18,821 | 25,777 | 18,812 | 22,442 |
| 2011 | 19,035 | 26,393 | 19,281 | 22,850 |
| 2012 | 19,742 | 26,994 | 19,816 | 23,310 |
| 2013 | 20,162 | 27,503 | 20,120 | 23,596 |
| 2014 | 20,464 | 27,916 | 20,349 | 23,849 |
| 2015 | 20,887 | 28,277 | 20,638 | 24,153 |
| 2016 | 20,909 | 28,616 | 20,819 | 24,324 |
| 2017 | 21,100 | 28,912 | 21,106 | 24,599 |
| 2018 | 21,528 | 29,231 | 21,412 | 24,725 |
| 2019 | 21,634 | 29,563 | 21,637 | 24,914 |
| 2020 | 22,082 | 29,888 | 21,826 | 25,062 |
| 2021 | 22,298 | 30,178 | 21,987 | 25,270 |
| 2022 | 22,252 | 30,443 | 22,168 | 25,512 |
| 2023 | 22,467 | 30,690 | 22,372 | 25,682 |
| 2024 | 22,853 | 30,998 | 22,693 | 25,789 |
| 2025 | 23,060 | 31,333 | 22,858 | 25,922 |

TABLE C-2

**PJM LOCATIONAL DELIVERABILITY AREAS
WESTERN MID-ATLANTIC: METED, PENLC, PL AND UGI
SEASONAL PEAKS - MW**

| YEAR | BASE (50/50) FORECAST | | | |
|------|-----------------------|----------------------|--------------------|----------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 10,296 | 12,992 | 10,247 | 12,652 |
| 2011 | 10,529 | 13,327 | 10,571 | 12,920 |
| 2012 | 10,906 | 13,750 | 10,947 | 13,246 |
| 2013 | 11,213 | 14,068 | 11,123 | 13,536 |
| 2014 | 11,378 | 14,289 | 11,258 | 13,728 |
| 2015 | 11,529 | 14,468 | 11,409 | 13,886 |
| 2016 | 11,655 | 14,614 | 11,511 | 14,035 |
| 2017 | 11,790 | 14,762 | 11,651 | 14,198 |
| 2018 | 11,937 | 14,898 | 11,815 | 14,296 |
| 2019 | 12,044 | 15,043 | 11,877 | 14,414 |
| 2020 | 12,135 | 15,168 | 11,975 | 14,495 |
| 2021 | 12,235 | 15,277 | 12,028 | 14,618 |
| 2022 | 12,325 | 15,382 | 12,136 | 14,745 |
| 2023 | 12,410 | 15,486 | 12,251 | 14,839 |
| 2024 | 12,541 | 15,612 | 12,349 | 14,904 |
| 2025 | 12,655 | 15,745 | 12,432 | 14,984 |

| YEAR | EXTREME WEATHER (90/10) FORECAST | | | |
|------|----------------------------------|----------------------|--------------------|----------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 10,761 | 13,587 | 10,403 | 13,298 |
| 2011 | 10,951 | 13,927 | 10,719 | 13,566 |
| 2012 | 11,420 | 14,349 | 11,130 | 13,909 |
| 2013 | 11,722 | 14,688 | 11,334 | 14,221 |
| 2014 | 11,953 | 14,914 | 11,459 | 14,371 |
| 2015 | 12,164 | 15,105 | 11,609 | 14,558 |
| 2016 | 12,166 | 15,238 | 11,721 | 14,694 |
| 2017 | 12,271 | 15,360 | 11,891 | 14,869 |
| 2018 | 12,503 | 15,507 | 12,038 | 14,955 |
| 2019 | 12,608 | 15,661 | 12,142 | 15,109 |
| 2020 | 12,825 | 15,829 | 12,215 | 15,169 |
| 2021 | 12,840 | 15,930 | 12,277 | 15,278 |
| 2022 | 12,878 | 16,021 | 12,402 | 15,396 |
| 2023 | 12,967 | 16,098 | 12,513 | 15,515 |
| 2024 | 13,160 | 16,240 | 12,642 | 15,569 |
| 2025 | 13,269 | 16,412 | 12,719 | 15,663 |

TABLE C-3

**PJM LOCATIONAL DELIVERABILITY AREAS
EASTERN MID-ATLANTIC: AE, DPL, JCPL, PECO, PS AND RECO
SEASONAL PEAKS - MW**

| YEAR | BASE (50/50) FORECAST | | | |
|------|-----------------------|----------------------|--------------------|----------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 18,716 | 32,801 | 19,868 | 22,522 |
| 2011 | 19,181 | 33,697 | 20,468 | 22,906 |
| 2012 | 19,842 | 34,686 | 21,649 | 23,502 |
| 2013 | 20,304 | 35,444 | 22,068 | 23,975 |
| 2014 | 20,769 | 35,971 | 22,192 | 24,308 |
| 2015 | 21,033 | 36,432 | 22,368 | 24,583 |
| 2016 | 21,192 | 36,839 | 22,404 | 24,836 |
| 2017 | 21,362 | 37,214 | 22,845 | 25,064 |
| 2018 | 21,604 | 37,461 | 23,487 | 25,263 |
| 2019 | 21,770 | 37,910 | 23,688 | 25,453 |
| 2020 | 22,154 | 38,244 | 23,572 | 25,613 |
| 2021 | 22,338 | 38,546 | 23,608 | 25,814 |
| 2022 | 22,342 | 38,845 | 23,768 | 26,018 |
| 2023 | 22,484 | 39,142 | 24,092 | 26,159 |
| 2024 | 22,677 | 39,435 | 24,721 | 26,317 |
| 2025 | 22,907 | 39,774 | 24,678 | 26,454 |

| YEAR | EXTREME WEATHER (90/10) FORECAST | | | |
|------|----------------------------------|----------------------|--------------------|----------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 22,030 | 34,827 | 23,368 | 23,618 |
| 2011 | 22,350 | 35,756 | 24,171 | 23,921 |
| 2012 | 23,199 | 36,539 | 25,113 | 24,519 |
| 2013 | 23,988 | 37,476 | 25,563 | 24,973 |
| 2014 | 24,463 | 38,181 | 25,875 | 25,170 |
| 2015 | 24,935 | 38,628 | 26,191 | 25,632 |
| 2016 | 24,891 | 39,025 | 26,436 | 25,893 |
| 2017 | 25,171 | 39,410 | 26,872 | 26,122 |
| 2018 | 25,492 | 39,607 | 27,201 | 26,304 |
| 2019 | 25,771 | 40,017 | 27,438 | 26,468 |
| 2020 | 26,371 | 40,530 | 27,592 | 26,486 |
| 2021 | 26,463 | 40,835 | 27,703 | 26,883 |
| 2022 | 26,420 | 41,118 | 28,029 | 27,050 |
| 2023 | 26,639 | 41,413 | 28,331 | 27,215 |
| 2024 | 27,147 | 41,615 | 28,591 | 27,356 |
| 2025 | 27,372 | 42,152 | 28,772 | 27,314 |

TABLE C-4

**PJM LOCATIONAL DELIVERABILITY AREAS
SOUTHERN MID-ATLANTIC: BGE AND PEPCO
SEASONAL PEAKS - MW**

| YEAR | BASE (50/50) FORECAST | | | |
|------|-----------------------|----------------------|--------------------|----------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 9,144 | 14,433 | 9,302 | 11,459 |
| 2011 | 9,293 | 14,742 | 9,475 | 11,637 |
| 2012 | 9,441 | 14,956 | 9,810 | 11,818 |
| 2013 | 9,665 | 15,244 | 9,940 | 11,954 |
| 2014 | 9,818 | 15,466 | 10,066 | 12,088 |
| 2015 | 9,966 | 15,711 | 10,165 | 12,208 |
| 2016 | 10,044 | 15,872 | 10,196 | 12,352 |
| 2017 | 10,088 | 16,073 | 10,472 | 12,466 |
| 2018 | 10,314 | 16,253 | 10,659 | 12,592 |
| 2019 | 10,505 | 16,529 | 10,761 | 12,704 |
| 2020 | 10,658 | 16,764 | 10,850 | 12,828 |
| 2021 | 10,784 | 16,945 | 10,881 | 12,946 |
| 2022 | 10,837 | 17,081 | 11,003 | 13,062 |
| 2023 | 10,861 | 17,287 | 11,242 | 13,177 |
| 2024 | 11,179 | 17,536 | 11,435 | 13,298 |
| 2025 | 11,269 | 17,741 | 11,516 | 13,405 |

| YEAR | EXTREME WEATHER (90/10) FORECAST | | | |
|------|----------------------------------|----------------------|--------------------|----------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 10,655 | 15,120 | 10,824 | 12,100 |
| 2011 | 10,825 | 15,461 | 11,057 | 12,281 |
| 2012 | 11,113 | 15,722 | 11,266 | 12,468 |
| 2013 | 11,273 | 15,963 | 11,418 | 12,631 |
| 2014 | 11,476 | 16,210 | 11,564 | 12,729 |
| 2015 | 11,678 | 16,444 | 11,755 | 12,886 |
| 2016 | 11,823 | 16,689 | 11,872 | 13,009 |
| 2017 | 11,907 | 16,902 | 12,039 | 13,133 |
| 2018 | 12,155 | 17,123 | 12,246 | 13,249 |
| 2019 | 12,302 | 17,355 | 12,412 | 13,389 |
| 2020 | 12,495 | 17,579 | 12,565 | 13,507 |
| 2021 | 12,652 | 17,801 | 12,694 | 13,627 |
| 2022 | 12,788 | 18,009 | 12,808 | 13,745 |
| 2023 | 12,910 | 18,213 | 12,934 | 13,862 |
| 2024 | 13,113 | 18,426 | 13,169 | 13,979 |
| 2025 | 13,266 | 18,646 | 13,290 | 14,095 |

TABLE C-5

PJM LOCATIONAL DELIVERABILITY AREAS
MID-ATLANTIC and APS: AE, APS, BGE, DPL, JCPL, METED, PECO, PENLC, PEPCO, PL, PS, RECO, and UGI
SEASONAL PEAKS - MW

| YEAR | BASE (50/50) FORECAST | | | |
|------|-----------------------|----------------------|--------------------|----------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 44,590 | 68,465 | 44,944 | 54,675 |
| 2011 | 45,357 | 70,221 | 46,299 | 55,837 |
| 2012 | 46,664 | 72,141 | 47,961 | 57,142 |
| 2013 | 47,865 | 73,697 | 48,858 | 58,110 |
| 2014 | 48,843 | 74,865 | 49,342 | 58,797 |
| 2015 | 49,498 | 75,833 | 49,847 | 59,466 |
| 2016 | 49,739 | 76,722 | 50,242 | 60,074 |
| 2017 | 50,287 | 77,505 | 51,016 | 60,826 |
| 2018 | 50,692 | 78,230 | 51,781 | 61,300 |
| 2019 | 51,290 | 79,122 | 52,220 | 61,787 |
| 2020 | 52,174 | 79,918 | 52,523 | 62,155 |
| 2021 | 52,582 | 80,636 | 52,814 | 62,657 |
| 2022 | 52,780 | 81,323 | 53,197 | 63,284 |
| 2023 | 53,174 | 81,897 | 53,964 | 63,735 |
| 2024 | 53,661 | 82,690 | 54,535 | 64,177 |
| 2025 | 54,466 | 83,430 | 54,982 | 64,485 |

| YEAR | EXTREME WEATHER (90/10) FORECAST | | | |
|------|----------------------------------|----------------------|--------------------|----------------------|
| | SPRING (WK 14-19) | SUMMER (WK 20-39) | FALL (WK 40-45) | WINTER (WK 46-13) |
| 2010 | 49,349 | 71,933 | 51,294 | 57,651 |
| 2011 | 49,868 | 73,832 | 52,840 | 58,574 |
| 2012 | 51,551 | 75,360 | 54,604 | 59,963 |
| 2013 | 53,411 | 77,275 | 55,518 | 61,002 |
| 2014 | 54,369 | 78,793 | 56,159 | 61,730 |
| 2015 | 55,818 | 79,622 | 56,838 | 62,553 |
| 2016 | 55,023 | 80,470 | 57,391 | 63,140 |
| 2017 | 55,625 | 81,345 | 58,271 | 63,897 |
| 2018 | 56,372 | 81,498 | 59,058 | 64,213 |
| 2019 | 56,987 | 82,895 | 59,645 | 64,769 |
| 2020 | 59,132 | 83,843 | 60,016 | 65,118 |
| 2021 | 58,826 | 84,586 | 60,356 | 65,766 |
| 2022 | 58,660 | 85,310 | 61,046 | 66,229 |
| 2023 | 59,185 | 86,067 | 61,684 | 66,931 |
| 2024 | 60,432 | 86,694 | 62,423 | 67,144 |
| 2025 | 61,081 | 87,789 | 62,847 | 67,507 |

THIS PAGE INTENTIONALLY LEFT BLANK

Table D-1

**SUMMER EXTREME WEATHER (90/10) PEAK LOAD
FOR EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION (MW)
2010-2025**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|-----------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| AE | 2,900 | 3,073 | 3,213 | 3,322 | 3,386 | 3,436 | 3,481 | 3,522 | 3,569 | 3,601 | 3,638 | 3,672 | 3,704 | 3,733 | 3,769 | 3,810 |
| BGE | 7,738 | 7,962 | 8,104 | 8,232 | 8,388 | 8,549 | 8,711 | 8,849 | 8,992 | 9,142 | 9,284 | 9,428 | 9,559 | 9,690 | 9,824 | 9,960 |
| DPL | 4,146 | 4,223 | 4,286 | 4,359 | 4,421 | 4,475 | 4,532 | 4,583 | 4,644 | 4,693 | 4,753 | 4,813 | 4,869 | 4,937 | 5,000 | 5,065 |
| JCPL | 6,855 | 7,065 | 7,239 | 7,434 | 7,607 | 7,710 | 7,807 | 7,897 | 7,903 | 8,020 | 8,149 | 8,219 | 8,295 | 8,365 | 8,397 | 8,535 |
| METED | 3,030 | 3,125 | 3,236 | 3,315 | 3,365 | 3,404 | 3,441 | 3,476 | 3,509 | 3,538 | 3,572 | 3,601 | 3,631 | 3,658 | 3,691 | 3,732 |
| PECO | 9,009 | 9,218 | 9,480 | 9,701 | 9,856 | 9,961 | 10,046 | 10,128 | 10,175 | 10,279 | 10,351 | 10,403 | 10,438 | 10,479 | 10,532 | 10,601 |
| PENLC | 2,942 | 3,007 | 3,091 | 3,149 | 3,209 | 3,273 | 3,313 | 3,351 | 3,407 | 3,453 | 3,521 | 3,557 | 3,587 | 3,621 | 3,668 | 3,725 |
| PEPCO | 7,383 | 7,499 | 7,619 | 7,732 | 7,822 | 7,896 | 7,978 | 8,053 | 8,132 | 8,213 | 8,296 | 8,374 | 8,451 | 8,523 | 8,602 | 8,686 |
| PL | 7,428 | 7,604 | 7,828 | 8,013 | 8,127 | 8,214 | 8,270 | 8,317 | 8,381 | 8,451 | 8,517 | 8,555 | 8,584 | 8,599 | 8,660 | 8,733 |
| PS | 11,456 | 11,707 | 11,908 | 12,169 | 12,414 | 12,543 | 12,651 | 12,767 | 12,800 | 12,903 | 13,114 | 13,200 | 13,279 | 13,365 | 13,378 | 13,598 |
| RECO | 462 | 471 | 482 | 491 | 498 | 503 | 508 | 513 | 517 | 522 | 526 | 529 | 533 | 536 | 540 | 544 |
| UGI | 199 | 203 | 207 | 212 | 214 | 216 | 216 | 217 | 217 | 219 | 220 | 220 | 220 | 220 | 221 | 223 |
| DIVERSITY - MID-ATLANTIC(-) | 330 | 270 | 554 | 186 | 1 | 89 | 113 | 48 | 596 | 74 | 100 | 89 | 30 | 0 | 16 | 1 |
| PJM MID-ATLANTIC | 63,218 | 64,887 | 66,139 | 67,943 | 69,306 | 70,091 | 70,841 | 71,625 | 71,650 | 72,960 | 73,841 | 74,482 | 75,120 | 75,726 | 76,266 | 77,211 |
| FE/GPU | 12,815 | 13,184 | 13,466 | 13,885 | 14,180 | 14,386 | 14,559 | 14,722 | 14,773 | 14,997 | 15,241 | 15,374 | 15,512 | 15,644 | 15,742 | 15,991 |
| PLGRP | 7,626 | 7,807 | 8,035 | 8,224 | 8,341 | 8,429 | 8,485 | 8,534 | 8,598 | 8,670 | 8,737 | 8,774 | 8,803 | 8,819 | 8,881 | 8,956 |

Table D-1

**SUMMER EXTREME WEATHER (90/10) PEAK LOAD
FOR EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO
2010-2025**

| | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 |
|-------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| AEP | 24,432 | 25,092 | 25,798 | 26,323 | 26,681 | 26,829 | 27,151 | 27,318 | 27,435 | 27,680 | 27,775 | 27,980 | 28,156 | 28,240 | 28,408 | 28,657 |
| APS | 8,988 | 9,220 | 9,432 | 9,576 | 9,689 | 9,791 | 9,890 | 9,981 | 10,077 | 10,164 | 10,270 | 10,367 | 10,463 | 10,557 | 10,650 | 10,751 |
| ATSI | 13,411 | 13,731 | 14,261 | 14,578 | 14,779 | 14,956 | 14,974 | 15,091 | 15,204 | 15,305 | 15,421 | 15,409 | 15,437 | 15,477 | 15,556 | 15,650 |
| COMED | 24,069 | 25,033 | 26,194 | 26,913 | 27,350 | 27,796 | 28,239 | 28,576 | 28,918 | 29,272 | 29,568 | 29,845 | 30,051 | 30,189 | 30,364 | 30,508 |
| DAY | 3,502 | 3,619 | 3,773 | 3,847 | 3,883 | 3,912 | 3,936 | 3,951 | 3,964 | 3,966 | 3,972 | 3,982 | 3,985 | 3,986 | 3,991 | 4,004 |
| DLCO | 3,048 | 3,099 | 3,181 | 3,237 | 3,280 | 3,322 | 3,365 | 3,405 | 3,446 | 3,477 | 3,509 | 3,539 | 3,566 | 3,592 | 3,620 | 3,653 |
| DIVERSITY - WESTERN (-) | 828 | 839 | 753 | 694 | 752 | 643 | 684 | 625 | 606 | 621 | 616 | 615 | 621 | 538 | 539 | 655 |
| PJM WESTERN (with ATSI) | 76,622 | 78,955 | 81,886 | 83,780 | 84,910 | 85,963 | 86,871 | 87,697 | 88,438 | 89,243 | 89,899 | 90,507 | 91,037 | 91,503 | 92,050 | 92,568 |
| DIVERSITY - WESTERN (-) | 803 | 846 | 710 | 642 | 676 | 526 | 676 | 598 | 559 | 562 | 502 | 567 | 599 | 519 | 497 | 578 |
| PJM WESTERN (without ATSI) | 63,236 | 65,217 | 67,668 | 69,254 | 70,207 | 71,124 | 71,905 | 72,633 | 73,281 | 73,997 | 74,592 | 75,146 | 75,622 | 76,045 | 76,536 | 76,995 |
| DOM | 20,240 | 21,006 | 21,912 | 22,523 | 23,001 | 23,477 | 23,971 | 24,468 | 24,951 | 25,450 | 25,941 | 26,476 | 27,005 | 27,562 | 28,126 | 28,693 |
| DIVERSITY - INTERREGIONAL (-) | 2,481 | 2,611 | 2,275 | 2,949 | 3,248 | 3,182 | 3,207 | 3,311 | 2,742 | 3,377 | 3,514 | 3,666 | 3,619 | 3,661 | 3,670 | 3,873 |
| PJM RTO (with ATSI) | 157,599 | 162,237 | 167,662 | 171,297 | 173,969 | 176,349 | 178,476 | 180,479 | 182,297 | 184,276 | 186,167 | 187,799 | 189,543 | 191,130 | 192,772 | 194,599 |
| DIVERSITY - INTERREGIONAL (-) | 2,082 | 2,117 | 1,789 | 2,297 | 2,657 | 2,574 | 2,613 | 2,731 | 2,063 | 2,737 | 2,879 | 2,965 | 3,023 | 3,033 | 2,972 | 3,247 |
| PJM RTO (without ATSI) | 144,612 | 148,993 | 153,930 | 157,423 | 159,857 | 162,118 | 164,104 | 165,995 | 167,819 | 169,670 | 171,495 | 173,139 | 174,724 | 176,300 | 177,956 | 179,652 |

Table D-2

**WINTER EXTREME WEATHER (90/10) PEAK LOAD
FOR EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION (MW)
2009/10- 2024/25**

| | 09/10 | 10/11 | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 | 20/21 | 21/22 | 22/23 | 23/24 | 24/25 |
|-----------------------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| AE | 1,851 | 1,894 | 1,988 | 2,046 | 2,074 | 2,105 | 2,120 | 2,156 | 2,162 | 2,198 | 2,206 | 2,218 | 2,244 | 2,261 | 2,266 | 2,284 |
| BGE | 6,331 | 6,425 | 6,516 | 6,579 | 6,615 | 6,705 | 6,762 | 6,843 | 6,874 | 6,967 | 7,026 | 7,077 | 7,147 | 7,203 | 7,236 | 7,314 |
| DPL | 3,543 | 3,588 | 3,637 | 3,686 | 3,712 | 3,764 | 3,794 | 3,839 | 3,857 | 3,908 | 3,945 | 3,979 | 4,024 | 4,061 | 4,089 | 4,144 |
| JCPL | 4,117 | 4,205 | 4,325 | 4,428 | 4,454 | 4,540 | 4,580 | 4,629 | 4,649 | 4,724 | 4,747 | 4,779 | 4,819 | 4,852 | 4,868 | 4,922 |
| METED | 2,672 | 2,744 | 2,835 | 2,915 | 2,945 | 2,988 | 3,006 | 3,056 | 3,057 | 3,104 | 3,122 | 3,134 | 3,169 | 3,199 | 3,198 | 3,239 |
| PECO | 6,769 | 6,852 | 7,057 | 7,207 | 7,242 | 7,361 | 7,450 | 7,544 | 7,559 | 7,643 | 7,632 | 7,699 | 7,756 | 7,794 | 7,784 | 7,795 |
| PENLC | 2,887 | 2,958 | 3,052 | 3,139 | 3,179 | 3,242 | 3,292 | 3,362 | 3,397 | 3,467 | 3,498 | 3,546 | 3,601 | 3,647 | 3,674 | 3,717 |
| PEPCO | 5,770 | 5,862 | 5,977 | 6,086 | 6,114 | 6,196 | 6,248 | 6,345 | 6,375 | 6,471 | 6,511 | 6,562 | 6,656 | 6,718 | 6,747 | 6,809 |
| PL | 7,535 | 7,659 | 7,828 | 7,988 | 8,033 | 8,141 | 8,179 | 8,273 | 8,282 | 8,349 | 8,366 | 8,395 | 8,468 | 8,496 | 8,484 | 8,517 |
| PS | 7,150 | 7,255 | 7,415 | 7,573 | 7,597 | 7,715 | 7,743 | 7,822 | 7,863 | 7,970 | 7,994 | 8,009 | 8,083 | 8,123 | 8,140 | 8,221 |
| RECO | 240 | 242 | 244 | 245 | 247 | 249 | 251 | 253 | 255 | 258 | 260 | 262 | 264 | 266 | 268 | 270 |
| UGI | 204 | 206 | 211 | 214 | 214 | 216 | 217 | 219 | 219 | 220 | 220 | 220 | 221 | 222 | 221 | 222 |
| DIVERSITY - MID-ATLANTIC(-) | 253 | 343 | 271 | 585 | 254 | 381 | 194 | 280 | 303 | 567 | 407 | 243 | 437 | 284 | 327 | 407 |
| PJM MID-ATLANTIC | 48,816 | 49,547 | 50,814 | 51,521 | 52,172 | 52,841 | 53,448 | 54,061 | 54,246 | 54,712 | 55,120 | 55,637 | 56,015 | 56,558 | 56,648 | 57,047 |
| FE/GPU | 9,644 | 9,871 | 10,166 | 10,426 | 10,545 | 10,729 | 10,852 | 11,016 | 11,102 | 11,238 | 11,317 | 11,423 | 11,544 | 11,665 | 11,731 | 11,834 |
| PLGRP | 7,739 | 7,865 | 8,038 | 8,193 | 8,247 | 8,353 | 8,396 | 8,485 | 8,500 | 8,550 | 8,577 | 8,615 | 8,676 | 8,704 | 8,704 | 8,730 |

Table D-2

**WINTER EXTREME WEATHER (90/10) PEAK LOAD
FOR EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO (MW)
2009/10- 2024/25**

| | 09/10 | 10/11 | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 | 20/21 | 21/22 | 22/23 | 23/24 | 24/25 |
|-------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| AEP | 24,126 | 24,326 | 24,816 | 25,352 | 25,470 | 25,738 | 25,824 | 26,019 | 26,006 | 26,256 | 26,329 | 26,394 | 26,533 | 26,629 | 26,582 | 26,790 |
| APS | 8,990 | 9,179 | 9,417 | 9,606 | 9,674 | 9,850 | 9,924 | 10,043 | 10,067 | 10,211 | 10,280 | 10,379 | 10,493 | 10,595 | 10,624 | 10,733 |
| ATSI | 10,990 | 11,116 | 11,390 | 11,634 | 11,694 | 11,819 | 11,864 | 11,941 | 11,971 | 12,090 | 12,098 | 12,116 | 12,146 | 12,177 | 12,160 | 12,235 |
| COMED | 16,170 | 16,433 | 17,121 | 17,745 | 17,895 | 18,271 | 18,464 | 18,763 | 18,909 | 19,247 | 19,353 | 19,453 | 19,685 | 19,816 | 19,815 | 19,943 |
| DAY | 3,150 | 3,162 | 3,245 | 3,282 | 3,298 | 3,340 | 3,332 | 3,344 | 3,334 | 3,350 | 3,353 | 3,358 | 3,359 | 3,363 | 3,349 | 3,365 |
| DLCO | 2,225 | 2,236 | 2,265 | 2,295 | 2,293 | 2,325 | 2,327 | 2,344 | 2,351 | 2,383 | 2,378 | 2,389 | 2,399 | 2,411 | 2,413 | 2,429 |
| DIVERSITY - WESTERN (-) | 1,143 | 1,015 | 1,152 | 1,365 | 969 | 1,311 | 1,115 | 1,297 | 1,176 | 1,522 | 1,320 | 1,180 | 1,341 | 1,399 | 1,237 | 1,338 |
| PJM WESTERN (with ATSI) | 64,508 | 65,437 | 67,102 | 68,549 | 69,355 | 70,032 | 70,620 | 71,157 | 71,462 | 72,015 | 72,471 | 72,909 | 73,274 | 73,592 | 73,706 | 74,157 |
| DIVERSITY - WESTERN (-) | 942 | 1,036 | 1,141 | 1,300 | 1,015 | 1,292 | 1,026 | 1,354 | 1,128 | 1,470 | 1,348 | 1,087 | 1,391 | 1,469 | 1,165 | 1,366 |
| PJM WESTERN (without ATSI) | 53,719 | 54,300 | 55,723 | 56,980 | 57,615 | 58,232 | 58,845 | 59,159 | 59,539 | 59,977 | 60,345 | 60,886 | 61,078 | 61,345 | 61,618 | 61,894 |
| DOM | 18,467 | 18,873 | 19,568 | 20,125 | 20,364 | 20,861 | 21,200 | 21,615 | 21,860 | 22,312 | 22,671 | 23,031 | 23,474 | 23,884 | 24,192 | 24,715 |
| DIVERSITY - INTERREGIONAL (-) | 942 | 1,024 | 1,447 | 1,077 | 1,050 | 1,087 | 1,201 | 1,417 | 917 | 1,153 | 1,460 | 1,227 | 1,120 | 1,470 | 950 | 1,660 |
| PJM RTO (with ATSI) | 130,849 | 132,833 | 136,037 | 139,118 | 140,841 | 142,647 | 144,067 | 145,416 | 146,651 | 147,886 | 148,802 | 150,350 | 151,643 | 152,564 | 153,596 | 154,259 |
| DIVERSITY - INTERREGIONAL (-) | 748 | 818 | 1,198 | 863 | 1,035 | 920 | 1,098 | 919 | 654 | 836 | 1,221 | 1,146 | 768 | 978 | 826 | 1,326 |
| PJM RTO (without ATSI) | 120,254 | 121,902 | 124,907 | 127,763 | 129,116 | 131,014 | 132,395 | 133,916 | 134,991 | 136,165 | 136,915 | 138,408 | 139,799 | 140,809 | 141,632 | 142,330 |

Table E-1

**ANNUAL NET ENERGY (GWh) AND GROWTH RATES FOR
EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION
2010-2020**

| | | ESTIMATED 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | Annual Growth Rate (10 yr) |
|------------------|---|---------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|---|
| AE | | 11,238 | 11,574 | 12,180 | 12,845 | 13,259 | 13,543 | 13,752 | 13,978 | 14,117 | 14,287 | 14,426 | 14,611 | 2.4% |
| | % | | 3.0% | 5.2% | 5.5% | 3.2% | 2.1% | 1.5% | 1.6% | 1.0% | 1.2% | 1.0% | 1.3% | |
| BGE | | 34,158 | 35,504 | 36,413 | 37,106 | 37,496 | 38,115 | 38,763 | 39,503 | 39,977 | 40,533 | 41,083 | 41,788 | 1.6% |
| | % | | 3.9% | 2.6% | 1.9% | 1.1% | 1.7% | 1.7% | 1.9% | 1.2% | 1.4% | 1.4% | 1.7% | |
| DPL | | 18,782 | 19,050 | 19,326 | 19,617 | 19,800 | 20,036 | 20,251 | 20,517 | 20,652 | 20,856 | 21,031 | 21,327 | 1.1% |
| | % | | 1.4% | 1.4% | 1.5% | 0.9% | 1.2% | 1.1% | 1.3% | 0.7% | 1.0% | 0.8% | 1.4% | |
| JCPL | | 24,045 | 25,157 | 25,965 | 26,987 | 27,590 | 28,097 | 28,525 | 29,004 | 29,281 | 29,628 | 29,919 | 30,324 | 1.9% |
| | % | | 4.6% | 3.2% | 3.9% | 2.2% | 1.8% | 1.5% | 1.7% | 1.0% | 1.2% | 1.0% | 1.4% | |
| METED | | 15,672 | 16,167 | 16,690 | 17,320 | 17,706 | 18,013 | 18,254 | 18,518 | 18,651 | 18,841 | 18,983 | 19,238 | 1.8% |
| | % | | 3.2% | 3.2% | 3.8% | 2.2% | 1.7% | 1.3% | 1.4% | 0.7% | 1.0% | 0.8% | 1.3% | |
| PECO | | 41,204 | 41,360 | 42,402 | 44,042 | 44,952 | 45,759 | 46,372 | 47,010 | 47,333 | 47,751 | 48,081 | 48,592 | 1.6% |
| | % | | 0.4% | 2.5% | 3.9% | 2.1% | 1.8% | 1.3% | 1.4% | 0.7% | 0.9% | 0.7% | 1.1% | |
| PENLC | | 17,670 | 18,391 | 18,970 | 19,707 | 20,184 | 20,648 | 21,089 | 21,574 | 21,904 | 22,296 | 22,660 | 23,135 | 2.3% |
| | % | | 4.1% | 3.1% | 3.9% | 2.4% | 2.3% | 2.1% | 2.3% | 1.5% | 1.8% | 1.6% | 2.1% | |
| PEPCO | | 32,384 | 33,422 | 33,955 | 34,661 | 35,058 | 35,464 | 35,816 | 36,283 | 36,542 | 36,900 | 37,250 | 37,737 | 1.2% |
| | % | | 3.2% | 1.6% | 2.1% | 1.1% | 1.2% | 1.0% | 1.3% | 0.7% | 1.0% | 0.9% | 1.3% | |
| PL | | 40,958 | 41,829 | 42,928 | 44,403 | 45,269 | 45,988 | 46,533 | 47,100 | 47,357 | 47,729 | 47,987 | 48,487 | 1.5% |
| | % | | 2.1% | 2.6% | 3.4% | 2.0% | 1.6% | 1.2% | 1.2% | 0.5% | 0.8% | 0.5% | 1.0% | |
| PS | | 46,644 | 48,576 | 49,778 | 51,262 | 52,091 | 52,857 | 53,504 | 54,250 | 54,646 | 55,142 | 55,570 | 56,239 | 1.5% |
| | % | | 4.1% | 2.5% | 3.0% | 1.6% | 1.5% | 1.2% | 1.4% | 0.7% | 0.9% | 0.8% | 1.2% | |
| RECO | | 1,521 | 1,581 | 1,616 | 1,663 | 1,685 | 1,706 | 1,727 | 1,751 | 1,763 | 1,781 | 1,793 | 1,814 | 1.4% |
| | % | | 4.0% | 2.2% | 2.9% | 1.3% | 1.2% | 1.2% | 1.4% | 0.7% | 1.0% | 0.7% | 1.2% | |
| UGI | | 1,037 | 1,049 | 1,075 | 1,108 | 1,124 | 1,138 | 1,147 | 1,159 | 1,161 | 1,166 | 1,167 | 1,175 | 1.1% |
| | % | | 1.2% | 2.5% | 3.1% | 1.4% | 1.2% | 0.8% | 1.0% | 0.2% | 0.4% | 0.1% | 0.7% | |
| PJM MID-ATLANTIC | | 285,314 | 293,660 | 301,298 | 310,721 | 316,214 | 321,364 | 325,733 | 330,647 | 333,384 | 336,910 | 339,950 | 344,467 | 1.6% |
| | % | | 2.9% | 2.6% | 3.1% | 1.8% | 1.6% | 1.4% | 1.5% | 0.8% | 1.1% | 0.9% | 1.3% | |
| FE/GPU | | 57,387 | 59,715 | 61,625 | 64,014 | 65,480 | 66,758 | 67,868 | 69,096 | 69,836 | 70,765 | 71,562 | 72,697 | 2.0% |
| | % | | 4.1% | 3.2% | 3.9% | 2.3% | 2.0% | 1.7% | 1.8% | 1.1% | 1.3% | 1.1% | 1.6% | |
| PLGRP | | 41,995 | 42,878 | 44,003 | 45,511 | 46,393 | 47,126 | 47,680 | 48,259 | 48,518 | 48,895 | 49,154 | 49,662 | 1.5% |
| | % | | 2.1% | 2.6% | 3.4% | 1.9% | 1.6% | 1.2% | 1.2% | 0.5% | 0.8% | 0.5% | 1.0% | |

Note: Estimated 2009 includes weather-normalized data through August.
All average growth rates are calculated from the first year of the forecast.

Table E-1 (Continued)

**ANNUAL NET ENERGY (GWh) AND GROWTH RATES FOR
EACH PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION
2021-2025**

| | | 2021 | 2022 | 2023 | 2024 | 2025 | Annual Growth Rate (15 yr) |
|------------------|---|-------------|-------------|-------------|-------------|-------------|---|
| AE | | 14,711 | 14,844 | 14,971 | 15,140 | 15,243 | 1.9% |
| | % | 0.7% | 0.9% | 0.9% | 1.1% | 0.7% | |
| BGE | | 42,231 | 42,785 | 43,325 | 43,953 | 44,364 | 1.5% |
| | % | 1.1% | 1.3% | 1.3% | 1.4% | 0.9% | |
| DPL | | 21,485 | 21,697 | 21,933 | 22,217 | 22,384 | 1.1% |
| | % | 0.7% | 1.0% | 1.1% | 1.3% | 0.8% | |
| JCPL | | 30,548 | 30,850 | 31,124 | 31,486 | 31,733 | 1.6% |
| | % | 0.7% | 1.0% | 0.9% | 1.2% | 0.8% | |
| METED | | 19,356 | 19,521 | 19,670 | 19,884 | 20,038 | 1.4% |
| | % | 0.6% | 0.9% | 0.8% | 1.1% | 0.8% | |
| PECO | | 48,747 | 49,002 | 49,214 | 49,561 | 49,745 | 1.2% |
| | % | 0.3% | 0.5% | 0.4% | 0.7% | 0.4% | |
| PENLC | | 23,429 | 23,776 | 24,101 | 24,496 | 24,787 | 2.0% |
| | % | 1.3% | 1.5% | 1.4% | 1.6% | 1.2% | |
| PEPCO | | 37,985 | 38,348 | 38,689 | 39,125 | 39,377 | 1.1% |
| | % | 0.7% | 1.0% | 0.9% | 1.1% | 0.6% | |
| PL | | 48,608 | 48,860 | 49,058 | 49,403 | 49,587 | 1.1% |
| | % | 0.2% | 0.5% | 0.4% | 0.7% | 0.4% | |
| PS | | 56,525 | 56,973 | 57,363 | 57,876 | 58,218 | 1.2% |
| | % | 0.5% | 0.8% | 0.7% | 0.9% | 0.6% | |
| RECO | | 1,821 | 1,834 | 1,847 | 1,862 | 1,870 | 1.1% |
| | % | 0.4% | 0.7% | 0.7% | 0.8% | 0.4% | |
| UGI | | 1,174 | 1,179 | 1,179 | 1,186 | 1,188 | 0.8% |
| | % | -0.1% | 0.4% | 0.0% | 0.6% | 0.2% | |
| PJM MID-ATLANTIC | | 346,620 | 349,669 | 352,474 | 356,189 | 358,534 | 1.3% |
| | % | 0.6% | 0.9% | 0.8% | 1.1% | 0.7% | |
| FE/GPU | | 73,333 | 74,147 | 74,895 | 75,866 | 76,558 | 1.7% |
| | % | 0.9% | 1.1% | 1.0% | 1.3% | 0.9% | |
| PLGRP | | 49,782 | 50,039 | 50,237 | 50,589 | 50,775 | 1.1% |
| | % | 0.2% | 0.5% | 0.4% | 0.7% | 0.4% | |

Table E-1

**ANNUAL NET ENERGY (GWh) AND GROWTH RATES FOR
EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO
2010-2020**

| | | ESTIMATED 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | Annual Growth Rate (10 yr) |
|----------------------------|---|---------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|---|
| AEP | | 134,618 | 137,640 | 140,545 | 144,746 | 146,711 | 148,337 | 149,735 | 151,306 | 151,796 | 152,662 | 153,232 | 154,656 | 1.2% |
| | % | | 2.2% | 2.1% | 3.0% | 1.4% | 1.1% | 0.9% | 1.0% | 0.3% | 0.6% | 0.4% | 0.9% | |
| APS | | 47,545 | 50,221 | 51,488 | 52,783 | 53,459 | 54,150 | 54,721 | 55,414 | 55,749 | 56,260 | 56,714 | 57,488 | 1.4% |
| | % | | 5.6% | 2.5% | 2.5% | 1.3% | 1.3% | 1.1% | 1.3% | 0.6% | 0.9% | 0.8% | 1.4% | |
| ATSI | | 65,838 | 69,726 | 71,466 | 74,097 | 75,440 | 76,581 | 77,441 | 78,361 | 78,698 | 79,172 | 79,455 | 80,226 | 1.4% |
| | % | | 5.9% | 2.5% | 3.7% | 1.8% | 1.5% | 1.1% | 1.2% | 0.4% | 0.6% | 0.4% | 1.0% | |
| COMED | | 100,825 | 103,204 | 107,578 | 113,770 | 117,526 | 120,183 | 122,684 | 125,253 | 126,780 | 128,537 | 130,288 | 132,545 | 2.5% |
| | % | | 2.4% | 4.2% | 5.8% | 3.3% | 2.3% | 2.1% | 2.1% | 1.2% | 1.4% | 1.4% | 1.7% | |
| DAY | | 17,570 | 17,842 | 18,455 | 19,281 | 19,641 | 19,873 | 20,057 | 20,240 | 20,257 | 20,305 | 20,296 | 20,426 | 1.4% |
| | % | | 1.5% | 3.4% | 4.5% | 1.9% | 1.2% | 0.9% | 0.9% | 0.1% | 0.2% | 0.0% | 0.6% | |
| DLCO | | 14,278 | 14,677 | 14,908 | 15,305 | 15,529 | 15,760 | 15,973 | 16,215 | 16,360 | 16,538 | 16,683 | 16,902 | 1.4% |
| | % | | 2.8% | 1.6% | 2.7% | 1.5% | 1.5% | 1.4% | 1.5% | 0.9% | 1.1% | 0.9% | 1.3% | |
| PJM WESTERN (with ATSI) | | 380,674 | 393,310 | 404,440 | 419,982 | 428,306 | 434,884 | 440,611 | 446,789 | 449,640 | 453,474 | 456,668 | 462,243 | 1.6% |
| | % | | 3.3% | 2.8% | 3.8% | 2.0% | 1.5% | 1.3% | 1.4% | 0.6% | 0.9% | 0.7% | 1.2% | |
| PJM WESTERN (without ATSI) | | 314,836 | 323,584 | 332,974 | 345,885 | 352,866 | 358,303 | 363,170 | 368,428 | 370,942 | 374,302 | 377,213 | 382,017 | 1.7% |
| | % | | 2.8% | 2.9% | 3.9% | 2.0% | 1.5% | 1.4% | 1.4% | 0.7% | 0.9% | 0.8% | 1.3% | |
| DOM | | 94,091 | 97,196 | 100,466 | 104,758 | 107,335 | 109,664 | 111,879 | 114,406 | 116,289 | 118,487 | 120,663 | 123,368 | 2.4% |
| | % | | 3.3% | 3.4% | 4.3% | 2.5% | 2.2% | 2.0% | 2.3% | 1.6% | 1.9% | 1.8% | 2.2% | |
| PJM RTO (with ATSI) | | 760,079 | 784,166 | 806,204 | 835,461 | 851,855 | 865,912 | 878,223 | 891,842 | 899,313 | 908,871 | 917,281 | 930,078 | 1.7% |
| | % | | 3.2% | 2.8% | 3.6% | 2.0% | 1.7% | 1.4% | 1.6% | 0.8% | 1.1% | 0.9% | 1.4% | |
| PJM RTO (without ATSI) | | 694,241 | 714,440 | 734,738 | 761,364 | 776,415 | 789,331 | 800,782 | 813,481 | 820,615 | 829,699 | 837,826 | 849,852 | 1.8% |
| | % | | 2.9% | 2.8% | 3.6% | 2.0% | 1.7% | 1.5% | 1.6% | 0.9% | 1.1% | 1.0% | 1.4% | |

Note: Estimated 2009 includes weather-normalized data through August.
All average growth rates are calculated from the first year of the forecast.

Table E-1 (Continued)

**ANNUAL NET ENERGY (GWh) AND GROWTH RATES FOR
EACH PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO
2021-2025**

| | | 2021 | 2022 | 2023 | 2024 | 2025 | Annual Growth Rate (15 yr) |
|-------------------------|---|-------------|-------------|-------------|-------------|-------------|---|
| AEP | | 154,993 | 155,769 | 156,366 | 157,419 | 157,800 | 0.9% |
| | % | 0.2% | 0.5% | 0.4% | 0.7% | 0.2% | |
| APS | | 57,865 | 58,408 | 58,914 | 59,573 | 59,951 | 1.2% |
| | % | 0.7% | 0.9% | 0.9% | 1.1% | 0.6% | |
| ATSI | | 80,334 | 80,623 | 80,769 | 81,099 | 81,259 | 1.0% |
| | % | 0.1% | 0.4% | 0.2% | 0.4% | 0.2% | |
| COMED | | 133,596 | 134,696 | 135,489 | 136,620 | 137,081 | 1.9% |
| | % | 0.8% | 0.8% | 0.6% | 0.8% | 0.3% | |
| DAY | | 20,418 | 20,455 | 20,448 | 20,490 | 20,499 | 0.9% |
| | % | 0.0% | 0.2% | 0.0% | 0.2% | 0.0% | |
| DLCO | | 16,998 | 17,131 | 17,252 | 17,410 | 17,516 | 1.2% |
| | % | 0.6% | 0.8% | 0.7% | 0.9% | 0.6% | |
| PJM WESTERN (with ATSI) | | 464,204 | 467,082 | 469,238 | 472,611 | 474,106 | 1.3% |
| | % | 0.4% | 0.6% | 0.5% | 0.7% | 0.3% | |
| PJM WESTERN (without AT | | 383,870 | 386,459 | 388,469 | 391,512 | 392,847 | 1.3% |
| | % | 0.5% | 0.7% | 0.5% | 0.8% | 0.3% | |
| DOM | | 125,393 | 127,828 | 130,301 | 133,153 | 135,408 | 2.2% |
| | % | 1.6% | 1.9% | 1.9% | 2.2% | 1.7% | |
| PJM RTO (with ATSI) | | 936,217 | 944,579 | 952,013 | 961,953 | 968,048 | 1.4% |
| | % | 0.7% | 0.9% | 0.8% | 1.0% | 0.6% | |
| PJM RTO (without ATSI) | | 855,883 | 863,956 | 871,244 | 880,854 | 886,789 | 1.5% |
| | % | 0.7% | 0.9% | 0.8% | 1.1% | 0.7% | |

Table E-2

**MONTHLY NET ENERGY FORECAST (GWh) FOR EACH
PJM MID-ATLANTIC ZONE AND GEOGRAPHIC REGION**

| | AE | BGE | DPL | JCPL | METED | PECO | PENLC | PEPCO | PL | PS | RECO | UGI | PJM MID-ATLANTIC |
|----------|-----------|------------|------------|-------------|--------------|-------------|--------------|--------------|-----------|-----------|-------------|------------|-------------------------|
| Jan 2010 | 975 | 3,263 | 1,757 | 2,161 | 1,470 | 3,662 | 1,673 | 2,971 | 3,977 | 4,055 | 129 | 104 | 26,197 |
| Feb 2010 | 861 | 2,857 | 1,544 | 1,898 | 1,307 | 3,237 | 1,496 | 2,615 | 3,516 | 3,609 | 113 | 92 | 23,145 |
| Mar 2010 | 890 | 2,844 | 1,517 | 1,976 | 1,355 | 3,351 | 1,578 | 2,613 | 3,597 | 3,833 | 122 | 92 | 23,768 |
| Apr 2010 | 816 | 2,521 | 1,339 | 1,804 | 1,219 | 3,043 | 1,428 | 2,377 | 3,150 | 3,586 | 114 | 78 | 21,475 |
| May 2010 | 861 | 2,616 | 1,399 | 1,893 | 1,255 | 3,153 | 1,461 | 2,507 | 3,197 | 3,760 | 123 | 77 | 22,302 |
| Jun 2010 | 1,010 | 3,090 | 1,638 | 2,219 | 1,331 | 3,557 | 1,458 | 3,020 | 3,323 | 4,325 | 145 | 80 | 25,196 |
| Jul 2010 | 1,270 | 3,568 | 1,936 | 2,666 | 1,479 | 4,109 | 1,563 | 3,436 | 3,680 | 5,014 | 171 | 91 | 28,983 |
| Aug 2010 | 1,240 | 3,483 | 1,893 | 2,555 | 1,461 | 4,010 | 1,580 | 3,335 | 3,647 | 4,865 | 163 | 89 | 28,321 |
| Sep 2010 | 939 | 2,805 | 1,508 | 1,989 | 1,254 | 3,252 | 1,461 | 2,721 | 3,216 | 3,928 | 127 | 77 | 23,277 |
| Oct 2010 | 878 | 2,637 | 1,414 | 1,931 | 1,289 | 3,212 | 1,518 | 2,481 | 3,282 | 3,825 | 123 | 80 | 22,670 |
| Nov 2010 | 857 | 2,669 | 1,424 | 1,902 | 1,285 | 3,179 | 1,506 | 2,471 | 3,355 | 3,715 | 120 | 86 | 22,569 |
| Dec 2010 | 977 | 3,151 | 1,681 | 2,163 | 1,462 | 3,595 | 1,669 | 2,875 | 3,889 | 4,061 | 131 | 103 | 25,757 |
| | AE | BGE | DPL | JCPL | METED | PECO | PENLC | PEPCO | PL | PS | RECO | UGI | MID-ATLANTIC |
| Jan 2011 | 1,006 | 3,345 | 1,786 | 2,222 | 1,521 | 3,730 | 1,728 | 3,024 | 4,079 | 4,155 | 131 | 107 | 26,834 |
| Feb 2011 | 886 | 2,922 | 1,565 | 1,949 | 1,345 | 3,285 | 1,538 | 2,652 | 3,590 | 3,682 | 115 | 93 | 23,622 |
| Mar 2011 | 920 | 2,914 | 1,537 | 2,031 | 1,396 | 3,403 | 1,624 | 2,648 | 3,679 | 3,913 | 124 | 94 | 24,283 |
| Apr 2011 | 858 | 2,591 | 1,357 | 1,861 | 1,258 | 3,114 | 1,470 | 2,410 | 3,225 | 3,672 | 117 | 80 | 22,013 |
| May 2011 | 909 | 2,695 | 1,421 | 1,957 | 1,298 | 3,233 | 1,509 | 2,550 | 3,290 | 3,855 | 126 | 80 | 22,923 |
| Jun 2011 | 1,061 | 3,179 | 1,664 | 2,290 | 1,374 | 3,641 | 1,503 | 3,063 | 3,412 | 4,431 | 149 | 82 | 25,849 |
| Jul 2011 | 1,338 | 3,648 | 1,958 | 2,736 | 1,515 | 4,195 | 1,601 | 3,472 | 3,755 | 5,107 | 174 | 93 | 29,592 |
| Aug 2011 | 1,311 | 3,581 | 1,926 | 2,643 | 1,515 | 4,130 | 1,637 | 3,396 | 3,763 | 5,003 | 167 | 91 | 29,163 |
| Sep 2011 | 999 | 2,879 | 1,528 | 2,056 | 1,292 | 3,342 | 1,504 | 2,764 | 3,299 | 4,026 | 130 | 79 | 23,898 |
| Oct 2011 | 941 | 2,705 | 1,433 | 2,006 | 1,335 | 3,328 | 1,573 | 2,529 | 3,387 | 3,935 | 126 | 83 | 23,381 |
| Nov 2011 | 917 | 2,737 | 1,446 | 1,976 | 1,332 | 3,292 | 1,560 | 2,521 | 3,457 | 3,826 | 123 | 88 | 23,275 |
| Dec 2011 | 1,034 | 3,217 | 1,705 | 2,238 | 1,509 | 3,709 | 1,723 | 2,926 | 3,992 | 4,173 | 134 | 105 | 26,465 |
| | AE | BGE | DPL | JCPL | METED | PECO | PENLC | PEPCO | PL | PS | RECO | UGI | MID-ATLANTIC |
| Jan 2012 | 1,064 | 3,408 | 1,810 | 2,301 | 1,573 | 3,863 | 1,789 | 3,087 | 4,200 | 4,270 | 135 | 109 | 27,609 |
| Feb 2012 | 974 | 3,082 | 1,643 | 2,092 | 1,444 | 3,527 | 1,653 | 2,802 | 3,831 | 3,925 | 122 | 99 | 25,194 |
| Mar 2012 | 978 | 2,963 | 1,551 | 2,101 | 1,440 | 3,517 | 1,676 | 2,689 | 3,777 | 4,013 | 127 | 96 | 24,928 |
| Apr 2012 | 913 | 2,640 | 1,375 | 1,939 | 1,305 | 3,243 | 1,528 | 2,460 | 3,340 | 3,784 | 120 | 82 | 22,729 |
| May 2012 | 968 | 2,749 | 1,441 | 2,041 | 1,350 | 3,371 | 1,573 | 2,604 | 3,416 | 3,982 | 130 | 82 | 23,707 |
| Jun 2012 | 1,123 | 3,228 | 1,682 | 2,375 | 1,420 | 3,771 | 1,557 | 3,110 | 3,516 | 4,549 | 153 | 85 | 26,569 |
| Jul 2012 | 1,394 | 3,703 | 1,980 | 2,831 | 1,572 | 4,347 | 1,661 | 3,529 | 3,883 | 5,244 | 179 | 96 | 30,419 |
| Aug 2012 | 1,367 | 3,633 | 1,948 | 2,735 | 1,568 | 4,273 | 1,696 | 3,450 | 3,883 | 5,137 | 172 | 94 | 29,956 |
| Sep 2012 | 1,045 | 2,917 | 1,540 | 2,128 | 1,334 | 3,456 | 1,557 | 2,800 | 3,398 | 4,121 | 133 | 81 | 24,510 |
| Oct 2012 | 987 | 2,752 | 1,456 | 2,085 | 1,388 | 3,455 | 1,636 | 2,583 | 3,512 | 4,056 | 130 | 86 | 24,126 |
| Nov 2012 | 959 | 2,779 | 1,469 | 2,053 | 1,381 | 3,409 | 1,618 | 2,577 | 3,567 | 3,939 | 126 | 91 | 23,968 |
| Dec 2012 | 1,073 | 3,252 | 1,722 | 2,306 | 1,545 | 3,810 | 1,763 | 2,970 | 4,080 | 4,242 | 136 | 107 | 27,006 |

Table E-2

**MONTHLY NET ENERGY FORECAST (GWh) FOR EACH
PJM WESTERN AND PJM SOUTHERN ZONE, GEOGRAPHIC REGION AND RTO**

| | | | | | | | PJM WESTERN (w | PJM WESTERN | | PJM RTO | PJM RTO |
|----------|--------|-------|-------|--------|-------|-------|-------------------|----------------|--------|----------|-----------|
| | AEP | APS | ATSI | COMED | DAY | DLCO | ATSI) | (wo ATSI) | DOM | (w ATSI) | (wo ATSI) |
| Jan 2010 | 12,838 | 4,791 | 6,204 | 8,958 | 1,598 | 1,268 | 35,657 | 29,453 | 9,039 | 70,893 | 64,689 |
| Feb 2010 | 11,321 | 4,235 | 5,569 | 7,969 | 1,412 | 1,129 | 31,635 | 26,066 | 7,865 | 62,645 | 57,076 |
| Mar 2010 | 11,590 | 4,306 | 5,836 | 8,342 | 1,471 | 1,193 | 32,738 | 26,902 | 7,694 | 64,200 | 58,364 |
| Apr 2010 | 10,354 | 3,775 | 5,375 | 7,706 | 1,333 | 1,106 | 29,649 | 24,274 | 6,830 | 57,954 | 52,579 |
| May 2010 | 10,672 | 3,834 | 5,549 | 7,996 | 1,379 | 1,165 | 30,595 | 25,046 | 7,158 | 60,055 | 54,506 |
| Jun 2010 | 11,203 | 4,004 | 5,702 | 8,726 | 1,506 | 1,258 | 32,399 | 26,697 | 8,524 | 66,119 | 60,417 |
| Jul 2010 | 12,302 | 4,408 | 6,296 | 10,212 | 1,680 | 1,420 | 36,318 | 30,022 | 9,640 | 74,941 | 68,645 |
| Aug 2010 | 12,257 | 4,384 | 6,276 | 9,864 | 1,672 | 1,392 | 35,845 | 29,569 | 9,394 | 73,560 | 67,284 |
| Sep 2010 | 10,668 | 3,836 | 5,543 | 8,155 | 1,389 | 1,175 | 30,766 | 25,223 | 7,731 | 61,774 | 56,231 |
| Oct 2010 | 10,886 | 3,920 | 5,670 | 8,183 | 1,414 | 1,167 | 31,240 | 25,570 | 7,206 | 61,116 | 55,446 |
| Nov 2010 | 10,995 | 4,036 | 5,568 | 8,067 | 1,412 | 1,146 | 31,224 | 25,656 | 7,370 | 61,163 | 55,595 |
| Dec 2010 | 12,554 | 4,692 | 6,138 | 9,026 | 1,576 | 1,258 | 35,244 | 29,106 | 8,745 | 69,746 | 63,608 |
| | | | | | | | | | | | |
| | AEP | APS | ATSI | COMED | DAY | DLCO | WESTERN | WESTERN | DOM | PJM RTO | PJM RTO |
| Jan 2011 | 13,084 | 4,928 | 6,334 | 9,210 | 1,639 | 1,286 | 36,481 | 30,147 | 9,304 | 72,619 | 66,285 |
| Feb 2011 | 11,485 | 4,337 | 5,653 | 8,166 | 1,442 | 1,140 | 32,223 | 26,570 | 8,071 | 63,916 | 58,263 |
| Mar 2011 | 11,763 | 4,411 | 5,929 | 8,560 | 1,508 | 1,205 | 33,376 | 27,447 | 7,908 | 65,567 | 59,638 |
| Apr 2011 | 10,528 | 3,861 | 5,488 | 8,011 | 1,375 | 1,120 | 30,383 | 24,895 | 7,051 | 59,447 | 53,959 |
| May 2011 | 10,895 | 3,939 | 5,684 | 8,334 | 1,431 | 1,183 | 31,466 | 25,782 | 7,409 | 61,798 | 56,114 |
| Jun 2011 | 11,428 | 4,104 | 5,833 | 9,059 | 1,556 | 1,276 | 33,256 | 27,423 | 8,789 | 67,894 | 62,061 |
| Jul 2011 | 12,517 | 4,490 | 6,431 | 10,612 | 1,730 | 1,436 | 37,216 | 30,785 | 9,934 | 76,742 | 70,311 |
| Aug 2011 | 12,591 | 4,505 | 6,477 | 10,365 | 1,745 | 1,420 | 37,103 | 30,626 | 9,738 | 76,004 | 69,527 |
| Sep 2011 | 10,896 | 3,927 | 5,685 | 8,554 | 1,441 | 1,194 | 31,697 | 26,012 | 8,004 | 63,599 | 57,914 |
| Oct 2011 | 11,182 | 4,024 | 5,868 | 8,667 | 1,481 | 1,193 | 32,415 | 26,547 | 7,502 | 63,298 | 57,430 |
| Nov 2011 | 11,299 | 4,147 | 5,762 | 8,543 | 1,474 | 1,172 | 32,397 | 26,635 | 7,676 | 63,348 | 57,586 |
| Dec 2011 | 12,877 | 4,815 | 6,322 | 9,497 | 1,633 | 1,283 | 36,427 | 30,105 | 9,080 | 71,972 | 65,650 |
| | | | | | | | | | | | |
| | AEP | APS | ATSI | COMED | DAY | DLCO | WESTERN | WESTERN | DOM | PJM RTO | PJM RTO |
| Jan 2012 | 13,431 | 5,054 | 6,707 | 9,708 | 1,699 | 1,314 | 37,913 | 31,206 | 9,685 | 75,034 | 68,327 |
| Feb 2012 | 12,230 | 4,610 | 5,995 | 8,930 | 1,552 | 1,209 | 34,526 | 28,531 | 8,701 | 68,482 | 62,487 |
| Mar 2012 | 12,043 | 4,508 | 6,241 | 9,028 | 1,564 | 1,228 | 34,612 | 28,371 | 8,222 | 67,627 | 61,386 |
| Apr 2012 | 10,846 | 3,953 | 5,872 | 8,510 | 1,444 | 1,150 | 31,775 | 25,903 | 7,365 | 61,699 | 55,827 |
| May 2012 | 11,237 | 4,039 | 6,066 | 8,880 | 1,507 | 1,217 | 32,946 | 26,880 | 7,742 | 64,246 | 58,180 |
| Jun 2012 | 11,738 | 4,180 | 6,161 | 9,567 | 1,624 | 1,306 | 34,576 | 28,415 | 9,134 | 70,152 | 63,991 |
| Jul 2012 | 12,882 | 4,586 | 6,859 | 11,151 | 1,810 | 1,475 | 38,763 | 31,904 | 10,312 | 79,316 | 72,457 |
| Aug 2012 | 12,944 | 4,595 | 6,827 | 10,916 | 1,821 | 1,456 | 38,559 | 31,732 | 10,101 | 78,503 | 71,676 |
| Sep 2012 | 11,165 | 3,995 | 6,019 | 9,016 | 1,505 | 1,222 | 32,922 | 26,903 | 8,298 | 65,593 | 59,574 |
| Oct 2012 | 11,507 | 4,127 | 6,200 | 9,171 | 1,550 | 1,225 | 33,780 | 27,580 | 7,816 | 65,609 | 59,409 |
| Nov 2012 | 11,608 | 4,241 | 6,039 | 9,021 | 1,531 | 1,203 | 33,643 | 27,604 | 7,982 | 65,523 | 59,484 |
| Dec 2012 | 13,115 | 4,895 | 6,454 | 9,872 | 1,674 | 1,300 | 37,310 | 30,856 | 9,400 | 73,677 | 67,223 |

Table E-3

**MONTHLY NET ENERGY FORECAST (GWh)
FOR FE/GPU AND PLGRP**

| | FE/GPU | PLGRP |
|----------|---------------|--------------|
| Jan 2010 | 5,304 | 4,081 |
| Feb 2010 | 4,701 | 3,608 |
| Mar 2010 | 4,909 | 3,689 |
| Apr 2010 | 4,451 | 3,228 |
| May 2010 | 4,609 | 3,274 |
| Jun 2010 | 5,008 | 3,403 |
| Jul 2010 | 5,708 | 3,771 |
| Aug 2010 | 5,596 | 3,736 |
| Sep 2010 | 4,704 | 3,293 |
| Oct 2010 | 4,738 | 3,362 |
| Nov 2010 | 4,693 | 3,441 |
| Dec 2010 | 5,294 | 3,992 |
| | | |
| | FE/GPU | PLGRP |
| Jan 2011 | 5,471 | 4,186 |
| Feb 2011 | 4,832 | 3,683 |
| Mar 2011 | 5,051 | 3,773 |
| Apr 2011 | 4,589 | 3,305 |
| May 2011 | 4,764 | 3,370 |
| Jun 2011 | 5,167 | 3,494 |
| Jul 2011 | 5,852 | 3,848 |
| Aug 2011 | 5,795 | 3,854 |
| Sep 2011 | 4,852 | 3,378 |
| Oct 2011 | 4,914 | 3,470 |
| Nov 2011 | 4,868 | 3,545 |
| Dec 2011 | 5,470 | 4,097 |
| | | |
| | FE/GPU | PLGRP |
| Jan 2012 | 5,663 | 4,309 |
| Feb 2012 | 5,189 | 3,930 |
| Mar 2012 | 5,217 | 3,873 |
| Apr 2012 | 4,772 | 3,422 |
| May 2012 | 4,964 | 3,498 |
| Jun 2012 | 5,352 | 3,601 |
| Jul 2012 | 6,064 | 3,979 |
| Aug 2012 | 5,999 | 3,977 |
| Sep 2012 | 5,019 | 3,479 |
| Oct 2012 | 5,109 | 3,598 |
| Nov 2012 | 5,052 | 3,658 |
| Dec 2012 | 5,614 | 4,187 |

Note: FE/GPU contains JCPL, METED, and PENLC zones; PLGRP contains PL and UGI zones.

THIS PAGE INTENTIONALLY LEFT BLANK

TABLE F-1**PJM RTO HISTORICAL PEAKS
(MW)****SUMMER**

| YEAR | NORMALIZED BASE | NORMALIZED COOLING | NORMALIZED TOTAL | UNRESTRICTED PEAK | PEAK DATE/TIME |
|-------------|------------------------|---------------------------|-------------------------|--------------------------|----------------------------|
| 1998 | 72,950 | 38,170 | 111,120 | 114,996 | Tuesday 07/21/1998 17:00 |
| 1999 | 73,990 | 42,980 | 116,970 | 121,655 | Tuesday 07/06/1999 17:00 |
| 2000 | 76,300 | 40,080 | 116,380 | 114,178 | Wednesday 08/09/2000 17:00 |
| 2001 | 75,990 | 45,080 | 121,070 | 131,116 | Thursday 08/09/2001 16:00 |
| 2002 | 77,140 | 48,120 | 125,260 | 130,360 | Thursday 08/01/2002 17:00 |
| 2003 | 77,650 | 46,700 | 124,350 | 126,332 | Thursday 08/21/2003 17:00 |
| 2004 | | | 130,645 | 120,235 | Wednesday 06/09/2004 17:00 |
| 2005 | | | 133,550 | 134,219 | Tuesday 07/26/2005 16:00 |
| 2006 | | | 134,905 | 145,951 | Wednesday 08/02/2006 17:00 |
| 2007 | | | 136,095 | 140,948 | Wednesday 08/08/2007 16:00 |
| 2008 | | | 136,315 | 130,792 | Monday 06/09/2008 17:00 |
| 2009 | | | 133,780 | 126,944 | Monday 08/10/2009 17:00 |

WINTER

| YEAR | NORMALIZED BASE | NORMALIZED HEATING | NORMALIZED TOTAL | UNRESTRICTED PEAK | PEAK DATE/TIME |
|-------------|------------------------|---------------------------|-------------------------|--------------------------|----------------------------|
| 97/98 | | | | 88,970 | Wednesday 01/14/1998 19:00 |
| 98/99 | | | | 99,982 | Tuesday 01/05/1999 19:00 |
| 99/00 | | | | 102,359 | Thursday 01/27/2000 20:00 |
| 00/01 | | | | 101,717 | Wednesday 12/20/2000 19:00 |
| 01/02 | | | | 97,294 | Thursday 01/03/2002 19:00 |
| 02/03 | | | | 112,755 | Thursday 01/23/2003 19:00 |
| 03/04 | | | 108,110 | 106,760 | Monday 01/26/2004 19:00 |
| 04/05 | | | 110,250 | 114,061 | Monday 12/20/2004 19:00 |
| 05/06 | | | 111,745 | 110,415 | Wednesday 12/14/2005 19:00 |
| 06/07 | | | 112,455 | 118,800 | Monday 02/05/2007 20:00 |
| 07/08 | | | 113,185 | 111,724 | Thursday 01/03/2008 19:00 |
| 08/09 | | | 113,150 | 117,169 | Friday 01/16/2009 19:00 |

Notes: Normalized values for 1998 - 2003 are calculated by PJM staff using the bottom-up coincident peak weather-normalization methodology.

Normalized values for 2004 - 2009 are calculated by PJM staff using a methodology consistent with the PJM Load Forecast Model.

All times are shown in hour ending Eastern Prevailing Time.

All historic peak values reflect the membership of the PJM RTO as of December 31, 2009.

TABLE F-2
PJM RTO HISTORICAL NET ENERGY
(GWH)

| YEAR | ENERGY | GROWTH RATE |
|-------------|---------------|--------------------|
| 1998 | 620,061 | 0.8% |
| 1999 | 636,404 | 2.6% |
| 2000 | 651,190 | 2.3% |
| 2001 | 651,319 | 0.0% |
| 2002 | 673,526 | 3.4% |
| 2003 | 674,471 | 0.1% |
| 2004 | 689,008 | 2.2% |
| 2005 | 682,441 | -1.0% |
| 2006 | 694,989 | 1.8% |
| 2007 | 724,541 | 4.3% |
| 2008 | 713,910 | -1.5% |

Note: All historic net energy values reflect the membership of the PJM RTO as of December 31, 2009.

Table G-1

**ANNUALIZED AVERAGE GROWTH OF GROSS METROPOLITAN PRODUCT
FOR EACH PJM ZONE AND RTO**

| | 5-Year (2010-15) | 10-Year (2010-20) | 15 Year (2010-25) |
|------------------------|-----------------------------|------------------------------|------------------------------|
| AE | 3.9% | 2.5% | 2.0% |
| BGE | 3.3% | 2.9% | 2.6% |
| DPL | 2.5% | 2.2% | 2.1% |
| JCPL | 3.2% | 2.3% | 1.9% |
| METED | 2.8% | 1.9% | 1.6% |
| PECO | 2.6% | 1.8% | 1.4% |
| PENLC | 2.5% | 2.1% | 1.8% |
| PEPCO | 3.3% | 2.7% | 2.4% |
| PL | 2.5% | 1.7% | 1.3% |
| PS | 3.2% | 2.3% | 1.9% |
| RECO | 3.3% | 2.4% | 2.0% |
| UGI | 2.2% | 1.4% | 1.0% |
| AEP | 3.9% | 2.5% | 2.0% |
| APS | 2.9% | 1.9% | 1.5% |
| ATSI | 2.7% | 1.7% | 1.3% |
| COMED | 3.4% | 2.4% | 1.8% |
| DAY | 2.5% | 1.4% | 1.0% |
| DLCO | 2.8% | 2.3% | 1.9% |
| DOM | 3.8% | 3.2% | 2.9% |
| PJM RTO (with ATSI) | 3.2% | 2.4% | 2.0% |
| PJM RTO (without ATSI) | 3.2% | 2.4% | 2.1% |

Source: Moody's Economy.com, November, 2009

Note: Values presented are annualized compound average growth rates.

In the
United States Court of Appeals
For the Seventh Circuit

Nos. 08-1306, 08-1780, 08-2071, 08-2124, 08-2239

ILLINOIS COMMERCE COMMISSION, *et al.*,

Petitioners,

v.

FEDERAL ENERGY REGULATORY COMMISSION, *et al.*,

Respondents.

Petitions to Review Orders of the
Federal Energy Regulatory Commission.

ARGUED APRIL 13, 2009—DECIDED AUGUST 6, 2009

Before CUDAHY, POSNER, and TINDER, *Circuit Judges*.

POSNER, *Circuit Judge*. We have before us challenges to a decision by the Federal Energy Regulatory Commission concerning the reasonableness of rates for the transmission of electricity over facilities owned by utilities that belong to a Regional Transmission Organization (that is, a power pool) called PJM Interconnection. *PJM Interconnection, L.L.C.*, 119 F.E.R.C. ¶ 61,063 (2007), rehearing denied, 122 F.E.R.C. ¶ 61,082 (2008); see 16 U.S.C. § 824e; *Atlantic City Electric Co. v. FERC*, 295 F.3d 1, 10 (D.C. Cir. 2002). (“PJM”

stands for “Pennsylvania-New Jersey-Maryland,” but the full name is not used any more.) “RTOs are voluntary associations in which each of the owners of transmission lines that comprise an integrated regional grid cedes to the RTO complete operational control over its transmission lines.” Richard J. Pierce, Jr., “Regional Transmission Organizations: Federal Limitations Needed for Tort Liability,” 23 *Energy L.J.* 63, 64 (2002); see also *Regional Transmission Organizations*, 65 Fed. Reg. 810-01, 2000 WL 4557 (FERC Jan. 6, 2000); *Morgan Stanley Capital Group Inc. v. Public Utility District No. 1*, 128 S. Ct. 2733, 2741 (2008). PJM’s region stretches east and south from the Chicago area, primarily to western Michigan and eastern Indiana, Ohio, Pennsylvania, New Jersey, Delaware, Maryland, the District of Columbia, and Virginia. *PJM Interconnection, L.L.C.*, *supra*, p. 3, see *FPL Energy Marcus Hook, L.P. v. FERC*, 430 F.3d 441, 442-43 (D.C. Cir. 2005). The region is home to more than 50 million consumers of electricity.

Two issues are presented. The first, raised by American Electric Power Service Corporation and the Public Utilities Commission of Ohio (participation by state commissions in rate proceedings before FERC is authorized by 16 U.S.C. § 825g(a); see also § 825l(a)), involves the pricing of electricity transmitted from the Midwest to the East through Ohio. PJM wants that transmission to be priced on the basis of the cost to American Electric of transmitting one more unit of electricity, that is, the marginal cost; and FERC agrees. Such a price excludes the cost that the company incurred when it built the transmission facilities. That cost—which American

Electric wants to be permitted to reflect in its rates—is what economists call a “sunk” cost, that is, a cost that has already been incurred. So while its financial burden can be shifted (from American Electric to the eastern utilities), the cost itself cannot be shifted, and therefore shifting the financial burden created by the cost from one set of shoulders to another will have no direct effect on service or investment.

Had FERC decided that American Electric would not be permitted to charge a price that covered the cost of building a new transmission facility or upgrading an existing one, its decision would have affected the allocation of resources and not just of money. It would have deterred the building of new facilities that benefited customers outside American Electric’s service area, because building them would become an unprofitable venture. FERC emphasizes, however, that the company’s existing facilities, which are all that are involved in this case, were built before 2001 when PJM became a Regional Transmission Organization, and were intended to serve American Electric’s customers only. So even if the facilities had not been fully paid for, there would be no economic basis for shifting any part of their costs to other members, because American Electric did not expect when it built the facilities that any part of their cost would be defrayed by anyone besides its customers. PJM and FERC have made clear that American Electric *will* be allowed to charge a price that covers its costs for transmission to other utilities over new or upgraded facilities.

American Electric points out that some of its existing facilities are not fully depreciated. But it can continue to depreciate them over their remaining useful life in order to create an accounting reserve or obtain a tax benefit. And when it builds a new facility it will be allowed, as we said, to recover the full costs of that facility in its prices.

The company may be trying to extract a monopoly price for the use of its facilities. It stands between western sellers of electricity and their eastern customers and would like to extract a toll for giving the former passage to the latter, a toll that has no relation to its costs of rendering that service. It charged its customers for the costs of building its existing facilities and recovered those costs fully and now wants to recover them all over again from another group of consumers. And it's not as if American Electric were being required to provide transmission to the east at zero price. It is permitted to charge for the service—just not to include in the charge its sunk costs.

The second issue relates to the financing of new transmission facilities. Here the Ohio commission joins its Illinois counterpart, representing the interests of the midwestern utilities in PJM's region, in objecting to PJM's proposed method, approved by FERC, for pricing new transmission facilities that have a capacity of 500 kilovolts or more. Heretofore all new facilities in PJM's region have been financed by contributions from the region's electrical utilities calculated on the basis of the benefits that each utility receives from the facilities. This will continue to be the rule for facilities with capacities of

less than 500 kV. But for the higher-voltage facilities FERC has decided that all the utilities in PJM's region should contribute pro rata; that is, their rates should be raised by a uniform amount sufficient to defray the facilities' costs.

FERC's stated reasons are that some of PJM's members entered into similar pro rata sharing agreements with each other more than forty years ago and would like to follow that precedent, that figuring out who benefits from a new transmission facility and by how much is very difficult and so generates litigation, and that everyone benefits from high-capacity transmission facilities because they increase the reliability of the entire network. Despite the stakes in the dispute—the new policy might, for example, force Commonwealth Edison to contribute hundreds of millions of dollars to an above-500 kV eastern project called "Project Mountaineer," when it would not have had to pay a dime under the benefits-based system applicable to lower-voltage transmission facilities—no data are referred to in FERC's two opinions (the original opinion and the opinion on rehearing). No lawsuits are mentioned. No specifics concerning difficulties in assessing benefits are offered. No particulars are presented concerning the contribution that very high-voltage facilities are likely to make to the reliability of PJM's network. Not even the roughest estimate of likely benefits to the objecting utilities is presented. The first sentence in this paragraph is an adequate summary of the Commission's reasoning, minus recourse to metaphor, as in the Commission's repeated references to very high-voltage facilities as the "backbone" of PJM's network. The Commission's insouciance about the basis for its ruling

is mirrored by its lawyers: their brief devotes only five pages to the 500 kV pricing issue.

The objections to the Commission's ruling pivot on an asymmetry between the eastern and western portions of PJM's region. In the west the electrical generating plants usually are close to the customers—Chicago for example is ringed by power plants. As a result, relatively low-voltage transmission facilities—mainly 345 kV—are preferred. In the east, where the power plants generally are farther away from the customers, 500 kV and even higher-voltage transmission facilities are preferred, because high voltage is more efficient than low for transmitting electricity over long distances. So far as appears, few if any such facilities will be built in the objectors' service areas, that is, in the Midwest, within the foreseeable future. FERC seems not to care whether any will ever be built, because the reasons it gave for approving PJM's new pricing method are independent of where the facilities are located.

The first two reasons the Commission gave can be dispatched briefly. The fact that some of the same members of PJM who agreed to share the costs of such facilities with each other many years ago would like contributions from midwestern utilities carries no weight. The eastern utilities that created PJM refer to themselves revealingly as the "classic" PJM utilities, and the fact that these utilities thought it appropriate to share costs in 1967 says nothing about the advantages and disadvantages of such an arrangement in the larger, modern PJM network.

The Commission said that it would be inclined to defer to “regional consensus,” but acknowledged there was none; the midwestern utilities are part of PJM’s region but did not agree to the eastern utilities’ cost-sharing proposal. As we shall see, the fact that one group of utilities desires to be subsidized by another is no reason in itself for giving them their way.

The second reason the Commission gave for approving PJM’s pricing scheme—the difficulty of measuring benefits and the resulting likelihood of litigation over them—fails because of the absence of any indication that the difficulty exceeds that of measuring the benefits to particular utilities of a smaller-capacity transmission line. Like the D.C. Circuit in *Sithe/Independence Power Partners, L.P. v. FERC*, 285 F.3d 1, 5 (D.C. Cir. 2002) (citation omitted), we acknowledge “that feasibility concerns play a role in approving rates, indicating that FERC is not bound to reject any rate mechanism that tracks the cost-causation principle less than perfectly.” But we also agree that “the Commission’s cursory response simply will not do. At no point did the Commission explain how these considerations [that the tariffs and refund mechanism produced ‘efficient price signals,’ and that petitioner’s requested refunds would somehow disrupt that price signaling, would be ‘infeasible,’ and a matter of ‘unending controversy’] applied. Why, we wonder, would a different method of refunds, based more closely on cost-causation principles, jeopardize desirable price signaling or be infeasible?” *Id.*

No doubt the more a transmission facility costs, and therefore the greater the stakes in a dispute between

potential contributors to that cost, the more litigation there is likely to be. But how much more (at least approximately) is the critical consideration and the Commission ignored it.

That leaves for consideration the benefits that the midwestern utilities might derive from the greater reliability that the larger-capacity transmission facilities might confer on the network as a whole. The reason for building such facilities is to satisfy the demand of eastern consumers for electricity, but the more transmission capacity there is, the less likely are blackouts or brownouts caused by surges of demand for electricity on hot summer days or by accidents that shut down a part of the electrical grid. Because the transmission lines in PJM's service region are interconnected, a failure in one part of the region can affect the supply of electricity in other parts of the network. So utilities and their customers in the western part of the region could benefit from higher-voltage transmission lines in the east, but nothing in FERC's opinions in this case enables even the roughest of ballpark estimates of those benefits.

At argument FERC's counsel reluctantly conceded that if Commonwealth Edison would derive only \$1 million in expected benefits from Project Mountaineer, for which it is being asked to chip in (by its estimate) \$480 million, the disparity between benefit and cost would be unreasonable. The concession was prudent. *Algonquin Gas Transportation Co. v. FERC*, 948 F.2d 1305, 1313 (D.C. Cir. 1991); *Pacific Gas & Electric Co. v. FERC*, 373 F.3d 1315, 1320-21 (D.C. Cir. 2004). As FERC itself explained in *Trans-*

continental Gas Pipe Line Corp., 112 F.E.R.C. ¶ 61,170, 61,924-61,925 (2005), “a claim of generalized system benefits is not enough to justify requiring the existing shippers to subsidize the uncontested increase in electric costs caused by the Cherokee project. . . . The rehearing applicants suggest that the use of the Cherokee shippers’ transportation quantities in deriving the fuel retention percentages and their payment of such charges reduce the fuel costs borne by the existing shippers. However, they point to no evidence in the record that seeks to quantify this benefit, or even shows that such a benefit has occurred The Commission concludes that all these alleged benefits are simply too speculative and unsupported to be taken into account.”

FERC is not authorized to approve a pricing scheme that requires a group of utilities to pay for facilities from which its members derive no benefits, or benefits that are trivial in relation to the costs sought to be shifted to its members. “[A]ll approved rates [must] reflect to some degree the costs actually caused by the customer who must pay them.” *KN Energy, Inc. v. FERC*, 968 F.2d 1295, 1300 (D.C. Cir. 1992); *Transmission Access Policy Study Group v. FERC*, 225 F.3d 667, 708 (D.C. Cir. 2000); *Pacific Gas & Elec. Co. v. FERC*, No. 03-1025, 373 F.3d 1315, 1320-21 (D.C. Cir. 2004). Not surprisingly, we evaluate compliance with this unremarkable principle by comparing the costs assessed against a party to the burdens imposed or benefits drawn by that party.” *Midwest ISO Transmission Owners v. FERC*, 373 F.3d 1361, 1368 (D.C. Cir. 2004); see also *Alcoa Inc. v. FERC*, 564 F.3d 1342, 1346-47 (D.C. Cir. 2009); *Sithe/Independence Power Partners, L.P. v. FERC*, *supra*,

285 F.3d at 4-5; Federal Power Act, 16 U.S.C. § 824d. To the extent that a utility benefits from the costs of new facilities, it may be said to have “caused” a part of those costs to be incurred, as without the expectation of its contributions the facilities might not have been built, or might have been delayed. But as far as one can tell from the Commission’s opinions in this case, the likely benefit to Commonwealth Edison from new 500 kV projects is zero. The opinion on rehearing attributes the need for new transmission capacity in PJM to the threat of “degraded reliability in *Eastern PJM*,” 122 F.E.R.C. ¶ 61,082, p. 13 (emphasis added), and nowhere do the Commission’s opinions suggest that degraded reliability is a danger in Midwestern PJM.

No doubt there will be *some* benefit to the midwestern utilities just because the network *is* a network, and there have been outages in the Midwest. But enough of a benefit to justify the costs that FERC wants shifted to those utilities? Nothing in the Commission’s opinions enables an answer to that question. Although the Commission did say that a 500 kV transmission line has twice the capacity of a 345 kV line, it added that “the *reliability* of 500 kV and above circuits in terms of momentary and sustained interruptions is 70 percent more reliable than 138 kV circuits and 60 percent more than 230 kV circuits on a per mile basis,” *PJM Interconnection, L.L.C., supra*, 119 F.E.R.C. ¶ 61,063, p. 23; 122 F.E.R.C. ¶ 61,082, p. 16 (emphasis added)—but did not compare the reliability of a 500 kV line to that of a 345 kV line, even though network reliability is the benefit that the Commission

thinks the midwestern utilities will obtain from new 500 kV lines in the East.

Rather desperately FERC's lawyer, and the lawyer for the eastern utilities that intervened in support of its ruling, reminded us at argument that Commission has a great deal of experience with issues of reliability and network needs, and they asked us therefore (in effect) to take the soundness of its decision on faith. But we cannot do that because we are not authorized to uphold a regulatory decision that is not supported by substantial evidence on the record as a whole, or to supply reasons for the decision that did not occur to the regulators. E.g., 5 U.S.C. § 706; *Bethany v. FERC*, 276 F.3d 934, 940 (7th Cir. 2002); *Central Illinois Public Service Co. v. FERC*, 941 F.2d 622, 627 (7th Cir. 1991); *Pacific Gas & Electric Co. v. FERC*, *supra*, 373 F.3d at 1319. The reasons that did occur to FERC are inadequate.

We do not suggest that the Commission has to calculate benefits to the last penny, or for that matter to the last million or ten million or perhaps hundred million dollars. *Midwest ISO Transmission Owners v. FERC*, *supra*, 373 F.3d at 1369 ("we have never required a ratemaking agency to allocate costs with exacting precision"); *Sithe/Independence Power Partners, L.P. v. FERC*, *supra*, 285 F.3d at 5. If it cannot quantify the benefits to the midwestern utilities from new 500 kV lines in the East, even though it does so for 345 kV lines, but it has an articulable and plausible reason to believe that the benefits are at least roughly commensurate with those utilities' share of total electricity sales in PJM's region, then fine;

the Commission can approve PJM's proposed pricing scheme on that basis. For that matter it can presume that new transmission lines benefit the entire network by reducing the likelihood or severity of outages. E.g., *Western Massachusetts Elec. Co. v. FERC*, 165 F.3d 922, 927 (D.C. Cir. 1999). But it cannot use the presumption to avoid the duty of "comparing the costs assessed against a party to the burdens imposed or benefits drawn by that party." *Midwest ISO Transmission Owners v. FERC*, *supra*, 373 F.3d at 1368. Nor did it in the *Western Massachusetts* case.

In *Midwest ISO*, where the objecting utilities contended that they were being asked to pay far more than their share of the benefits—which they said was a measly 5 percent—the court found that they were misrepresenting the record. 373 F.3d at 1370. There is no comparable basis on which to affirm the Commission's decision in this case. Our review of decisions by FERC is deferential, e.g., *Town of Norwood v. FERC*, 962 F.2d 20, 22 (D.C. Cir. 1992); "we require only that the agency have made a reasoned decision based upon substantial evidence in the record." *Id.* But the Commission failed to do that, and so the case must be remanded for further proceedings; we intimate no view on their outcome.

To summarize, the petitions for review that concern the pricing of existing transmission facilities are denied, but the petitions concerning the pricing of new facilities that have a capacity of 500 kilovolts or more are granted.

CUDAHY, *Circuit Judge*, concurring in part and dissenting in part. I concur fully in the majority's approval of FERC's rate design for existing facilities' transmission costs. I write separately to express my concerns over the majority's disapproval of the proposed rate design for new transmission lines operating at voltages at or in excess of 500,000 volts.

The United States is now engaged in an urgent project to upgrade its electric transmission grid, which for years has been generally regarded as inadequate,¹ and may become more deficient with the addition of major new anticipated loads.² The existing transmission system originally served vertically integrated utilities that built their own generation relatively close to their customers. The system was not designed for long-distance power

¹ *E.g.*, *House Report on the Energy Policy Act of 2005*, H.R. Rep. No. 109-215(I), at 171 ("Investment in electric transmission expansion has not kept pace with electricity demand. Moreover, transmission system reliability is suspect as demonstrated by the blackout that hit the Northeast and Midwest in August of 2003. Legislation is needed to address the issues of transmission capacity, operation, and reliability. In addition, state regulatory approval delays siting of new transmission lines by many years. Even if a project is completed, there is uncertainty as to whether utilities will be able to recover all of their investment, which hinders new transmission construction.").

² *See, e.g.*, Argonne, *Impact of Plug-in Hybrid Electric Vehicles on the Electricity Market in Illinois*, available at http://www.dis.anl.gov/news/Illinois_PluginHybrids.html (visited 7/27/09).

transfers between different parts of the country. The inadequacy of the present network and the urgency of the need for its improvement has only been exacerbated by the additional burdens imposed by deregulation (or restructuring), which “unbundled” generation and transmission and created a need to bring power from distant generators.³ Additional challenges have been posed by the demand for power from renewable generation sources (such as wind farms) that are often located in places remote from centers of electric consumption.⁴

Long-distance transmission, which inherently presents challenges to reliability, is accomplished most efficiently by the highest levels of voltage—500 kV and above. According to FERC, “500 kV and above circuits . . . [are] 70 percent more reliable than 138 kV circuits and 60 percent more than 230 kV circuits on a per mile basis.” *PJM Interconnection LLC*, 122 FERC ¶ 61,082, 2008 WL 276596, at *16 (Jan. 31, 2008) (order on rehearing). Further, because power transfer capability increases with the square of voltage,⁵ extra-high voltage transmission also

³ See Mark Cooper, *Electricity Deregulation Puts Pressure on the Transmission Network and Increases its Cost*, available at <http://www.consumersunion.org/Transmission%20brief%208.27.pdf> (visited 7/27/09).

⁴ See Matthew L. Wald, *Debate on Clean Energy Leads to Regional Divide*, N.Y. Times, July 14, 2009, at A13.

⁵ See generally Peter W. Sauer, *Reactive Power and Voltage Control Issues in Electric Power Systems*, Applied Mathematics for
(continued...)

facilitates enormous transfers of power: “the maximum transfer capability at 500 kV and above is approximately 6 times greater than a similar transmission line operated at 230 kV and more than twice that at 345 kV” *Id.* In light of its unique contributions to reliability and transfer capability, extra-high voltage transmission is especially fitted to be financed equally by all utilities that benefit from its role as the “backbone” of the system.⁶ Pro rata rates for extra-high voltage transmission, through their simplicity of application, also provide a strong incentive to build transmission undeterred by fruitless controversy over the allocation of costs.

It is significant that FERC’s conclusion that the costs of extra-high voltage transmission facilities should be shared is consistent with the proposals of fifteen of PJM’s seventeen members. In the course of this proceeding,

⁵ (...continued)

Restructured Electric Power Systems: Optimization, Control, and Computational Intelligence (Joe H. Chow, Felix F. Wu & James A. Momoh, eds.) (2005).

⁶ These are “backbone” facilities because they “integrate major system resources,” *Pacific Gas & Elec. Co.*, 53 FERC ¶ 61146, 61520-21 & n.65, 1990 WL 319356, at *10 (Oct. 31, 1990), by facilitating major transfers of power between and among regions. To my knowledge, no court prior to ours has objected to the metaphor. See *Public Serv. Co. of Ind., Inc. v. FERC*, 575 F.2d 1204, 1217 (7th Cir. 1978); see also *Cal. Dep’t of Water Res. v. FERC*, 489 F.3d 1029, 1035 (9th Cir. 2007); *Boston Edison Co. v. FERC*, 441 F.3d 10, 11 (1st Cir. 2006); *Cajun Elec. Power Coop., Inc. v. FERC*, 924 F.2d 1132, 1134 (D.C. Cir. 1991).

various parties proposed voltages lower than 500 kV as the threshold above which proportional cost-sharing should apply. Although PJM's members were unable to agree on a specific voltage cutoff, they were broadly in agreement that the rate structure should be designed to share the costs of facilities providing general systemic benefits. There was thus an effort by many parties to broaden the area of rate-simplification by enlarging the set of new transmission facilities to be governed by cost-sharing, not to narrow or eliminate it. I think these efforts illustrate the value of simplification and the difficulties in the design of a transmission rate structure that attempts rigidly and in all circumstances to trace benefits to specific utilities.

However theoretically attractive may be the principle of "beneficiary pays," an unbending devotion to this rule in every instance can only ignite controversy, sustain arguments and discourage construction while the nation suffers from inadequate and unreliable transmission. Unsurprisingly, it is not possible to realistically determine for each utility and with reference to each major project the likelihood that rate-simplification will reduce litigation, or to calculate the precise value of not having to cover the costs of power failures and of not paying costs associated with congestion, and all this over the next forty to fifty years. Concerns about the real value to individual utilities of the stability and efficiency provided by improvements to the backbone grid are answered by their voluntary participation in the power pool and its collaborative "RTEP" (or regional transmission expansion planning) process. Rate-making based on cost

causation is assured by this process, since universal cost-sharing is recommended only when developments are found to benefit the integrated system as a whole.⁷

Contrary to the majority's suggestion, FERC did not violate principles of "cost causation" by failing to propose a number that would represent the specific monetary benefits to each utility of a more reliable network. Cost causation requires that "approved rates reflect to some degree the costs actually caused by the customer who must pay them." *Midwest ISO Transmission Owners v. FERC*, 373 F.3d 1361, 1368 (D.C. Cir. 2004) (Roberts, J.) (quoting *KN Energy, Inc. v. FERC*, 968 F.2d 1294, 1300 (D.C. Cir. 1992)) (internal quotation marks omitted). However, until today, no court has found that cost causation requires FERC to monetize the benefits of reliability improvements in

⁷ "Project Mountaineer," with which the majority seems particularly concerned, is no exception. Project Mountaineer is a plan to construct hundreds of miles of 500 and 765 kV linkages between eastern and western PJM. The PJM literature, to which Commonwealth Edison could have objected but did not, indicates that Project Mountaineer was a response to the nearly 200% increase in congestion costs from 2004 to 2005. Ventyx, *Major Transmission Constraints in PJM*, at *3 n.4 (2007), available at <http://www.ventyx.com/pdf/wp07-transmission-constraints.pdf> (visited 7/14/09). These increased congestion costs were partly due to the expansion of PJM's footprint. *Id.* As part of its cost allocation process, PJM determined that Project Mountaineer "would bring about substantial congestion relief and reliability improvements increasing Midwest-to-east transfers by 5,000 MW." *Id.* at *3.

order to share the costs. Indeed, the cases the majority cites support the opposite conclusion. Most notably, in *Midwest ISO*, the panel was quite clear that utilities that draw benefits from being a part of a power pool should share the cost of *having* a power pool. *Id.* at 1371. As then-Judge Roberts explained, “upgrades designed to preserve the grid’s reliability constitute system enhancements that *are presumed to benefit the entire system.*” *Id.* at 1369 (internal quotation marks, citations and alterations omitted, and emphasis added); *see also Entergy Servs., Inc. v. FERC*, 319 F.3d 536, 543 (D.C. Cir. 2003); *Western Massachusetts Elec. Co. v. FERC*, 165 F.3d 922, 927 (D.C. Cir. 1999). Since there is a *presumption* that enhanced reliability benefits all of the systems members, Commonwealth Edison (ComEd) can be required to bear a proportional share of an improvement’s costs even where it is not possible to determine precisely how much it benefits. Put otherwise, the burden is on ComEd to show that it would *not* benefit from the newly planned transmission facilities; the burden is not on FERC to estimate how much ComEd would benefit from a more reliable grid.

Indeed, in *Midwest ISO*, the panel *rejected* the objecting utility’s argument that it could not be made to pay sixty to seventy percent of an investment’s costs because it would obtain only five percent of the benefits. 373 F.3d at 1370. As the majority notes, the panel found no record support for the utility’s claim that its benefits would be so low. (Maj. Op. at 12.) However, the panel also held that cost causation principles do not require the costs of a new facility to be apportioned based on the objecting utility’s actual *use* of that facility. To the

contrary, the “benefits” of system enhancements must be understood more broadly than this. Again, then-Judge Roberts:

even if they are not in some sense *using* the ISO [roughly a term for a power pool], the MISO Owners still benefit from *having* an ISO. In this sense, MISO is somewhat like the federal court system. It costs a considerable amount to set up and maintain a court system, and these costs—the costs of *having* a court system—are borne by the taxpayers, even though the vast majority of them will have no contact with that system (will not *use* that system) in any given year . . . The MISO Owners’ position is tantamount to saying that if they are not a litigant, they should not be made to pay for any of the costs of *having* a court system. Since the MISO Owners do, in fact, draw benefits from being a part of the MISO regional transmission system, FERC correctly determined that they should share the cost of *having* an ISO.

Id. at 1371. I fear that the majority has lost sight of this basic principle.⁸

⁸ The other cases on which the majority relies also do not hold that FERC is required to explain the benefits of reliability. For instance, in *Algonquin Gas Transmission Co. v. FERC*, 948 F.2d 1305 (D.C. Cir. 1991), the court rejected FERC’s proposal to share the costs of a new gas pipeline because FERC had not provided *any* evidence that the pipeline would provide system-wide benefits. *Id.* at 1313. In the present case, by contrast, there
(continued...)

Because the majority's decision is based on an unusually narrow conception of cost-causation, its characterizations of FERC's and the intervenor's arguments as "insouciant" (Maj. Op. at 5) and "desperate" (Maj. Op. at 11) strike me as conspicuously misplaced. FERC responded to ComEd's objections by indicating that the proposed projects would improve reliability and reduce congestion. *See PJM Interconnection*, 2008 WL 276596, at *16. It did not explain how PJM's members benefit from a reliable network because no court had hitherto required it to do so. Until now, it went without saying that network reliability benefits the network's members. This is not insouciance; "[e]xplanations come to an end somewhere." Ludwig Wittgenstein, *Philosophical Investigations* §1 (G.E.M. Anscombe trans., 1968).

The big picture here is that FERC's proposal to spread the cost of very high voltage transmission on a uniform

⁸ (...continued)

is no dispute that the transmission facilities at issue would increase network transfer capacity and improve network reliability.

Along the same lines, *Alcoa Inc. v. FERC*, 564 F.3d 1342 (D.C. Cir. 2009), provides no support at all for the majority's robust understanding of the requirements of cost causation. In that case, the D.C. Circuit *rejected* Alcoa's claim that it was being asked to pay more than its fair share of the costs of maintaining network reliability, holding instead that because rate design rests on technical issues and policy judgments that lie at the core of the regulatory mission, FERC's explanation for its rate scheme "although admittedly spare, is nonetheless adequate." *Id.* at 1347-48.

basis seems to me in the interest of efficient, high-capacity transfer capability and of the closely linked improvement of reliability, which affects the system generally.⁹ Deregulation created a demand for competitive sources of power, often at a distance. Because 500 kV and above lines satisfy these new systemic needs, their separate treatment for rate-making purposes is both sensible and innovative. While an effort to identify specific benefits to

⁹ Indeed, the majority concedes that reliability problems affect all of the system's users when it acknowledges that failures in one part of an integrated network can affect the supply of electricity in other parts of the network. (Maj. Op. at 8). So-called "cascading outages" have occurred on a number of occasions in the recent past. Most notably, in 2003 a power failure that started in Ohio spread through eight states, including parts of PJM's footprint, leaving 50 million people without power and causing an estimated \$12 billion in economic losses. *E.g.*, Peter Fox-Penner, *A Year Later, Lessons From the Blackout*, N.Y. Times, Aug. 15, 2004, at 14WC. As the majority notes, FERC has not estimated the probability that degraded reliability in Eastern PJM could affect Midwestern PJM. However, even if this probability is vanishingly small, a very low number multiplied by billions of dollars may still yield a very high number. Further, there is no reason to suppose that ComEd's customers are unaffected by problems with the reliability of the PJM grid. By one estimate, power outages and disturbances cause \$4 to \$7 billion in damages per year in Illinois alone. *See* Primen, *The Cost of Power Disturbances to Industrial & Digital Economy Companies* (June 29, 2001), at D-1, available at <http://www.onpower.com/pdf/EPRICostOfPowerProblems.pdf> (visited 7/8/09).

specific utilities is a traditional rate design approach and may be appropriate for most electric plant facilities, it may miss the forest and focus on the trees when applied to very high voltage “backbone” facilities having a generalized role in supporting reliability and high capacity power transfer. Perhaps as important in this picture is the urgency of the need to build transmission and the need for incentives to that end. Pro rata assignment of costs eliminates not only lawsuits but nitpicking controversies of every sort and delays standing in the path of action. From that point of view, I think FERC may be in a better position to implement a policy leading to prompt improvement in a deficient transmission grid than this court, focused as it is on the inevitable complaints of utilities demanding more for their money. I therefore respectfully dissent from the majority’s unfortunate rejection of FERC’s rate scheme for new transmission lines carrying 500 kV or higher.