

MPUC Tracking Number	MTEP Year/App	MTEP Project Number	CON?	Utility	Description
2005-CX-1	2006 / A	279	Yes	CapX	Add new 230 kV Line between Boswell and Wilton (Bemidji – Grand Rapids 230 kV Line) to support the Bemidji area and the Red River Valley during winter peak conditions. This project is located in both the Northwest and Northeast zones. PUC Docket No. TL-07-1327
2007-NE-N1	2009/C	2548	Yes	MP	New 230/115 kV transformer & transmission line upgrade to 230 kV, Duluth area, St. Louis Co. Recent study indicates this project is not needed until the 2020 timeframe.
2007-NE-N2	2010/A	2547	No	MP	Transmission for Essar Steel, Grand Rapids-Nashwauk areas, Itasca Co., under construction PUC Docket No. TL-09-512
2007-NE-N3	2011/A	2571	Maybe	GRE	MN Pipeline-Menahga 115 kV line (operated at 34.5 kV) This project is impacted by pipeline pumping station voltage drop issues. The line may have to be extended to Hubbard or to RDO-Osage 34.5 kV line, unless voltage drop issues can be corrected. Either option may put line over 10 miles requiring a CON.
2007-NE-N5	2010/A	2576	No	GRE	Pokegama 115 kV distribution substation
2007-NE-N6	2012/B	2632	No	GRE	Onigum 115 kV conversion Line is currently less than 10 miles, however CON may be required if route is altered.
2009-NE-N1	2009/A	2552	No	MP	3 mile Skibo-Hoyt Lakes 138 kV transmission line, Hoyt Lakes area, St. Louis Co.