



12300 Elm Creek Boulevard
Maple Grove, Minnesota 55369-4718
763-445-5000
greatriverenergy.com

2 November 2015

ELECTRONIC FILING

Hon. James Mortenson
Administrative Law Judge
Minnesota, State of
P.O. Box 64620
St. Paul, MN 55164-0620

Re: *In the Matter of the Application of Great River Energy and Minnesota Power for a Certificate of Need and Route Permit for the Menahga Area 115 kV Project in Hubbard, Wadena and Becker Counties, Minnesota*

**Docket Nos. ET2, E015/CN-14-787; ET2, E015/TL-14-797
OAH 5-2500-32715**

Post-Hearing Comment

Dear Judge Mortenson:

On behalf of Great River Energy and Minnesota Power, Great River Energy respectfully submits the following information in response to a question raised during the public hearing held on October 19, 2015 for the Menahga Area 115 kV Project.

Clarification of Information in the Application of Great River Energy and Minnesota Power for a Certificate of Need and Route Permit for the Menahga Area 115 kV Project

Information on Page 6-5 of the application regarding the type of conductor, MVA, and capacity is ambiguous. ***The conductor Great River Energy proposes to use for the Menahga Area 115 kV Project is 477 ACSR, which will have a summer rating of 141.6 MVA.***

Judge Mortenson
2 November 2015
Page 2

Please feel free to call me at 763-445-5214 if you have any questions regarding this filing.

Sincerely,

GREAT RIVER ENERGY

A handwritten signature in cursive script that reads "Carole L. Schmidt".

Carole L. Schmidt
Supervisor, Transmission Permitting and Compliance

s:\legal\environmental\transmission\projects\Menahga Area Project\Public Hearing\Menahga Public Hearing Comment 11-2-15